


UPLOADED TO MASS
E16 802
Sent to PM for their
action



AMACON CONSTRUCTION SERVICE REQUEST FORM

PLEASE FAX TO 416 369-9068

NAME: Victor Tchou SUITE: 802
TEL: 289 521 1314 BUS. TEL: _____
Cell: _____ e-mail: vtchou@gmail.com
Project: _____ Address: _____

DATE OF REQUEST: June 8/2011 Permission to enter: YES ☐ NO ☒

Once received by an Amacon Customer Care Representative, this form becomes property of Amacon. Your request must be based on the Tarion Warranty guidelines - scratches, nicks, dents are not warrantable, unless noted at time of the PDI (Pre-Delivery Inspection). Your request will be reviewed and addressed by an Amacon Representative as soon as a possible. If this is an **Emergency** please contact your concierge **immediately** at 289-521-1313, 24 / hours. If your concern falls under the Common Area Element Warranty Guidelines, please see Property Management to address your concerns or call at 289-521-1199

ITEM#	ROOM/LOCATION	DESCRIPTION
1	Small Bdrm	① Water Stain on wall at vent area
2	Both Bdrms	② Water dropping sounds
3	Living Room	③ Defect in wood flooring
		checked: as follows.
		① - stain was due to water leak from unit 902 - above. A/c. clogged.
	Fixed - <u>LIST</u>	② water dropping from unit 902. water over flowing from Pantry due to clogged drain.

HOMEOWNER SIGNATURE

DATE:

June 8/2011
③ - flooring squeaking - need attention.

John Super.
9/6/11

Grahme Walsh

To: sli@verumest.ca; 'cquan@verumest.ca'
Cc: Mark Fritz
Subject: Elle - 802 - Service Request
Attachments: Elle - 802 - Service Request.pdf

Shirley/ Calvin:

I received this service request and noted that the damage to this unit was caused by a clogged drain of the Fan coil unit in 902 as investigated by your superintendent.

The clogged drain and the incurring damage is the responsibility of property management - it is part of your scope of work to maintain the common areas which includes the fan coils.

Amacon is not the maintenance company for the fan coils and cannot be held responsible for the upkeep of the fan coils almost six months after registration.

Please have your superintendent and/ or contractor deal with the issue at hand.

At no time will Amacon accept any back charges for the repairs to either unit 902 and 802.

Thank you

GRAHME WALSH
CONTRACTS/ CUSTOMER SERVICE MANAGER, CONSTRUCTION

37 Bay Street, Suite 400,
Toronto, ON, M5J 3B2
Tel. 416.369.9069
Fax. 416.369.9068
Email. gwalsh@amacon.com
Web. www.amacon.com

This e-mail is intended only for the named recipient(s) and may contain information that is privileged, confidential and/or exempt from disclosure under applicable law. No waiver of privilege, confidence or otherwise is intended by virtue of communication via the internet. Any unauthorized use, dissemination or copying is strictly prohibited. If you have received this e-mail in error, or are not named as a recipient, please immediately notify the sender and destroy all copies of this e-mail. Please be aware that internet communications are subject to the risk of data corruption and other transmission errors. For information of extraordinary sensitivity, we recommend that our clients use encryption software when they communicate with us by e-mail.

The message is ready to be sent with the following file or link attachments:

Elle - 802 - Service Request