



Soil Engineers Ltd.

CONSULTING ENGINEERS

GEOTECHNICAL • ENVIRONMENTAL • HYDROGEOLOGICAL • BUILDING SCIENCE

100 NUGGET AVENUE, TORONTO, ONTARIO M1S 3A7 • TEL: (416) 754-8515 • FAX: (416) 754-8516

BARRIE	MISSISSAUGA	OSHAWA	NEWMARKET	GRAVENHURST	PETERBOROUGH	HAMILTON
TEL: (705) 721-7863	TEL: (905) 542-7605	TEL: (905) 440-2040	TEL: (905) 853-0647	TEL: (705) 684-4242	TEL: (905) 440-2040	TEL: (905) 777-7956
FAX: (705) 721-7864	FAX: (905) 542-2769	FAX: (905) 725-1315	FAX: (416) 754-8516	FAX: (705) 684-8522	FAX: (905) 725-1315	FAX: (905) 542-2769

INSPECTION REPORT

December 23, 2016

REFERENCE NO.: 1604-C169.31

DATE INSPECTED: December 20, 2016

PROJECT: Goldpark Homes at Mt. Pleasant
Plan No. 43M-2005
City of Brampton

INSPECTED LOT: Lot 101 – Roulette Crescent
Building Permit No.: 16-135897


WORK DESCRIPTION: Foundation Wall – Rebar Inspection

INSPECTOR: Ibrahim Hajaj

COMMENTS:

The upper section of the foundation walls had been continuously reinforced by 2/15M rebar at the time of our inspection

SOIL ENGINEERS LTD.



REPORT GIVEN TO: Hand-written report given on site

Original to: Fieldwalk Investments Inc. - Attn: Ms. Jennelle Ramrattan