It is the builder's complete responsibility to ensure that all plans submitted for approval fully comply with the Architectural Guidelines and all applicable regulations and requirements including zoning provisions and any provisions in the subdivision agreement. The Control Architect is not responsible in any way for examining or approving site (lotting) plans or working drawings with respect to any zoning or building code or permit matter or that any house can be properly built or located on its lot.

This is to certify that these plans comply with the applicable Architectural Design Guidelines approved by the City of BRAMPTON.

JOHN G. WILLIAMS LTD., ARCHITECT APPROVED BY: DATE: MAR 24, 2020 stamp certifies compliance with the appl Design Guidelines only and bears no further




(PER UNIT) INTERNAL GARAGE WIDTH: INTERNAL GARAGE LENGTH: GARAGE DOOR WIDTH:

NOTE: BUILDER TO VERIFY LOCATION OF ALL HYDRANTS, STREET LIGHTS, TRANSFORMERS AND OTHER SERVICES. IF MIN, DIMENSIONS ARE NOT MAINTAINED BUILDER IS TO RELOCATE AT HIS OWN EXPENSI

REG. PLAN No. 43M-2039 R1F-9.0-2452 LOT NUMBER LOT 119 LOT AREA(m $)^2$ 307.1 BLDG AREA(m) 2 N/A LOT COVERAGE(%) N/A No. OF STOREYS MEAN HEIGHT(m) N/A PEAK HEIGHT(m)

N/A

DECK LINE(m)



NO.	ISSUED OR REVISION CO		DWN	СН
1	ISSUED FOR REVIEW	11-MAR-20	_	
2	REVISED PER ENG COMM - FINAL	18-MAR-20	DJH	
				_
				_
				_
			l	

PRIANT FOOTING NOTE:

STHE RESPONSIBILITY OF THE BUILDER TO VERIFY FROM THE

HITECTURAL DRAWINGS BEFORE CONSTRUCTION, WHETHER

JITONAL THICKNESS MAY BE REQUIRED.

T GRADING PLANS ASSUME A TBS TO USF DISTANCE OF 0.23, BASED

FOOTING THICKNESS UP TO 6".

ADDITIONAL FOOTING THICKNESS IS REQUIRED THE USF IS TO BE

VERED BY THE FOLLOWING AMOUNTS:

UP TO 9" FOOTING, LOWER USF BY 0.07



WWW.RNDESIGN.COM T:905-738-3177 WWW.THEPLUSGROUP.CA

TAKEN DESIGN RESPONSIBILITY FOR THE DESIGN WO BEHALF OF **RN DESIGN LTD**,UNDER DIVISION C,PART-3 SUBSECTION-3.2.4 OF THE BUILDING CODE. I AM QUALIFIED AND THE FIRM IS REGISTERED IN THE APPROPRIATE CLASSES /

QUALIFIED DESIGNER BCIN:


GOLD PARK HOMES

MCLAUGHLIN AND MAYFIELD-PH2 BRAMPTON, ON

DRAWING

SITE PLAN

DRAWN BY	SCALE			
DJH	1:250			
PROJECT No.	LOT NUMBER			
19037 (13098 Ph.2)	LOT 119			



WAINWRIGHT DRIVE

URBANTECH NOTES:

 No final utility location information at this time. Urbantech will not be responsible for future changes to design. Builder should notify purchaser's that street hardware and above ground utility furniture may be added or removed rom their frontages.

2) Builder to lower underside of footings where adjacent to RLCB leads. Exact depth to be determined on site during footing excavation.

3) Builder to stake out driveway curb depressions at time of curb installation.

4) Builder to verify location of all hydrants, street lights, transformers and all er services. If min. dimensions are not maintained as per City standards, builder is to relocate at his own expense.

6) Final fence design have not been provided at this time. Purchaser to be advised that actual fencing details may not be as shown on this plan.

URBANTECH CONSULTING

We certify that the proposed grades at the lot corners are correct, and that the lot grading of the subject lot is in conformity to the approved subdivision grading plans and City standards

REVIEWED BY: M.W. DATE: Mar 24/20

