

Planning and Development Services

Building Division 8850 McLaughlin Road, Unit 1 Brampton, ON L6Y 5T1

WATER PIPE SIZING AND PLUMBING DATA SHEET CERTIFIED MODEL WITH ONE DWELLING UNIT

THIS TABLE IS APPLICABLE FOR A HOUSE AFTER DECEMBER 31, 2017

Builder Name:


GREENPARK HOMES

Certified Model Name:

MILLWOOD 12 -407 2/

Optional Floor Layout:

Application No.:



Description	Basement Floor Qty.	First Floor Qty.	Second Floor Qty.	Third Floor Qty.
Bidet				
Extra Shower			1	
Lav			1	
Bar Sink				
Powder room (7)		1		
Kitchen Sink		1		
Dishwasher		1		
Laundry Tub			1	
Washing Machine			1	
Hose Bib		2		Same

Total Fixture Units 30

Minimum Diametre of Water Service Pipe

Required from the Property Line to the

House (Inch)

Notes:

(1) A potable water system shall be designed, constructed and installed to conform to good engineering practice appropriate to the circumstances, such as that described in the ASHRAE Handbooks and ASPE Data Books.

1

- (2) No water system between the point of connection with the water service pipe or the water meter and the first branch that supplies a water heater that serves more than one fixture shall be less than ¾ in. in size.
- (3) The minimum water pressure at the entry to the building is 200 kPa, and the total maximum length of the water system is 90 m.
- (4) In a hot water distribution system of a developed length of more than 30 m from the HWT to the farthest fixture or supplying more than 4 storeys, the water temperature shall be maintained by, (a) recirculation, or (b) a self-regulating heat tracing system.
- (5)
 - Where piping may be exposed to freezing conditions, it shall be protected from the effects of freezing.
- (6) A bathroom group consists of 1 water closet, 1 lavatory, and 1 bathtub (with or without showerhead)
- (7) A powder room group consists of 1 water closet and 1 lavatory.

PLEASE SEE NOTES AS T OF THE REV

Swhite

