

CITY OF HAMILTON
Building Division

Permit No. 20-199355


THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by

IAN 15 2021
fascia raised by 16"
DATE
FOR OFFICE BUILDING OFFICIAL

6/12 roof pitch unless noted



ASPHALT SHINGLES
FINISHED OVERHANG: 12"
2x6 EXTERIOR WALLS
2x6 FASCIA BOARD
HEEL: R.T.M.C.


All conventional framing to conform with
Part 9 of O.B.C. 2012 (2019 amendment).
Roof rafters that cross over or meet trusses
to be min. 2x4 SPF #2 @ 24" o/c with a
vertical post to the truss at each cross
point. Vertical posts longer than 6' to have
lateral bracing so that the distance between
the post end points and lateral bracing does
not exceed 6'.

DESIGN CONFORMS WITH OBC 2012
(2019 amendment) OCCUPANCY:
RESIDENTIAL | PART: 9
Ss = 31.35 psf | Sr = 8.4 psf

DESIGN LOADS:
TCSL = 25.6 psf
TCDL = 6.0 psf
BCLL = 0.0 psf
BCDL = 7.4 psf

HARDWARE:
LUS24 - (O)
LJS26DS - (V)
HGUS26-2 - (XX)
LUS26-2-(VV)

BEAMS:
B40= B41 = B42=
2- 2x10 SPF #2

 DENOTES:
CONVENTIONAL
FRAMING

M13125




Job Track: 51225
Plan Log: 202401
Layout ID: 412449

Builder / Location:
GREEN PARK HOMES / WATERDOWN
Project: **RUSSELL GARDENS PH.3**
Date: 2020-09-10 Sales: Mario DiCano Designer: JG

Model / Elevation:
MOUNTAINASH 4-014/3

Milek ver 8.3.3.247

THESE DRAWINGS CONSTITUTE THE PROPERTY OF TAMARACK ROOF TRUSSES INC., SHALL NOT BE REPRODUCED, PUBLISHED, OR
REDISTRIBUTED IN ANY MANNER OR UTILIZED FOR ANY PURPOSE OTHER THAN THE MANUFACTURE OF TRUSSES BY
TAMARACK ROOF TRUSSES INC AND WILL BE RETRACTED BY TAMARACK ROOF TRUSSES INC IF UTILIZED FOR ANY OTHER PURPOSE.



DELIVERY SHIPLIST

Lumber Yard: TAMARACK LUMBER
 Builder: GREEN PARK HOMES
 Project: RUSSELL GARDENS PH.3
 Location: WATERDOWN
 Model: MOUNTAINASH 4-0/4
 Lot #:
 Elevation: 3

Job Track: 51225
 PlanLog: 202401
 Layout ID: 412449
 Ref #
 Page: 1 of 3
 Date: 09-10-2020
 Designer:
 Sales Rep: Mario DiCano

Roof Trusses

PROFILE	QTY PLY	MARK TYPE	PITCH	SPAN	HEIGHT	LUMBER	OVERHANG LEFT RIGHT	HEEL HEIGHT LEFT RIGHT	LBS. BFT.	BUNDLE # STACK #	LOAD BY REMARKS
	2	T41 Hip	6 /12	35-02-00	5-01-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	277.99 174.00		
	2	T42 Hip	6 /12	35-02-00	6-01-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	277.12 174.67		
	2	T43 Hip	6 /12	35-02-00	7-01-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	289.07 179.67		
	2	T44 Hip	6 /12	35-02-00	8-01-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	290.73 183.33		
	2	T45 Hip	6 /12	35-02-00	9-01-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	301.87 191.33		
	6	T46 Common	6 /12	35-02-00	9-11-08	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	910.08 558.00		
	1 2-ply	T47 Hip Girder	6 /12	16-07-00	4-01-04	2 x 4 2 x 6	1-03-08	1-02-00 2-02-00	158.02 100.67		
	1	T48 Hip	6 /12	16-07-00	5-01-04	2 x 4	1-03-08	1-02-00 2-02-00	68.15 43.33		
	1	T49 Common	6 /12	16-07-00	5-09-12	2 x 4	1-03-08	1-02-00 2-02-00	67.14 42.33		
	1	T50 Hip Girder	6 /12	10-11-00	2-07-04	2 x 4	1-03-08 1-03-08	1-02-00 1-02-00	42.73 28.33		
	1	T51 Hip	6 /12	10-11-00	4-07-04	2 x 4	1-03-08 1-03-08	2-02-00 2-02-00	51.54 34.50		
	1	T52 Flat	0 /12	9-04-00	2-10-00	2 x 4		2-10-00 2-10-00	36.11 23.83		
	1	G52 GABLE	0 /12	9-04-00	2-10-00	2 x 4		2-10-00 2-10-00	33.75 23.33		
	1	T53 Flat Girder	0 /12	9-04-00	3-10-00	2 x 6		3-10-00 3-10-00	50.9 31.50		




DELIVERY SHIPLIST

Lumber Yard: TAMARACK LUMBER
 Builder: GREEN PARK HOMES
 Project: RUSSELL GARDENS PH.3
 Location: WATERDOWN
 Model: MOUNTAINASH 4-0/4
 Lot #:
 Elevation: 3

Job Track: 51225
 PlanLog: 202401
 Layout ID: 412449
 Ref #
 Page: 2 of 3
 Date: 09-10-2020
 Designer:
 Sales Rep: Mario DiCano

Roof Trusses

PROFILE	QTY PLY	MARK TYPE	PITCH	SPAN	HEIGHT	LUMBER	OVERHANG LEFT RIGHT	HEEL HEIGHT LEFT RIGHT	LBS. BFT.	BUNDLE # STACK #	LOAD BY REMARKS
	1 2-ply	T54 Jack-Closed Girder	6 /12	6-10-08	4-01-04	2 x 4 2 x 6		8-00 4-01-04	59.61 37.33		
	1	T300 Hip Girder	6 /12	17-02-00	5-05-04	2 x 4 2 x 6	1-03-08 1-03-08	2-06-00 2-06-00	88.18 55.00		
	1 2-ply	T301 Jack-Closed Girder	6 /12	5-10-08	4-01-04	2 x 4 2 x 6		1-02-00 4-01-04	58.39 37.67		
	1 2-ply	T400 Hip Girder	6 /12	35-02-00	4-01-04	2 x 4 2 x 6	1-03-08 1-03-08	1-02-00 1-02-00	337.56 208.00		
	1 2-ply	T400Z Hip Girder	6 /12	35-02-00	4-01-04	2 x 4 2 x 6	1-03-08 1-03-08	1-02-00 1-02-00	337.56 208.00		
	9	J1 Jack-Open	6 /12	5-10-08	4-01-04	2 x 4	1-03-08	1-02-00 4-01-04	151.15 96.00		
	4	J40 Jack-Open	6 /12	3-09-08	4-01-04	2 x 4		2-02-08 4-01-04	52.34 35.33		
	4	J41 Jack-Open	6 /12	2-10-08	2-07-04	2 x 4	1-03-08	1-02-00 2-07-04	38.2 24.00		
	4	J300 Jack-Open	6 /12	5-10-08	5-05-04	2 x 4	1-03-08	2-06-00 5-05-04	81.15 54.00		
	3	C40 Jack-Open	6 /12	3-09-07	3-00-12	2 x 4	1-03-08 2-01-01	1-02-00 3-00-12	42.4 26.00		
	3	C41 Jack-Open	6 /12	1-09-07	2-00-12	2 x 4	1-03-08 4-01-01	1-02-00 2-00-12	34.75 22.00		
	3	C42 Jack-Open	6 /12	1-10-08	3-00-12	2 x 4	1-03-08 1-10-15	1-02-00 2-01-04	28.71 18.00		
	3	C43 Jack-Open	6 /12	1-09-07	2-00-12	2 x 4	1-03-08 1-01	1-02-00 2-00-12	21.06 14.00		
	2	C44 Jack-Open	6 /12	1-10-15	2-01-08	2 x 4	1-03-08 11-09	1-02-00 2-01-08	16.64 10.67		



DELIVERY SHIPLIST

Lumber Yard: TAMARACK LUMBER
 Builder: GREEN PARK HOMES
 Project: RUSSELL GARDENS PH.3
 Location: WATERDOWN
 Model: MOUNTAINASH 4-014
 Lot #:
 Elevation: 3

Job Track: 51225
 PlanLog: 202401
 Layout ID: 412449
 Ref #
 Page: 3 of 3
 Date: 09-10-2020
 Designer:
 Sales Rep: Mario DiCano

Roof Trusses

PROFILE	QTY PLY	MARK TYPE	PITCH	SPAN	HEIGHT	LUMBER	OVERHANG LEFT RIGHT	HEEL HEIGHT LEFT RIGHT	LBS. BFT.	BUNDLE # STACK #	LOAD BY REMARKS
	2	C45 Jack-Open	6 /12	1-10-15	2-01-08	2 x 4	1-03-08 1-01	1-02-00 2-01-08	14.65 9.33		
	2	C300 Jack-Open	6 /12	3-09-07	4-04-12	2 x 4	1-03-08 2-01-01	2-06-00 4-04-12	35.25 23.00		
	2	C301 Jack-Open	6 /12	1-09-07	3-04-12	2 x 4	1-03-08 4-01-01	2-06-00 3-04-12	30 20.33		
	2	C302 Jack-Open	6 /12	1-10-08	4-04-12	2 x 4	1-03-08 1-10-15	2-06-00 3-05-04	26.05 17.67		
	2	C303 Jack-Open	6 /12	1-09-07	3-04-12	2 x 4	1-03-08 1-01	2-06-00 3-04-12	20.88 15.00		

TOTAL # TRUSS= 79

TOTAL BFT OF ALL TRUSSES= 2720.15 BFT.

TOTAL WEIGHT OF ALL TRSSES 4327.53 LBS


HARDWARE

QTY	TYPE	MODEL	LENGTH
2	Hardware	HGUS26-2	
5	Hardware	LJS26DS	
6	Hardware	LUS24	
3	Hardware	LUS26-2	

TOTAL NUMBER OF ITEMS= 16

JOB NAME 408150	TRUSS NAME T1	QUANTITY 1	PLY 2	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 Mitak Industries, Inc. Sat Apr 25 11:02:17 2020 Page 1
ID:7vF?aG0E03cRUj6X1jSkziWYK-VShX5DRAXNen15LAM,IsZu8zCRhp/kAQnpVGMyzNCnc
Scale = 1:54.4



NUMBER	SIZE	QUANTITY	DESCR.
N. L. G. A. RULES			
CHORDS			
R - A	2x4	DRY	No.2
A - D	2x6	DRY	No.2
D - F	2x6	DRY	No.2
F - I	2x6	DRY	No.2
J - L	2x4	DRY	No.2
R - P	2x6	DRY	No.2
L - L	2x6	DRY	No.2
L - J	2x6	DRY	No.2

ALL WEBS 2x3 DRY SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN)	LOAD (PLF)
TOP CHORDS : (0.122"x3") SPIRAL NAILS		
R - A	12	TOP
F - J	12	TOP
A - D	12	SIDE (183.1)
D - F	12	SIDE (0.0)
F - I	12	SIDE (0.0)
BOTTOM CHORDS : (0.122"x3") SPIRAL NAILS		
R - P	12	SIDE (183.1)
L - L	12	SIDE (183.1)
L - J	12	SIDE (0.0)
WEBS : (0.122"x3") SPIRAL NAILS		
2x3	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

SIDE - PLF SHOWN IS THE EQUIVALENT UDL APPLIED TO ONE SIDE THAT THE CORRESPONDING NAILING PATTERN SHALL BE CAPABLE OF TRANSFERING. REMAINING PLF MUST BE APPLIED ON THE OPPOSITE SIDE OR ON THE TOP.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	REQ'D
GROSS REACTION				
JT	VERT	HORZ	DOWN	UPLIFT
R	3052	0	3052	0
J	3118	0	3118	0

UNFACTORED REACTIONS

1ST LOASE	MAX. MIN. COMPONENT REACTIONS
JT	COMBINED
R	2161
J	2209

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) R, J

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MEMB.	MAX. FACTORED	FACTORED	WEBS	MEMB.	MAX. FACTORED
FR-TO				FR-TO		
R-A	-2974 / 0	0.0	0.0	K-I	0 / 5083	0.63 (1)
A-S	-4326 / 0	-91.8	-91.8	A-Q	0 / 5078	0.63 (1)
S-T	-4326 / 0	-91.8	-91.8	K-H	-2465 / 0	0.30 (1)
T-B	-4326 / 0	-91.8	-91.8	Q-B	-2463 / 0	0.29 (1)
B-U	-6698 / 0	-91.8	-91.8	M-H	0 / 2804	0.35 (1)
U-V	-6696 / 0	-91.8	-91.8	B-O	0 / 2808	0.35 (1)
V-C	-6696 / 0	-91.8	-91.8	C-Q	-1326 / 0	0.16 (1)
C-D	-7505 / 0	-91.8	-91.8	N-G	0 / 956	0.15 (1)
D-W	-7505 / 0	-91.8	-91.8	C-N	0 / 959	0.12 (1)
W-E	-7505 / 0	-91.8	-91.8	N-E	-851 / 0	0.10 (1)
E-X	-7505 / 0	-91.8	-91.8			
X-Y	-7505 / 0	-91.8	-91.8			
Y-F	-7505 / 0	-91.8	-91.8			
F-Z	-7505 / 0	-91.8	-91.8			
Z-G	-7505 / 0	-91.8	-91.8			
G-AA	-6698 / 0	-91.8	-91.8			
AA-AB	-6698 / 0	-91.8	-91.8			
AB-AC	-6698 / 0	-91.8	-91.8			
AC-H	-6698 / 0	-91.8	-91.8			
H-AD	-4330 / 0	-91.8	-91.8			
AD-AE	-4330 / 0	-91.8	-91.8			
AE-AF	-4330 / 0	-91.8	-91.8			
AF-I	-4330 / 0	-91.8	-91.8			
I-J	-3028 / 0	0.0	0.0			

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF
DL = 8.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN/C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 8.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.16")
CALCULATED VERT. DEFL.(LL) = L/999 (0.20")
ALLOWABLE DEFL.(TL) = L/360 (1.16")
CALCULATED VERT. DEFL.(TL) = L/999 (0.38")

CSI: TC=0.35/1.00 (H-I), BC=0.49/1.00 (M-N),
WB=0.63/1.00 (K-L), SS=0.17/1.00 (H-I)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 518 354 1657 788 1987 1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.66 (K) (INPUT = 0.90)
JSI METAL = 0.42 (P) (INPUT = 1.00)



Structural component only
DWG# T-2007063 1/2

CONTINUED ON PAGE 2

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408150	T1	1	2	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:02:47 2020 Page 2
ID:7vF?aG0E03cRU6X1SrkziWYK-vShX5DRAXNen1SLAM IsZu8zCRhpfkAQNPVGMzNCnc

PLATES (table in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW-1	MT20	6.0	9.0		Edge
B	TMVW-1	MT20	5.0	6.0	2.50	2.75
C	TMVW-1	MT20	5.0	6.0		
D	TS-1	MT20	5.0	6.0		
E	TMVW-1	MT20	3.0	6.0		
F	TS-1	MT20	5.0	6.0		
G	TMVW-1	MT20	5.0	6.0		
H	TMVW-1	MT20	5.0	6.0	2.50	2.75
I	TMVW-1	MT20	6.0	9.0		Edge
J	BMV1+p	MT20	3.0	6.0		
K	BMVW-1	MT20	6.0	9.0	3.00	4.25
L	BS-1	MT20	5.0	6.0		
M	BMVW-1	MT20	5.0	6.0	2.50	2.75
N	BMVW-1	MT20	5.0	6.0		
O	BMVW-1	MT20	6.0	9.0	2.50	2.75
P	BS-1	MT20	5.0	6.0		
Q	BMVW-1	MT20	6.0	9.0	3.00	4.25
R	BMV1+p	MT20	3.0	6.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

LOADING

TOTAL LOAD CASES: 14)


CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MAX. UNBRAC LENGTH FR-TO	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)
FR-TO		FROM TO					
K-AR	0/0	-18.5	-18.5	0.06 (4)	10.00		
AR-AS	0/0	-18.5	-18.5	0.06 (4)	10.00		
AS-AT	0/0	-18.5	-18.5	0.06 (4)	10.00		
AT-J	0/0	-18.5	-18.5	0.06 (4)	10.00		

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
B	5-10-12	-110	-110		FRONT	VERT	TOTAL		C1
C	11-10-12	-110	-110		FRONT	VERT	TOTAL		C1
D	13-10-12	-110	-110		FRONT	VERT	TOTAL		C1
O	11-10-12	-26	-26		FRONT	VERT	TOTAL		C1
P	9-10-12	-26	-26		FRONT	VERT	TOTAL		C1
Q	5-10-12	-26	-26		FRONT	VERT	TOTAL		C1
S	1-10-12	-110	-110		FRONT	VERT	TOTAL		C1
T	3-10-12	-110	-110		FRONT	VERT	TOTAL		C1
U	7-10-12	-110	-110		FRONT	VERT	TOTAL		C1
V	9-10-12	-110	-110		FRONT	VERT	TOTAL		C1
W	15-10-12	-110	-110		FRONT	VERT	TOTAL		C1
X	17-10-12	-110	-110		FRONT	VERT	TOTAL		C1
Y	19-10-12	-110	-110		FRONT	VERT	TOTAL		C1
Z	21-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AA	23-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AB	25-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AC	27-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AD	29-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AE	31-10-12	-110	-110		FRONT	VERT	TOTAL		C1
AF	33-10-12	-113	-113		FRONT	VERT	TOTAL		C1
AG	1-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AH	3-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AI	7-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AJ	13-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AK	15-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AL	17-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AM	19-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AN	21-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AO	23-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AP	25-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AQ	27-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AR	29-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AS	31-10-12	-26	-26		FRONT	VERT	TOTAL		C1
AT	33-10-12	-27	-27		FRONT	VERT	TOTAL		C1

CONNECTION REQUIREMENTS

- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.



Structural component only
DWG# T-2007063 7/2

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408150	T1Z	1	2	GREEN PARK HOMES	

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:49 2020 Page 2
ID:7vF?aG0E03cRUj6X1S/kziWYK-SrpiVvTQ3 UVGPVZTPnKeJDIEFf/bWiq7 NRrzNCna

PLATES (table is in inches)					
JT	TYPE	PLATES	W	LEN	Y X
A	TMVW-t	MT20	6.0	9.0	Edge
B	TMWW-t	MT20	5.0	6.0	2.50 2.75
C	TMWW-t	MT20	5.0	6.0	
D	TS-t	MT20	5.0	6.0	
E	TMW+w	MT20	3.0	6.0	
F	TS-t	MT20	5.0	6.0	
G	TMWW-t	MT20	5.0	6.0	
H	TMWW-t	MT20	5.0	6.0	2.50 2.75
I	TMVW-t	MT20	6.0	9.0	Edge
J	BMV1+p	MT20	3.0	6.0	
K	BMWW-t	MT20	6.0	9.0	3.00 4.25
L	BS-t	MT20	5.0	6.0	
M	BMWW-t	MT20	5.0	6.0	2.50 2.75
N	BMWWWW-t	MT20	5.0	6.0	
O	BMWW-t	MT20	5.0	6.0	2.50 2.75
P	BS-t	MT20	5.0	6.0	
Q	BMWW-t	MT20	6.0	9.0	3.00 4.25
R	BMV1+p	MT20	3.0	6.0	


Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
AC	18-3-8	-1293	-1293	---	BACK	VERT	TOTAL	---	C1


CONNECTION REQUIREMENTS

- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.



Structural component only
DWG# T-2007064 72

Structural component only
DWG# T-2007065



LUMBER

N.L.G.A. RULES

CHORDS	SIZE	LUMBER	DESCR.
R - A	2x4	DRY No.2	SPF
A - C	2x4	DRY No.2	SPF
C - G	2x4	DRY No.2	SPF
G - I	2x4	DRY No.2	SPF
I - J	2x4	DRY No.2	SPF
J - O	2x4	DRY No.2	SPF
O - M	2x4	DRY No.2	SPF
M - J	2x4	DRY No.2	SPF

ALL WEBS 2x3 DRY No.2 SPF
DRY: SEASONED LUMBER.

PLATES (table in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW-1	MT20	5.0	8.0	2.00	2.50
B	TMVW-1	MT20	5.0	6.0		
C	TS-1	MT20	3.0	6.0		
D	TMVW-1	MT20	4.0	4.0		
E	TMVW-1	MT20	2.0	4.0		
F	TMVW-1	MT20	4.0	4.0		
G	TS-1	MT20	3.0	6.0		
H	TMVW-1	MT20	5.0	8.0		
I	TMVW-1	MT20	3.0	4.0	2.00	2.50
J	BMV1-p	MT20	5.0	6.0		
K	BMVW-1	MT20	5.0	6.0	2.00	2.50
L	BMVW-1	MT20	5.0	6.0		
M	BS-1	MT20	3.0	6.0		
N	BMVW-1	MT20	4.0	9.0		
O	BS-1	MT20	3.0	6.0		
P	BMVW-1	MT20	5.0	6.0		
Q	BMVW-1	MT20	5.0	6.0	2.00	2.50
R	BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION VERT	MAXIMUM FACTORED GROSS REACTION DOWN	INPUT BRG IN-SX	REQD BRG IN-SX
R	1920	0	0	3-8
J	1920	0	0	3-8

UNFACTORED REACTIONS

JT	1ST CASE COMBINED	MAX. MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
R	1358	881 / 0	0 / 0	0 / 0	467 / 0	0 / 0
J	1358	891 / 0	0 / 0	0 / 0	467 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) R, J

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURIN SPACING = 3.58 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF A-R, I-J.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)	
FR-TO		FROM TO		FR-TO			
R-A	-1875 / 0	0.0	0.0 0.33 (1)	K-I	0 / 2368	0.53 (1)	
A-B	-1691 / 0	-91.8	-91.8 0.55 (1)	A-Q	0 / 2368	0.53 (1)	
B-C	-2608 / 0	-91.8	-91.8 0.68 (1)	K-H	-1538 / 0	0.90 (1)	
C-D	-2608 / 0	-91.8	-91.8 0.68 (1)	Q-B	-1538 / 0	0.90 (1)	
D-E	-2608 / 0	-91.8	-91.8 0.58 (1)	L-H	0 / 1304	0.29 (1)	
E-F	-2608 / 0	-91.8	-91.8 0.58 (1)	B-P	0 / 1304	0.29 (1)	
F-G	-2608 / 0	-91.8	-91.8 0.68 (1)	L-F	-826 / 0	0.48 (1)	
G-H	-2608 / 0	-91.8	-91.8 0.68 (1)	P-D	-826 / 0	0.48 (1)	
H-I	-1691 / 0	-91.8	-91.8 0.55 (1)	N-F	0 / 453	0.10 (1)	
I-J	-1875 / 0	0.0	0.0 0.33 (1)	D-N	0 / 453	0.10 (1)	
R-Q	0 / 0	-18.5	-18.5 0.15 (4)	N-E	-537 / 0	0.31 (1)	
Q-P	0 / 1691	-18.5	-18.5 0.35 (1)				
P-O	0 / 2608	-18.5	-18.5 0.47 (1)				
O-N	0 / 2608	-18.5	-18.5 0.47 (1)				
N-M	0 / 2608	-18.5	-18.5 0.47 (1)				
M-L	0 / 2608	-18.5	-18.5 0.47 (1)				
L-K	0 / 1691	-18.5	-18.5 0.35 (1)				
K-J	0 / 0	-18.5	-18.5 0.15 (4)				

TOTAL WEIGHT = 2 X 153 = 305 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.8 PSF
DL = 6.0 PSF	
BOT CH.	LL = 0.0 PSF
DL = 7.4 PSF	
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. O.C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCC 2010, NBC 2012, ABC 2019
- PART 9 OF NBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.16")

CALCULATED VERT. DEFL.(LL) = L/999 (0.18")

ALLOWABLE DEFL.(TL) = L/360 (1.16")

CALCULATED VERT. DEFL.(TL) = L/999 (0.33")

CSI: TO=0.66/1.00 (F-H:1), BC=0.47/1.00 (N-P:1), WS=0.90/1.00 (H-K:1), SSI=0.25/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 618 354 1987 798 1987 1655

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP = 0.88 (I) (INPUT = 0.90)

JSI METAL = 0.83 (M) (INPUT = 1.00)



Structural component only
DWG# T-2007066

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408150	T4	2	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington					
Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:52 2020 Page 1					
ID:7VF?aG0E03cRUj6X1jSkzWYK-sOUQ8wVJMV47IE88XL1GyrNSOJK?gW4C12AZnCnX					
Scale = 1:54.6					



CHORDS	SIZE	LUMBER	DESCR.
P - A	2x4	DRY	No.2
A - C	2x4	DRY	No.2
C - F	2x4	DRY	No.2
F - H	2x4	DRY	No.2
I - H	2x4	DRY	No.2
P - N	2x4	DRY	No.2
N - K	2x4	DRY	No.2
K - I	2x4	DRY	No.2
ALL WEBS	2x3	DRY	No.2
EXCEPT			
J - H	2x4	DRY	No.2

PLATES (table is in inches)	W	LEN	Y	X
JT TYPE				
A - TMVW-I	MT20	5.0	6.0	2.25
B - TMVW-I	MT20	4.0	6.0	
C - TS-I	MT20	3.0	6.0	
D - TMVW-I	MT20	4.0	4.0	
E - TMVW-I	MT20	2.0	4.0	
F - TS-I	MT20	3.0	6.0	
G - TMVW-I	MT20	4.0	6.0	
H - TMVW-I	MT20	5.0	6.0	2.50
I - BMV1-p	MT20	3.0	4.0	
J - BMVW-I	MT20	5.0	6.0	2.50
K - BS-I	MT20	3.0	6.0	
L - BMVW-I	MT20	4.0	9.0	
M - BMVW-I	MT20	4.0	8.0	
N - BS-I	MT20	3.0	6.0	
O - BMVW-I	MT20	5.0	6.0	2.00
P - BMV1-p	MT20	3.0	4.0	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
JT	VERT	DOWN	UPLIFT	IN-SX
P	1920	0	0	3-8
I	1920	0	0	3-8

UNFACTORED REACTIONS	1ST LOASE	MAX/MIN. COMPONENT REACTIONS	DEAD	SOIL
JT	COMBINED	SNOW	LIVE	PERM. LIVE
P	1358	891 / 0	0 / 0	0 / 0
I	1358	891 / 0	0 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) P, I

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.31 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF A-P, H-I, B-D, D-L, G-J.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING
TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSI (LC)	UNBRAC LENGTH FR-TO	WEBS	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)
FR-TO					FR-TO		
P-A	-1888 / 0	0.0	0.0	0.43 (1)	A-O	0 / 2315	0.52 (1)
A-B	-1882 / 0	-91.8	-91.8	0.82 (1)	O-B	-1468 / 0	0.47 (1)
B-C	-2416 / 0	-91.8	-91.8	0.95 (1)	B-M	0 / 1059	0.24 (1)
C-D	-2416 / 0	-91.8	-91.8	0.95 (1)	M-D	-617 / 0	0.54 (1)
D-E	-2415 / 0	-91.8	-91.8	0.74 (1)	D-L	-2 / 0	0.00 (1)
E-F	-2415 / 0	-91.8	-91.8	0.96 (1)	L-E	-616 / 0	0.54 (1)
F-G	-2415 / 0	-91.8	-91.8	0.96 (1)	G-L	0 / 1054	0.24 (1)
G-H	-1883 / 0	-91.8	-91.8	0.82 (1)	J-G	-1465 / 0	0.47 (1)
H-I	-1888 / 0	0.0	0.0	0.43 (1)	I-H	0 / 2316	0.37 (1)
P-O	0 / 0	-18.5	-18.5	0.22 (4)	O-P	0 / 0	0.00
O-N	0 / 1662	-18.5	-18.5	0.39 (1)	N-O	0 / 0	0.00
N-M	0 / 1662	-18.5	-18.5	0.39 (1)	M-N	0 / 0	0.00
M-L	0 / 2416	-18.5	-18.5	0.47 (1)	L-M	0 / 0	0.00
L-K	0 / 1883	-18.5	-18.5	0.39 (1)	K-L	0 / 0	0.00
K-J	0 / 1663	-18.5	-18.5	0.39 (1)	J-K	0 / 0	0.00
J-I	0 / 0	-18.5	-18.5	0.22 (4)	I-J	0 / 0	0.00

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.8	PSF
	DL = 6.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (1.16")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.15")
ALLOWABLE DEFL.(TL) = $L/360$ (1.16")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.29")

CSI: TC=0.98/1.00 (E-G:1), BC=0.47/1.00 (L-M:1);
WB=0.54/1.00 (D-M:1), SI=0.30/1.00 (G-H:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1867 798 1987 1856

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.90 (A) (INPUT = 0.90)
JSI METAL= 0.53 (K) (INPUT = 1.00)




Structural component only
DWG# T-2007067

JOB NAME 408150	TRUSS NAME T5	QUANTITY 10	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
--------------------	------------------	----------------	----------	-------------------------------	----------

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITak Industries, Inc. Sat Apr 25 11:02:53 2020 Page 1
ID:17vF7aG0E03cRUj6X1jSkzWYK-Kc2pL.GWx7D?x10pKfSg9Os5sl3ONJkybacznCnW
34-8 34 10 0
34-8 34 10 0
Scale = 1:54.8



CHORDS	SIZE	DRY	LUMBER
P - A	2x4	DRY	No.2
A - C	2x4	DRY	No.2
C - F	2x4	DRY	No.2
F - H	2x4	DRY	No.2
H - J	2x4	DRY	No.2
J - K	2x4	DRY	No.2
K - L	2x4	DRY	No.2
L - I	2x4	DRY	No.2

ALL WEBS EXCEPT	SIZE	DRY	LUMBER
J - G	2x3	DRY	No.2
O - B	2x3	DRY	No.2
L - E	2x3	DRY	No.2
M - D	2x3	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMWW-t	MT20	5.0	6.0	2.50	2.50
B	TMWW-t	MT20	4.0	6.0		
C	TS-t	MT20	3.0	6.0		
D	TMWW-t	MT20	2.0	4.0		
E	TMWW-t	MT20	4.0	4.0		
F	TS-t	MT20	3.0	6.0		
G	TMWW-t	MT20	4.0	6.0		
H	TMWW-t	MT20	5.0	6.0	2.50	2.50
I	BMV-t-p	MT20	3.0	4.0		
J	BMWW-t	MT20	5.0	6.0	2.50	2.50
K	BS-t	MT20	3.0	6.0		
L	BMWW-t	MT20	4.0	6.0		
M	BMWW-t	MT20	4.0	6.0		
N	BS-t	MT20	3.0	6.0		
O	BMWW-t	MT20	5.0	6.0	2.50	2.50
P	BMV-t-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	HORZ	DOWN	HORZ
P	1920	0	1920	0
I	1920	0	1920	0

UNFACTORED REACTIONS

JT	1ST LOASE COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
P	1358	891 / 0	0 / 0	0 / 0	0 / 0	467 / 0	0 / 0
I	1358	891 / 0	0 / 0	0 / 0	0 / 0	467 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) P, I

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.56 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF A-P, H-I, G-J, B-O, E-M.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PL)	FACTORED HORZ. LOAD (LC)	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PL)	FACTORED HORZ. LOAD (LC)
FR-TO							
P-A	-1868 / 0	0.0	0.0	0.55 (1)	4.91	J-H	0 / 2171
A-B	-1458 / 0	-91.8	-91.8	0.80 (1)	4.28	A-O	0 / 2171
B-C	-2108 / 0	-91.8	-91.8	0.90 (1)	3.58	J-G	-1483 / 0
C-D	-2108 / 0	-91.8	-91.8	0.90 (1)	3.58	O-B	-1482 / 0
D-E	-2108 / 0	-91.8	-91.8	0.68 (1)	4.00	L-G	0 / 982
E-F	-2108 / 0	-91.8	-91.8	0.90 (1)	3.58	B-M	0 / 980
F-G	-2108 / 0	-91.8	-91.8	0.90 (1)	3.58	L-E	-613 / 0
G-H	-1458 / 0	-91.8	-91.8	0.79 (1)	4.27	M-D	-612 / 0
H-I	-1868 / 0	0.0	0.0	0.55 (1)	4.91	M-E	-2 / 0
P-O	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
O-N	0 / 1488	-18.5	-18.5	0.36 (1)	10.00		
N-M	0 / 1458	-18.5	-18.5	0.38 (1)	10.00		
M-L	0 / 2108	-18.5	-18.5	0.42 (1)	10.00		
L-K	0 / 1488	-18.5	-18.5	0.36 (1)	10.00		
K-J	0 / 1458	-18.5	-18.5	0.38 (1)	10.00		
J-I	0 / 0	-18.5	-18.5	0.22 (4)	10.00		

TOTAL WEIGHT = 10 X 178 = 1785 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
	DL = 6.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN./C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBC 2010, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.16")

CALCULATED VERT. DEFL.(LL) = L/999 (0.12")

ALLOWABLE DEFL.(TL) = L/360 (1.16")

CALCULATED VERT. DEFL.(TL) = L/999 (0.24")

CSI: TC=0.90/1.00 (B-D:1), BC=0.42/1.00 (L-M:1)

WB=0.78/1.00 (E-L:1), SS=0.31/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES


PLATE GRIP (DRY) SHEAR SECTION	(PSI)	(PLI)	(PLI)
MAX MIN MAX MIN MAX MIN			
MT20	618	354	1687
	788	1987	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.87 (A) (INPUT = 0.90)

JSI METAL= 0.47 (N) (INPUT = 1.00)



Structural component only
DWG# T-2007068

JOB NAME 408150	TRUSS NAME T6	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington					



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - C	2x4	DRY	No.2
C - E	2x4	DRY	No.2
E - G	2x4	DRY	No.2
M - B	2x4	DRY	No.2
H - F	2x4	DRY	No.2
M - J	2x6	DRY	No.2
J - H	2x6	DRY	No.2

ALL WEBS 2x3 DRY No.2
EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMWV-p	MT20	5.0	6.0	Edge	2.75
C TTWW-m	MT20	5.0	6.0	2.00	1.50
D TMW-w	MT20	2.0	4.0		
E TMWV-m	MT20	5.0	6.0	2.00	1.50
F TMWV-p	MT20	5.0	6.0	Edge	2.75
H BMV1-p	MT20	3.0	8.0		
I BMWV-1	MT20	5.0	6.0	2.50	2.75
J BS-1	MT20	5.0	6.0		
K BMWVW-1	MT20	5.0	6.0		
L BMWVW-1	MT20	5.0	6.0	2.50	2.75
M BMV1-p	MT20	3.0	6.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT VERT	1888	1888	0	5-8
M VERT	1422	1422	0	5-8
H VERT	1422	1422	0	5-8

UNFACTORED REACTIONS

1ST CASE	MAX. MIN. COMPONENT REACTIONS
JT COMBINED	1329
M COMBINED	909 / 0
H COMBINED	685 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) M, H

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.55 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC)	MAX. FACTORED VERT. LOAD (LC)	WEBS	MAX. FACTORED FORCE (LBS)	MAX. FACTORED VERT. LOAD (LC)
FR-TO					FR-TO		
A-B	0 / 41	-91.8	-91.8	0.14 (1)	L-C	0 / 383	0.08 (1)
B-C	-1847 / 0	-91.8	-91.8	0.34 (1)	C-K	0 / 310	0.08 (1)
C-D	-1641 / 0	-91.8	-91.8	0.38 (1)	K-D	-481 / 0	0.16 (1)
D-E	-1225 / 0	-91.8	-91.8	0.30 (1)	E-H	0 / 1010	0.25 (1)
E-F	0 / 41	-91.8	-91.8	0.14 (1)	H-I	-274 / 0	0.09 (1)
F-G	-1928 / 0	0.0	0.0	0.22 (1)	I-F	0 / 1480	0.37 (1)
G-H	-1380 / 0	0.0	0.0	0.16 (1)	F-G	0 / 981	0.24 (1)
M-N	0 / 0	-18.5	-18.5	0.24 (1)			
N-L	0 / 0	-18.5	-18.5	0.24 (1)			
L-O	0 / 1424	-18.5	-18.5	0.70 (1)			
O-K	0 / 1424	-18.5	-18.5	0.70 (1)			
K-J	0 / 932	-18.5	-18.5	0.25 (1)			
J-I	0 / 932	-18.5	-18.5	0.25 (1)			
I-H	0 / 0	-18.5	-18.5	0.04 (4)			

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX.	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
C	3-10-8	-241	-241	---	FRONT	VERT	TOTAL	---	C1
L	3-11-4	-17	-17	---	FRONT	VERT	TOTAL	---	C1
N	2-0-12	-17	-17	---	FRONT	VERT	TOTAL	---	C1
O	-5-6-8	-953	-953	---	FRONT	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

TOTAL WEIGHT = 84 lb

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN./C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 8.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2015 AMENDMENT)
- CSA 088-09, CSA 085-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (LL) = $L/998$ (0.08")
ALLOWABLE DEFL. (TL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (TL) = $L/999$ (0.10")

CSI: TO=0.38/1.00 (C-D-1), BC=0.70/1.00 (K-L-1), WB=0.37/1.00 (B-L-1), SS=0.45/1.00 (K-L-1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP (DRY)	SHEAR (PSI)	SECTION (PLI)
MT20	618	354	1667
			788
			1987
			1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (C) (INPUT = 0.90)
JSI METAL= 0.57 (J) (INPUT = 1.00)




Structural component only
DWG# T-2007069

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	T7	1	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:55 2020 Page 1
ID:17vF?ag0E03cRUj6X1:SkziWYK-G?AZmyXBqFf_KyjqtkuaTK3VZXS_cD2RiVzNCnU



LUMBER

N. L. G. A. RULES

CHORDS SIZE

A - B 2x4 DRY No.2

B - C 2x4 DRY No.2

C - D 2x4 DRY No.2

I - A 2x4 DRY No.2

E - D 2x4 DRY No.2

I - G 2x4 DRY No.2

G - E 2x4 DRY No.2

ALL WEBS 2x3 DRY No.2

EXCEPT

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

SPF

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY

BEARINGS

FACTORED	MAXIMUM FACTORED	INPUT	REQD
GROSS REACTION	GROSS REACTION	BRG	BRG
VERT	DOWN	IN-SX	IN-SX
JT 905 0	905 0	3-8	3-8
E 905 0	905 0	5-8	5-8

UNFACTORED REACTIONS

1ST LCASE	MAX. MIN. COMPONENT REACTIONS
JT COMBINED	SNOW LIVE PERM LIVE WIND DEAD SOIL
I 640 420 / 0	0 / 0 0 / 0 0 / 0 220 / 0 0 / 0
E 640 420 / 0	0 / 0 0 / 0 0 / 0 220 / 0 0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) I, E

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED	FACTORED	WEBS	MAX. FACTORED
MEMB.	FORCE	VERT. LOAD LC1 MAX. MAX. UNBRAC	MEMB.	FORCE
FR-TO	(LBS)	FROM TO CSI (LC) LENGTH FR-TO	FR-TO	(LBS)
A-B	-718 / 0	-91.8 -91.8 0.39 (1) 6.25	H-B	-34 / 68
B-C	-558 / 0	-91.8 -91.8 0.28 (1) 6.25	B-F	0 / 14
C-D	-729 / 0	-91.8 -91.8 0.42 (1) 6.25	F-C	-23 / 74
I-A	-860 / 0	0.0 0.0 0.09 (1) 7.81	A-H	0 / 567
E-D	-858 / 0	0.0 0.0 0.08 (1) 7.81	F-D	0 / 572
I-H	0 / 0	-18.5 -18.5 0.13 (4) 10.00		
H-G	0 / 550	-18.5 -18.5 0.18 (4) 10.00		
G-F	0 / 550	-18.5 -18.5 0.18 (4) 10.00		
F-E	0 / 0	-18.5 -18.5 0.14 (4) 10.00		

TOTAL WEIGHT = 70 lb (MEF)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL	= 25.6 PSF
DL	= 6.0 PSF
BOT CH. LL	= 0.0 PSF
DL	= 7.4 PSF
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 5.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2018
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-08, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (0.55")
CALCULATED VERT. DEFL. (LL) = L/999 (0.01")
ALLOWABLE DEFL. (TL) = L/360 (0.55")
CALCULATED VERT. DEFL. (TL) = L/999 (0.05")

CSI: TC=0.42/1.00 (C-D:1), BC=0.18/1.00 (F-H:4), WB=0.13/1.00 (D-F:1), SI=0.17/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY) SHEAR SECTION	(PSI)	(PLI)	(PLI)
MAX MIN MAX MIN MAX MIN			
MT20	618	354	1667

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.85 (D) (INPUT = 0.90)
JSI METAL= 0.24 (D) (INPUT = 1.00)



Structural component only
DWG# T-2007070


JOB NAME 408150	TRUSS NAME T8	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	TRUSS DESC.	ORWG NO.
---------------------------	-------------------------	----------------------	-----------------	--------------------------------------	-------------	----------

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:56 2020 Page 1

ID:7vPfaG0E03eRUj6X1tSrkzWYK-IBkxziYpQ8NWcUXvNNPzRo0Yi3nGGpIIRiAFBxzNcNt

Scale = 1:43.8



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - C	2x4	DRY	No.2
C - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
J - A	2x4	DRY	No.2
G - F	2x4	DRY	No.2
J - H	2x4	DRY	No.2
H - G	2x4	DRY	No.2
ALL WEBS EXCEPT	2x3	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
A	TMV-p	MT20	3.0	4.0	
B	TMVW-1	MT20	4.0	6.0	
C	TTW-m	MT20	4.0	4.0	
D	TTW-m	MT20	4.0	4.0	
E	TMVW-1	MT20	4.0	6.0	
F	TMV-p	MT20	3.0	4.0	
G	BMVW-1	MT20	4.0	4.0	
H	BS-1	MT20	3.0	6.0	
I	BMVWVW-1	MT20	5.0	12.0	3.00 6.00
J	BMVW-1	MT20	4.0	4.0	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	DOWN	HORIZ	UPLIFT
J	905	0	0	3-8
G	905	0	0	MECHANICAL

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT G. MINIMUM BEARING LENGTH AT JOINT G = 3-8.

UNFACTORED REACTIONS

1ST LCASE		MAX/MIN. COMPONENT REACTIONS					
JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
J	640	420 / 0	0 / 0	0 / 0	0 / 0	220 / 0	0 / 0
G	640	420 / 0	0 / 0	0 / 0	0 / 0	220 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) J

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC1) MAX. (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC1) MAX. (LC)
FR-TO				FR-TO			
A-B	0 / 27	-91.8	-91.8 0.22 (1)	10.00	B-I	-163 / 0	0.11 (1)
B-C	-849 / 0	-91.8	-91.8 0.17 (1)	8.25	I-E	-190 / 0	0.13 (1)
C-D	-489 / 0	-91.8	-91.8 0.01 (1)	8.25	J-B	-930 / 0	0.54 (1)
D-E	-650 / 0	-91.8	-91.8 0.18 (1)	8.25	E-G	-935 / 0	0.57 (1)
E-F	0 / 27	-91.8	-91.8 0.23 (1)	10.00	C-I	0 / 221	0.05 (1)
J-A	-129 / 0	0.0	0.0 0.01 (1)	7.81	I-D	0 / 222	0.05 (1)
G-F	-137 / 0	0.0	0.0 0.01 (1)	7.81			
J-I	0 / 590	-18.5	-18.5 0.41 (4)	10.00			
I-H	0 / 608	-18.5	-18.5 0.41 (4)	10.00			
H-G	0 / 608	-18.5	-18.5 0.41 (4)	10.00			

TOTAL WEIGHT = 77 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	8.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 085-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.65")
CALCULATED VERT. DEFL.(LL) = L/999 (0.02")
ALLOWABLE DEFL.(TL) = L/360 (0.55")
CALCULATED VERT. DEFL.(TL) = L/999 (0.11")

CSI: TC=0.23/1.00 (E-F:1), BC=0.41/1.00 (G-I:4), WB=0.57/1.00 (E-G:1), SI=0.13/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)	PLI
MT20	618	354	1657 788 1987 1858

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.75 (G) (INPUT = 0.90)
JSI METAL = 0.23 (G) (INPUT = 1.00)




Structural component only
DWG# T-2007071

JOB NAME 408150	TRUSS NAME T9	QUANTITY 1	PLY 1	JOB DESC GREEN PARK HOMES	TRUSS DESC.	DRWG NO.
---------------------------	-------------------------	----------------------	-----------------	-------------------------------------	-------------	----------

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:02:57 2020 Page 1
ID:7vF?ag0E03cRUj6X1/SrkzWYK-DOHJBeZBSVNEe65x4wCz7ZjsTB?LQvgMwojNzNCnS

Scale = 1:48.0



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - C	2x4	DRY	No.2
C - E	2x4	DRY	No.2
K - A	2x4	DRY	No.2
F - E	2x4	DRY	No.2
K - H	2x4	DRY	No.2
H - F	2x4	DRY	No.2
ALL WEBS EXCEPT	2x3	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW+p	MT20	4.0	4.0	1.00	2.00
B	TMVW-t	MT20	4.0	4.0	2.00	1.25
C	TTW+p	MT20	4.0	4.0	6.0	Edge
D	TMVW-t	MT20	4.0	4.0	2.00	1.25
E	TMVW+p	MT20	4.0	4.0	1.00	2.00
F	BMV1+p	MT20	3.0	4.0		
G	BMVW-t	MT20	4.0	6.0		
H	BS-t	MT20	3.0	6.0		
I	BMVWW-t	MT20	4.0	9.0		
J	BMVW-t	MT20	4.0	4.0		
K	BMV1+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	HORZ	DOWN	UPLIFT
K	905	0	905	0
F	905	0	905	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT F. MINIMUM BEARING LENGTH AT JOINT F = 3-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX. MIN. COMPONENT REACTIONS
K	COMBINED	SNOW LIVE PERM. LIVE WIND DEAD SOIL
K	840	420 / 0 0 / 0 0 / 0 0 / 0 220 / 0 0 / 0
F	840	420 / 0 0 / 0 0 / 0 0 / 0 220 / 0 0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CSI (LC)
FR-TO		FROM TO			FR-TO		
A-B	-772 / 0	-91.8	-91.8 0.20 (1)	6.25	J-B	-135 / 21	0.05 (1)
B-C	-620 / 0	-91.8	-91.8 0.19 (1)	8.25	B-I	-251 / 0	0.18 (1)
C-D	-822 / 0	-91.8	-91.8 0.20 (1)	6.25	I-C	0 / 478	0.11 (1)
D-E	-795 / 0	-91.8	-91.8 0.21 (1)	6.25	I-D	-278 / 0	0.20 (1)
K-A	-873 / 0	0.0	0.0 0.10 (1)	7.81	G-D	-110 / 31	0.04 (1)
F-E	-872 / 0	0.0	0.0 0.09 (1)	7.81	A-J	0 / 653	0.15 (1)
					G-E	0 / 662	0.15 (1)
K-J	0 / 0	-18.5	-18.5 0.07 (4)	10.00			
J-I	0 / 615	-18.5	-18.5 0.13 (1)	10.00			
I-H	0 / 633	-18.5	-18.5 0.14 (1)	10.00			
H-G	0 / 633	-18.5	-18.5 0.14 (1)	10.00			
G-F	0 / 0	-18.5	-18.5 0.07 (4)	10.00			

TOTAL WEIGHT = 77 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	= 25.6	PSF
	DL	= 6.0	PSF
BOT CH.	LL	= 0.0	PSF
	DL	= 7.4	PSF
TOTAL LOAD		= 39.0	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $\frac{1}{380}$ (0.55')
CALCULATED VERT. DEFL.(LL) = $\frac{1}{959}$ (0.02')
ALLOWABLE DEFL.(TL) = $\frac{1}{380}$ (0.55')
CALCULATED VERT. DEFL.(TL) = $\frac{1}{959}$ (0.03')

CSI: TC=0.21/1.00 (D-E:1), BC=0.14/1.00 (G-I:1), WB=0.20/1.00 (D-I:1), SSI=0.14/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PL)
MT20	618	354 1667 788 1987 1856

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.87 (E) (INPUT = 0.90)
JSI METAL= 0.24 (E) (INPUT = 1.00)




Structural component only
DWG# T-2007072

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	T10S	2	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MTEK Industries, Inc. Sat Apr 25 11:02:58 2020 Page 1
ID:7vF7aG0E03cRUj6X1SkzWYK-harO_a4yidDrohIVoRRWD5vytX_kqu2v0IMFzNcRr



Scale = 1/32.9

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY	No.2	SPF
D - G	2x4	DRY	No.2	SPF
N - B	2x4	DRY	No.2	SPF
H - F	2x4	DRY	No.2	SPF
N - M	2x4	DRY	No.2	SPF
M - C	2x4	DRY	No.2	SPF
L - J	2x4	DRY	No.2	SPF
I - E	2x4	DRY	No.2	SPF
I - H	2x4	DRY	No.2	SPF
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF
N - L	2x4	DRY	No.2	SPF
J - H	2x4	DRY	No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B, C, E, F					
B	TMVW+p	MT20	4.0	4.0	1.00 2.00
D	TTW+p	MT20	4.0	5.0	Edge
H	BMVW1+t	MT20	4.0	4.0	
I	BMV+p	MT20	3.0	4.0	
J	BMVWV1	MT20	5.0	12.0	5.00 7.75
K	BMVWV1	MT20	4.0	9.0	
L	BMVWV1	MT20	5.0	12.0	5.00 7.75
M	BMV+p	MT20	3.0	4.0	
N	BMVWV1	MT20	4.0	4.0	

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	DOWN	UPLIFT	IN-SX
N	729	0	0	5-8
H	729	0	0	MECHANICAL

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT H. MINIMUM BEARING LENGTH AT JOINT H = 1-8.

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
N	513	350/0	0/0	0/0	0/0	163/0	0/0
H	513	350/0	0/0	0/0	0/0	163/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) N

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 8.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 7.81 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (LBS)	MAX. FACTORED VERT. LOAD (LBS)	MAX. FACTORED VERT. LOAD (LBS)	MAX. FACTORED VERT. LOAD (LBS)	MAX. FACTORED VERT. LOAD (LBS)	MAX. FACTORED VERT. LOAD (LBS)
FR-TO							
A-B	0/41	-91.8	-91.8	0.13 (1)	10.00	C-K	-211/0
B-C	-647/0	-91.8	-91.8	0.14 (1)	6.25	K-D	0/229
C-D	-447/0	-91.8	-91.8	0.19 (1)	6.25	K-E	-210/0
D-E	-447/0	-91.8	-91.8	0.18 (1)	6.25	N-L	-28/0
E-F	-646/0	-91.8	-91.8	0.14 (1)	6.25	B-L	0/527
F-G	0/41	-91.8	-91.8	0.13 (1)	10.00	J-F	0/526
N-B	-701/0	0.0	0.0	0.07 (1)	7.81	J-H	-28/0
H-F	-701/0	0.0	0.0	0.07 (1)	7.81		
N-M	0/20	-18.5	-18.5	0.01 (4)	10.00		
M-L	0/14	0.0	0.0	0.03 (1)	10.00		
L-C	-92/2	0.0	0.0	0.02 (1)	7.81		
L-K	0/528	-18.5	-18.5	0.13 (1)	10.00		
K-J	0/527	-18.5	-18.5	0.13 (1)	10.00		
I-J	0/14	0.0	0.0	0.03 (1)	10.00		
J-E	-93/2	0.0	0.0	0.02 (1)	7.81		
I-H	0/20	-18.5	-18.5	0.01 (4)	10.00		

TOTAL WEIGHT = 2 X 56 = 112 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	6.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.36")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.01")
ALLOWABLE DEFL.(TL) = $L/360$ (0.36")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.02")

CS: TC=0.19/1.00 (C-D:1), BC=0.13/1.00 (K-L:1), WB=0.12/1.00 (B-L:1), SS=0.13/1.00 (C-D:1)

DOL LUMBER=1.00 NAIL=1.00 LB BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1867 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.74 (F) (INPUT = 0.50)
JSI METAL= 0.20 (F) (INPUT = 1.00)




Structural component only
DWG# T-2007073

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC	GREEN PARK HOMES	DRWG NO.
408150	T11	1	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version B.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:59 2020 Page 1
ID:7vF?aG0E03cRuj6X1jSrkziWYK-9mP4cKaj3i4TxGU3Vzg2Qe15HsstHx87gPvoGzNcNq

Scale = 1/25.4



LUMBER

N.L.G.A. RULES	CHORDS	SIZE	LUMBER
A - C	2x4	DRY	No.2
C - E	2x4	DRY	No.2
H - B	2x4	DRY	No.2
F - D	2x4	DRY	No.2
H - F	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2 EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMVW+p	MT20	4.0	4.0	1.00	2.00
C TTW+p	MT20	4.0	8.0	Edge	
D TMVW+p	MT20	4.0	4.0	1.00	2.00
F BMV1+p	MT20	3.0	4.0		
G BMVWW-t	MT20	4.0	9.0		
H BMV1+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	HORZ	DOWN	HORZ
H	729	0	729	0
F	729	0	729	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT F. MINIMUM BEARING LENGTH AT JOINT F = 1-8.

UNFACTORED REACTIONS

JT	1ST LCASE	MAX/MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
H	513	350 / 0	0 / 0	0 / 0	163 / 0	0 / 0
F	513	350 / 0	0 / 0	0 / 0	163 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) H

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CS (LC)	MAX. UNBRACED LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CS (LC)
FR-TO		FROM TO			FR-TO		
A-B	0 / 41	-91.8	-91.8 0.13 (1)	10.00	G-C	-15 / 89	0.03 (4)
B-C	-380 / 0	-91.8	-91.8 0.35 (1)	6.25	B-G	0 / 300	0.07 (1)
C-D	-380 / 0	-91.8	-91.8 0.35 (1)	6.25	G-D	0 / 300	0.07 (1)
D-E	0 / 41	-91.8	-91.8 0.13 (1)	10.00			
H-B	-390 / 0	0.0	0.0 0.07 (1)	7.81			
F-D	-390 / 0	0.0	0.0 0.07 (1)	7.81			
H-G	0 / 0	-18.5	-18.5 0.16 (4)	10.00			
G-F	0 / 0	-18.5	-18.5 0.16 (4)	10.00			

TOTAL WEIGHT = 49 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	= 25.6 PSF
	DL	= 6.0 PSF
BOT CH.	LL	= 0.0 PSF
	DL	= 7.4 PSF
TOTAL LOAD		= 39.0 PSF

SPACING = 24.0 IN C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.36")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.36")
CALCULATED VERT. DEFL.(TL) = L/999 (0.02")

CSI: TC=0.35/1.00 (B-C:1), BC=0.16/1.00 (G-H:4), WB=0.07/1.00 (D-G:1), SS=0.15/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 788
	1987	1656

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP = 0.62 (D) (INPUT = 0.90)
JSI METAL = 0.17 (D) (INPUT = 1.00)




Structural component only
DWG# T-2007074

JOB NAME 408150	TRUSS NAME T12	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
--------------------	-------------------	---------------	----------	-------------------------------	----------

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:03:01 2020 Page 1
ID:4NxGft_xHSHnsgnSWZu6izNuP6-59Xq1?cyEg?ciFQsAw?88rjPP4ZbxQqUb_u0s8zNCn0

Scale = 1:32.5



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER
A - B	2x4	DRY No.2
B - C	2x4	DRY No.2
F - A	2x4	DRY No.2
D - C	2x4	DRY No.2
F - D	2x4	DRY No.2

ALL WEBS 2x3 DRY No.2 EXCEPT

DRY: SEASONED LUMBER.

PLATES (table in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMWV+p	MT20	4.0	4.0	1.00	2.00
B	TTW+p	MT20	4.0	6.0	Edge	
C	TMWV+p	MT20	4.0	4.0	1.00	2.00
D	BMV1+p	MT20	3.0	4.0		
E	BMWVW+	MT20	4.0	9.0		
F	BMV1+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
F	423	0	0	0
D	423	0	0	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT F, D. MINIMUM BEARING LENGTH AT JOINT F = 1-8, JOINT D = 1-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
F	299	196 / 0	0 / 0	0 / 0	103 / 0	0 / 0
D	299	196 / 0	0 / 0	0 / 0	103 / 0	0 / 0

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC)	MAX. FACTORED VERT. LOAD (LC)	W E B S	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED VERT. LOAD (LC)
FR-TO									
A-B	-214 / 0	-91.8	-91.8	0.17 (1)	6.25	E-B	-78 / 37	0.03 (1)	
B-C	-214 / 0	-91.8	-91.8	0.17 (1)	6.25	A-E	0 / 184	0.04 (1)	
F-A	-395 / 0	0.0	0.0	0.05 (1)	7.81	E-C	0 / 184	0.04 (1)	
D-C	-395 / 0	0.0	0.0	0.05 (1)	7.81				
F-E	0 / 0	-18.5	-18.5	0.08 (4)	10.00				
E-D	0 / 0	-18.5	-18.5	0.08 (4)	10.00				

TOTAL WEIGHT = 35 lb

(M/F)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
	DL = 6.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2018
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.26")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.00")
ALLOWABLE DEFL.(TL) = $L/360$ (0.26")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.01")

CSI: TC=0.17/1.00 (B-C:1), BC=0.08/1.00 (D-E:4),
WB=0.04/1.00 (A-E:1), SSI=0.11/1.00 (B-C:1)

DCL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
	(PSI)	(PLI)	(PLI)
	MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 788	1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.31 (C) (INPUT = 0.90)
JSI METAL= 0.09 (C) (INPUT = 1.00)




Structural component only
DWG# T-2007075

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	T12S	2	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:03:02 2020 Page 1
ID:4NkGft_xHSHnsgnSWZu6izNuP6-ZL5CElda? 7IKP73keWNq3GbtUw7geceqedZObzNCnN



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
A - C	2x4	DRY	No.2
C - E	2x4	DRY	No.2
L - A	2x4	DRY	No.2
F - E	2x4	DRY	No.2
L - K	2x4	DRY	No.2
K - B	2x4	DRY	No.2
J - H	2x4	DRY	No.2
G - D	2x4	DRY	No.2
G - F	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A, B, D, E						
A	TMWW+p	MT20	4.0	4.0	1.00	2.00
C	TTW+p	MT20	4.0	6.0	Edge	
F	BMVW1-t	MT20	4.0	4.0		
G	BMV+p	MT20	3.0	4.0		
H	BMVWW-t	MT20	5.0	8.0	3.50	5.50
I	BMVWW-t	MT20	4.0	9.0		
J	BMVWW-t	MT20	5.0	8.0	3.50	5.50
K	BMV+p	MT20	3.0	4.0		
L	BMVW1-t	MT20	4.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
L	423	0	423	0
F	423	0	423	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT L, F. MINIMUM BEARING LENGTH AT JOINT L = 1-8, JOINT F = 1-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
L	299	186 / 0	0 / 0	0 / 0	0 / 0	103 / 0	0 / 0	0 / 0
F	299	186 / 0	0 / 0	0 / 0	0 / 0	103 / 0	0 / 0	0 / 0

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 7.81 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSI (LC)	UNBRAC LENGTH	MEMB.	WEBS	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)
FR-TO						FR-TO			
A-B	-282 / 0	-91.8	-91.8	0.08 (1)	6.25	I-C	0 / 125	0.03 (1)	
B-C	-274 / 0	-91.8	-91.8	0.07 (1)	6.25	I-D	-57 / 0	0.01 (1)	
C-D	-274 / 0	-91.8	-91.8	0.07 (1)	6.25	B-I	-57 / 0	0.01 (1)	
D-E	-282 / 0	-91.8	-91.8	0.08 (1)	6.25	L-J	-13 / 0	0.00 (1)	
L-A	-404 / 0	0.0	0.0	0.05 (1)	7.81	A-J	0 / 317	0.07 (1)	
F-E	-404 / 0	0.0	0.0	0.05 (1)	7.81	H-F	-13 / 0	0.00 (1)	
						H-E	0 / 317	0.07 (1)	
L-K	0 / 9	-18.5	-18.5	0.01 (4)	10.00				
K-J	0 / 11	0.0	0.0	0.01 (1)	10.00				
J-B	-182 / 0	0.0	0.0	0.01 (1)	7.81				
J-I	0 / 247	-18.5	-18.5	0.08 (1)	10.00				
I-H	0 / 247	-18.5	-18.5	0.08 (1)	10.00				
G-H	0 / 11	0.0	0.0	0.01 (1)	10.00				
H-D	-182 / 0	0.0	0.0	0.01 (1)	7.81				
G-F	0 / 9	-18.5	-18.5	0.01 (4)	10.00				

TOTAL WEIGHT = 2 X 43 = 85 lb [M]F

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.8 PSF
DL = 6.0 PSF	
BOT CH.	LL = 0.0 PSF
DL = 7.4 PSF	
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.26")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.00")
ALLOWABLE DEFL.(TL) = $L/360$ (0.26")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.01")

CSI: TC=0.07/1.00 (C-D:1), BC=0.08/1.00 (H-I:1),
WB=0.07/1.00 (A-J:1), SS=0.09/1.00 (C-D:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PL)
MT20	618	354 1667 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.30 (E) (INPUT = 0.30)
JSI METAL = 0.08 (E) (INPUT = 1.00)



Structural component only
DWG# T-2007076

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:03:03 2020 Page 1

0-0-0-8 9-8 9-14 2-9-14 2-7-10 53-8


1Di7vF7aG0E03cRUj5X1jSrkzWYK-1XfbSheCmFWyZaFiL1cDGpbHuDpP_en2INX7z1ZNCNm

0-10-10-10-11

552

1/2"

Scale = 1:16.8



Edge - INDICATES REFERENCE CORNER OF PLATE
TOUCHES EDGE OF CHORD

BEARINGS		FACTORED		MAXIMUM FACTORED		INPUT	REQRD
GROSS REACTION		GROSS REACTION				BRG	BRG
JT	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX
F	978	0	976	0	0	5-8	5-8
D	1015	0	1015	0	0	5-8	5-8

UNFACTORED REACTIONS						
1ST CASE		MAX./MIN. COMPONENT REACTIONS				
JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD
F	890	453 / 0	0 / 0	0 / 0	0 / 0	237 / 0
D	716	478 / 0	0 / 0	0 / 0	0 / 0	237 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F. D

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.55 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY ABOVE

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLR)	LC1 MAX CSI (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CSI (LC)
FR-TO		FROM	TO		FR-TO		
A-G	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55		
G-H	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55	A-E	0 / 2157 0.53 (1)
H-I	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55	E-B	-876 / 0 0.14 (1)
I-B	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55	E-C	0 / 2157 0.53 (1)
B-J	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55		
J-K	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55		
K-C	-2081 / 0	-91.8	-91.8	0.79 (1)	3.55		
F-A	-869 / 0	0.0	0.0	0.10 (1)	7.81		
D-C	-939 / 0	0.0	0.0	0.11 (1)	7.81		
F-L	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
L-M	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
M-N	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
N-E	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
E-O	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
O-P	0 / 0	-18.5	-18.5	0.22 (4)	10.00		
P-D	0 / 0	-18.5	-18.5	0.22 (4)	10.00		

LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CON
11-10-10	-123	-123	---	BACK	VERT	TOTAL	---	C1
9-14	-90	-90	---	BACK	VERT	TOTAL	---	C1
2-9-14	-82	-82	---	BACK	VERT	TOTAL	---	C1
4-9-14	-82	-82	---	BACK	VERT	TOTAL	---	C1
6-9-14	-82	-82	---	BACK	VERT	TOTAL	---	C1
8-9-14	-82	-82	---	BACK	VERT	TOTAL	---	C1
9-14	-51	-51	---	BACK	VERT	TOTAL	---	C1
2-9-14	-49	-49	---	BACK	VERT	TOTAL	---	C1
4-9-14	-49	-49	---	BACK	VERT	TOTAL	---	C1
6-9-14	-49	-49	---	BACK	VERT	TOTAL	---	C1
8-9-14	-49	-49	---	BACK	VERT	TOTAL	---	C1

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED

SPECIFIED LOADS:

TOP CH.	LL =	25.6	PSF
	DL =	6.0	PSF
BOT CH.	LL =	0.0	PSF
	DL =	7.4	PSF
TOTAL LOAD	=	39.0	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE
OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR
SMALL BUILDING REQUIREMENTS OF PART 9,
NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
 - PART 9 OF BCBC 2018, OBC 2012, ABC 2019
 - PART 9 OF OBC 2012 (2019 AMENDMENT)
 - CSA 086-09, CSA 086-14
 - TPIC 2011, TPIC 2014

55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN
(LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF
LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.36")
CALCULATED VERT. DEFL.(LL) = L/999 (0.08")
ALLOWABLE DEFL.(TL)= L/360 (0.36")
CALCULATED VERT. DEFL.(TL) = L/817 (0.18")

SSI: TC=0.79/1.00 (A-B:1), BC=0.22/1.00 (E-F:4),
WB=0.53/1.00 (A-E:1), SSI=0.39/1.00 (A-B:1)

COL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS= 1.00

COMPANION LIVE LOAD FACTOR = 1.00


AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


ITEM	TENSILE		TENSILE		TENSILE	
	STRENGTH		STRENGTH		STRENGTH	
	MAX	MIN	MAX	MIN	MAX	MIN
1	618	354	1667	788	1987	1658

LATE PLACEMENT TOI = 0.250 inches

LATE ROTATION TOL. = 5.0 Deg.

SI GRIP= 0.89 (A) (INPUT = 0.90)
SI METAL= 0.40 (E) (INPUT = 1.00)

Structural component only
DWG# T-2007077



TOP CHORDS : (0.122"x3") SPIRAL NAILS				LOADING				ADULT USER-DEFINED LOADS APPLIED TO ALL LOAD CASES.						
A-C	2	12		SIDE(122.0)	TOTAL LOAD CASES: (4)				THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015					
F	2	12		SIDE(61.0)	CHORDS			WEBS						
H	2	12		SIDE(61.0)	MAX. FACTORED			MAX. FACTORED						
J	2	12		SIDE(122.0)	MEMB. FORCE (LBS)			MEMB. FORCE (LBS)						
K	2	12		TOP	VERT. LOAD L1			MAX. UNBRAC						
L	2	12		TOP	FROM TO			FR-TO						
BOTTOM CHORDS : (0.122"x3") SPIRAL NAILS				FR-TO	(PLF)			CS1 (LC)						
A-P	2	12		A-B	0 / 42			R-C						
N	2	12		B-C	-3359 / 0			Q-Q						
K	2	12		C-T	-8608 / 0			Q-D						
WEBS : (0.122"x3") SPIRAL NAILS				T-U	-8606 / 0			D-C						
K3	1	6		U-V	-8606 / 0			O-E						
RAILS TO BE DRIVEN FROM ONE SIDE ONLY.				V-W	-8608 / 0			O-G						
HANGER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.				W-D	-8608 / 0			M-G						
				D-X	-7835 / 0			M-H						
				X-Y	-7835 / 0			L-H						
				Y-Z	-7835 / 0			B-R						
				Z-E	-7835 / 0			L-I						
				E-AA	-7835 / 0									
				AA-F	-7835 / 0									
				AB	-7835 / 0									
				AB-AC	-7835 / 0									
				AC-AD	-7835 / 0									
				AD-G	-7835 / 0									
				GA-E	-6512 / 0									

	AE-AF	-6612 / 0	-01.8	-01.8	0.38 (1)	4.32	COMP=1.00 SHEAR=1.00 TENS=1.00
	AF-AG	-6612 / 0	-01.8	-01.8	0.38 (1)	4.32	COMPANION LIVE LOAD FACTOR = 1.00
	AG-H	-6612 / 0	-01.8	-01.8	0.38 (1)	4.32	AUTOSOLVE HEELS OFF
	H-I	-3401 / 0	-01.8	-01.8	0.05 (1)	6.00	TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.
	I-J	0 / 42	-01.8	-01.8	0.04 (1)	10.00	NAIL VALUES
	S-B	-3366 / 0	0.0	0.0	0.12 (1)	7.58	PLATE GRIP(DRY) SHEAR SECTION (PSB) (PLB) (PL)
	K-I	-3406 / 0	0.0	0.0	0.12 (1)	7.55	MAX MIN MAX MIN MAX MIN
	S-AH	0 / 0	-18.5	-18.5	0.06 (4)	10.00	MT20 618 354 1667 788 1987 1656
	AH-R	0 / 0	-18.5	-18.5	0.06 (4)	10.00	PLATE PLACEMENT TOL = 0.250 inches
	R-AJ	0 / 2546	-18.5	-18.5	0.16 (1)	10.00	PLATE ROTATION TOL = 5.0 Deg.
AJ-AK	0 / 2546	-18.5	-18.5	0.16 (1)	10.00	JSI GRIP= 0.62 (M) (INPUT = 0.90)	
AK-AL	0 / 2546	-18.5	-18.5	0.16 (1)	10.00	JSI METAL= 0.32 (P) (INPUT = 1.00)	
AL-O	0 / 2546	-18.5	-18.5	0.16 (1)	10.00		
O-P	0 / 6606	-18.5	-18.5	0.32 (1)	10.00		
P-AM	0 / 6606	-18.5	-18.5	0.32 (1)	10.00		
AM-AN	0 / 6606	-18.5	-18.5	0.32 (1)	10.00		
AN-O	0 / 6606	-18.5	-18.5	0.32 (1)	10.00		
O-AC	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		
AO-AP	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		
AP-AQ	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		
AQ-N	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		
N-AR	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		
AR-M	0 / 6613	-18.5	-18.5	0.32 (1)	10.00		

CONTINUED ON PAGE 2

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC	DRWG NO.
408151	T20	1	2	GREEN PARK HOMES	

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:44 2020 Page 2
ID:h2dfiqC44wS E2tzqPs atzllRw-E6e?XzI51rNUYObeR4VLHMmiPOqOSI2/EXMbZWzNCX

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	7.0	8.0		
C	TTWW+m	MT20	8.0	9.0	3.50	1.75
D	TMVW-t	MT20	5.0	8.0	2.50	2.50
E	TMVW+w	MT20	3.0	8.0		
F	TS-t	MT20	5.0	8.0		
G	TMVW-t	MT20	5.0	8.0	2.50	2.50
H	TTWW+m	MT20	8.0	9.0	3.50	1.75
I	TMVW+p	MT20	7.0	8.0		
K	BMV1+p	MT20	3.0	8.0		
L	BMVW-t	MT20	5.0	8.0	2.50	2.25
M	BMVW-t	MT20	5.0	8.0	2.50	3.00
N	BS-t	MT20	6.0	9.0		
O	BMVWVW-t	MT20	5.0	12.0		
P	BS-t	MT20	6.0	9.0		
Q	BMVW-t	MT20	5.0	8.0	2.50	3.00
R	BMVW-t	MT20	5.0	8.0	2.50	2.25
S	BMV1+p	MT20	3.0	8.0		

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX	MAX. MEMB. FORCE (LBS)	MAX. FACTORED VERT. LOAD (LBS)	FACTORED VERT. LOAD (LBS)	CS1 (LC)
FR-TO		FROM TO					
M-AS	0 / 2579	-18.5	-18.5	0.16 (1)	10.00		
AS-AT	0 / 2579	-18.5	-18.5	0.16 (1)	10.00		
AT-AU	0 / 2579	-18.5	-18.5	0.16 (1)	10.00		
AU-L	0 / 2579	-18.5	-18.5	0.16 (1)	10.00		
L-AV	0 / 0	-18.5	-18.5	0.06 (4)	10.00		
AV-K	0 / 0	-18.5	-18.5	0.06 (4)	10.00		

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX.	FACE	DIR.	TYPE	HEEL	CONN.
C	2-11-8	-38	-42	FRONT	VERT	DEAD	--	C1
C	2-11-8	-191	-191	FRONT	VERT	SNOW	--	C1
H	32-2-8	-38	-42	FRONT	VERT	DEAD	--	C1
H	32-2-8	-116	-116	FRONT	VERT	TOTAL	--	C1
H	32-2-8	-191	-191	FRONT	VERT	SNOW	--	C1
L	31-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
P	11-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
T	3-11-4	-111	-111	FRONT	VERT	TOTAL	--	C1
U	5-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
V	7-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
W	9-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
X	11-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
Y	13-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
Z	15-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AA	17-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AB	19-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AC	21-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AD	23-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AE	25-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AF	27-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AG	29-11-4	-110	-110	FRONT	VERT	TOTAL	--	C1
AH	1-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AI	3-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AJ	5-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AK	7-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AL	9-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AM	13-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AN	15-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AO	17-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AP	19-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AQ	21-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AR	23-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AS	25-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AT	27-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AU	29-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1
AV	33-11-4	-26	-26	FRONT	VERT	TOTAL	--	C1

CONNECTION REQUIREMENTS

- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.




Structural component only
DWG# T-2007081 72

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408151	T20Z	1	2	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:45 2020 Page 1
ID:h2df1gC44ws E2tzqPs_atz1IRw-UCOLmko9VL9YAq n0aqaJuZ04E85KGT8585yzNCX



LUMBER	N.L.G.A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
A - C	2x6	DRY	No.2	SPF		
C - F	2x6	DRY	No.2	SPF		
F - H	2x6	DRY	No.2	SPF		
H - J	2x6	DRY	No.2	SPF		
S - B	2x6	DRY	No.2	SPF		
K - I	2x6	DRY	No.2	SPF		
S - P	2x6	DRY	1650F 1.5E	SPF		
P - N	2x6	DRY	1650F 1.5E	SPF		
N - K	2x6	DRY	1650F 1.5E	SPF		
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF		

DRY: SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN)	LOAD (PLF)
TOP CHORDS: (0.122"x3") SPIRAL NAILS		
A-C	12	SIDE (122.0)
C-F	12	SIDE (183.1)
F-H	12	TOP
H-J	12	TOP
S-B	12	TOP
K-I	12	TOP
BOTTOM CHORDS: (0.122"x3") SPIRAL NAILS		
S-P	12	SIDE (183.1)
P-N	12	SIDE (183.1)
N-K	12	TOP
WEBS: (0.122"x3") SPIRAL NAILS		
2x3	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
	GROSS REACTION	GROSS REACTION	BRG	BRG
	VERT	DOWN	UP	IN-SX
JT	4991	0	0	5-8
S	4991	0	0	5-8
K	3894	0	0	5-8

UNFACTORED REACTIONS
1ST LCASE MAX./MIN. COMPONENT REACTIONS

	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
JT	3528	2323 / 0	0 / 0	0 / 0	0 / 0	1206 / 0	0 / 0
S	3528	2323 / 0	0 / 0	0 / 0	0 / 0	1206 / 0	0 / 0
K	2608	1737 / 0	0 / 0	0 / 0	0 / 0	871 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.20 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	FACTORED	WEBS	FACTORED
MEMB.	MAX. FORCE	MEMB.	MAX. FORCE
	(LBS)		(LBS)
FR-TO	FROM TO	FR-TO	FROM TO
A-B	0 / 42	R-C	-253 / 44
B-C	-5342 / 0	C-Q	0 / 8589
C-D	-9971 / 0	Q-D	-1956 / 0
D-T	-12379 / 0	D-O	0 / 2894
T-E	-12379 / 0	O-E	-782 / 0
E-F	-12379 / 0	E-G	0 / 4229
F-G	-12379 / 0	G-H	-2619 / 0
G-H	-8599 / 0	H-H	0 / 6416
H-I	-3750 / 0	I-H	-984 / 0
I-J	0 / 42	H-R	0 / 4341
S-B	-5197 / 0	R-L	0 / 3047
K-I	-3727 / 0		
S-U	0 / 0		
U-R	0 / 0		
R-V	0 / 4073		
V-Q	0 / 4073		
Q-P	0 / 9871		
P-W	0 / 9871		
W-X	0 / 9871		
X-O	0 / 9871		
O-Y	0 / 8600		
Y-N	0 / 8600		
N-M	0 / 8600		
M-L	0 / 2839		
L-K	0 / 0		

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
C	2-11-8	-38	-42	---	FRONT	VERT	DEAD	---	C1
C	2-11-8	-117	-117	---	BACK	VERT	TOTAL	---	C1
C	2-11-8	-191	-191	---	FRONT	VERT	SNOW	---	C1
E	17-4-12	-110	-110	---	BACK	VERT	TOTAL	---	C1
O	17-4-12	-26	-26	---	BACK	VERT	TOTAL	---	C1
R	2-9-4	-26	-26	---	BACK	VERT	TOTAL	---	C1
T	15-4-12	-110	-110	---	BACK	VERT	TOTAL	---	C1
U	9-4	-26	-26	---	BACK	VERT	TOTAL	---	C1
V	4-8-8	-1066	-1066	---	BACK	VERT	TOTAL	---	C1
W	13-5-8	-1066	-1066	---	BACK	VERT	TOTAL	---	C1
X	15-4-12	-26	-26	---	BACK	VERT	TOTAL	---	C1
Y	18-5-8	-1738	-1738	---	BACK	VERT	TOTAL	---	C1

TOTAL WEIGHT = 2 X 183 = 365 LB

DESIGN CRITERIA

*** SPECIAL LOADS ANALYSIS ***
GEOMETRY AND/OR BASIC LOADS CHANGED BY USER.
LOADS WERE DERIVED FROM USER INPUT
NO FURTHER MODIFICATIONS WERE MADE

SPECIFIED LOADS:

TOP CH.	LL	= 25.6	PSF
	DL	= 6.0	PSF
BOT CH.	LL	= 0.0	PSF
	DL	= 7.4	PSF
TOTAL LOAD	= 39.0	PSF	

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

*** NON STANDARD GIRDER ***
ADD'L USER-DEFINED LOADS APPLIED TO ALL LOAD CASES.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.33")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/686 (0.82")

CSI: TG=0.52/1.00 (D-E:1), BC=0.73/1.00 (D-Q:1),
WB=0.81/1.00 (C-Q:1), SSL=0.57/1.00 (M-Q:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES


PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354 1667 788	1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP=0.88 (D) (INPUT = 0.90)
JSI METAL=0.84 (P) (INPUT = 1.00)

CONTINUED ON PAGE 2



Structural component only
DWG# T-2007082 42

JOB NAME 408151	TRUSS NAME T20Z	QUANTITY 1	PLY 2	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington					


Version 8.310 S Oct 29 2019 MiTek Industries, Inc. Sat Apr 25 11:19:45 2020 Page 2
ID:h2dfiqC44wS E2tqPs atllRw-JCOUmko8VL9YAq n0agaJuZo4EB5KGTB585vzNCX

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	7.0	8.0		
C	TTWW+m	MT20	8.0	9.0	3.50	1.75
D	TMWW-l	MT20	5.0	6.0	2.50	2.50
E	TMW+w	MT20	3.0	6.0		
F	TS-l	MT20	5.0	6.0		
G	TMWW-l	MT20	5.0	6.0	2.50	2.50
H	TTWW+m	MT20	8.0	9.0	3.50	1.75
I	TMVW+p	MT20	7.0	8.0		
K	BMV1+p	MT20	3.0	6.0		
L	BMWW-l	MT20	5.0	6.0	2.50	2.25
M	BMWW-l	MT20	5.0	8.0	2.50	2.75
N	BS-l	MT20	6.0	9.0		
O	BMWWWW-l	MT20	5.0	12.0	2.75	6.00
P	BS-l	MT20	6.0	9.0		
Q	BMWW-l	MT20	5.0	8.0	2.50	2.75
R	BMWW-l	MT20	5.0	6.0	2.50	2.25
S	BMV1+p	MT20	3.0	6.0		

CONNECTION REQUIREMENTS


- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.



Structural component only
DWG# T-2007082 7/2

JOB NAME 408151	TRUSS NAME T21	QUANTITY 2	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:46 2020 Page 1
 ID:h2dfqC44wS_E2tqPs_atzRw-AVlmymMZTdCnIdYUXpMnr1ECRIweZChridOzNCXh
 Scale = 1:57.3



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
A - C	2x4	DRY No.2	SPF
C - F	2x4	DRY No.2	SPF
F - I	2x4	DRY No.2	SPF
I - K	2x4	DRY No.2	SPF
U - B	2x4	DRY No.2	SPF
L - J	2x4	DRY No.2	SPF
U - R	2x4	DRY No.2	SPF
R - O	2x4	DRY No.2	SPF
O - L	2x4	DRY No.2	SPF
ALL WEBS	2x3	DRY No.2	SPF
EXCEPT			

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	5.0	6.0	Edge	2.75
C	TTWW+m	MT20	6.0	9.0	Edge	1.75
D, E, H						
D	TMVW-i	MT20	4.0	4.0		
F	TS-i	MT20	3.0	6.0		
G	TMVW-w	MT20	2.0	4.0		
I	TTWW+m	MT20	6.0	9.0	Edge	1.75
J	TMVW+p	MT20	5.0	6.0	Edge	2.75
L	BMV1+p	MT20	3.0	4.0		
M	BMVW-i	MT20	4.0	5.0	2.00	2.75
N	BMVW-i	MT20	5.0	6.0	2.50	2.75
O	BS-i	MT20	3.0	6.0		
P	BMVW-w	MT20	4.0	5.0		
Q	BMVW-i	MT20	4.0	4.0		
R	BS-i	MT20	3.0	6.0		
S	BMVW-i	MT20	5.0	6.0		
T	BMVW-i	MT20	4.0	6.0	2.00	2.75
U	BMV1+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT VERT	2066	0	5-8
U DOWN	2066	0	5-8
L UPLIFT	2066	0	5-8

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN COMPONENT REACTIONS
JT COMBINED	971 / 0
U SNOW	0 / 0
L LIVE	0 / 0
PERM LIVE	0 / 0
WIND	488 / 0
DEAD	488 / 0
SOIL	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) U, L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.20 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. UNBRACED LENGTH (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. UNBRACED LENGTH (LC)	
FR-TO				FR-TO			
A-B	0 / 41	-91.8	0.13 (1)	10.00	T-C	-358 / 0	0.14 (1)
B-C	-1960 / 0	-91.8	0.38 (1)	4.46	C-S	0 / 1838	0.41 (1)
C-D	-2871 / 0	-91.8	0.57 (1)	3.59	S-D	-1118 / 0	0.43 (1)
D-E	-3508 / 0	-91.8	0.65 (1)	3.21	D-Q	0 / 866	0.19 (1)
E-F	-3508 / 0	-91.8	0.53 (1)	3.36	Q-E	-475 / 0	0.18 (1)
F-G	-3505 / 0	-91.8	0.58 (1)	3.35	E-P	-2 / 0	0.09 (1)
G-H	-5505 / 0	-91.8	0.66 (1)	3.20	P-G	-474 / 0	0.18 (1)
H-I	-2871 / 0	-91.8	0.57 (1)	3.59	P-H	0 / 853	0.19 (1)
I-J	-1960 / 0	-91.8	0.38 (1)	4.46	H-N	-1117 / 0	0.43 (1)
J-K	0 / 41	-91.8	0.13 (1)	10.00	N-I	0 / 1837	0.41 (1)
U-B	-2037 / 0	0.0	0.22 (1)	5.92	M-I	-358 / 0	0.14 (1)
L-J	-2037 / 0	0.0	0.22 (1)	5.92	B-T	0 / 1571	0.35 (1)
U-T	0 / 0	-18.5	-18.5	0.10 (4)	M-J	0 / 1571	0.35 (1)
T-S	0 / 1494	-18.5	-18.5	0.30 (1)			
S-R	0 / 2871	-18.5	-18.5	0.51 (1)			
R-Q	0 / 2871	-18.5	-18.5	0.51 (1)			
Q-P	0 / 3506	-18.5	-18.5	0.62 (1)			
P-O	0 / 2872	-18.5	-18.5	0.51 (1)			
O-N	0 / 2872	-18.5	-18.5	0.51 (1)			
N-M	0 / 1494	-18.5	-18.5	0.30 (1)			
M-L	0 / 0	-18.5	-18.5	0.10 (4)			

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.I. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")

CALCULATED VERT. DEFL.(LL) = L/999 (0.20")

ALLOWABLE DEFL.(TL) = L/360 (1.17")

CALCULATED VERT. DEFL.(TL) = L/999 (0.39")

CSI: TO=0.66/1.00 (G-H:1), BC=0.62/1.00 (P-Q:1), WS=0.43/1.00 (D-S:1), SS=0.23/1.00 (H-I:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI)

	MAX	MIN	MAX	MIN	MAX	MIN
MT20	618	354	1667	788	1987	1656

PLATE TENSION TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.90 (S) (INPUT = 0.90)


JSI METAL = 0.90 (C) (INPUT = 1.00)



Structural component only
 DWG# T-2007083

JOB NAME 408151	TRUSS NAME T22	QUANTITY 2	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:47 2020 Page 1
 ID:h2dfqC44wS_E2tzqPs_atzllRw-ehJ89?n_Kml3PrKD6C22v?OAzcpWf3vZwVaFArZNCXg



LUMBER			
N. L. G. A. RULES			
CHORDS	SIZE	LUMBER	DESCR.
A - C	2x4	DRY	No.2
C - F	2x4	DRY	No.2
F - H	2x4	DRY	No.2
H - J	2x4	DRY	No.2
J - L	2x4	DRY	No.2
L - K	2x4	DRY	No.2
S - P	2x4	DRY	No.2
P - N	2x4	DRY	No.2
N - K	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
 EXCEPT
 DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW-p	MT20	5.0	6.0	1.50	3.00
C	TTWW-m	MT20	6.0	9.0	Edge	1.75
D	TMWW-t	MT20	4.0	4.0		
E	TMW-w	MT20	2.0	4.0		
F	TS-t	MT20	3.0	6.0		
G	TMWW-t	MT20	4.0	4.0		
H	TTWW-m	MT20	6.0	9.0	Edge	1.75
I	TMVW-p	MT20	5.0	6.0	1.50	3.00
K	BMV1-p	MT20	3.0	4.0		
L, M, Q, R						
L	BMWW-t	MT20	5.0	6.0		
N	BS-t	MT20	3.0	6.0		
O	BMWW-t	MT20	4.0	9.0		
P	BS-t	MT20	3.0	6.0		
S	BMV1-p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED		MAXIMUM FACTORED		INPUT		REQD	
JT	VERT	GROSS REACTION	HORZ	GROSS REACTION	HORZ	UP/LIFT	IN-SX	BRG	IN-SX
S	2086	0	0	2086	0	0	5-8	5-8	5-8
K	2086	0	0	2086	0	0	5-8	5-8	5-8

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
S	1458	971.0	0.0	0.0	0.0	488.0	0.0
K	1458	971.0	0.0	0.0	0.0	488.0	0.0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.28 FT.
 MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS		FACTORED		WEBS		FACTORED	
MEMB.	FORCE (LBS)	VERT. LOAD	CS (LC)	MEMB.	FORCE (LBS)	VERT. LOAD	CS (LC)
FR-TO				FR-TO			
A-B	0.41	-91.8	-91.8 0.13 (1)	R-C	-248.7	0.14 (1)	
B-C	-2004.0	-91.8	-91.8 0.64 (1)	C-D	0.1538	0.35 (1)	
C-D	-2653.0	-91.8	-91.8 0.74 (1)	D-E	-943.0	0.55 (1)	
D-E	-2978.0	-91.8	-91.8 0.78 (1)	E-F	0.450	0.10 (1)	
E-F	-2978.0	-91.8	-91.8 0.78 (1)	F-G	-513.0	0.30 (1)	
F-G	-2978.0	-91.8	-91.8 0.78 (1)	G-H	0.450	0.10 (1)	
G-H	-2653.0	-91.8	-91.8 0.74 (1)	H-I	-943.0	0.55 (1)	
H-I	-2004.0	-91.8	-91.8 0.64 (1)	I-J	0.1538	0.35 (1)	
I-J	0.41	-91.8	-91.8 0.13 (1)	J-K	-248.7	0.14 (1)	
J-K	-2026.0	0.0	0.0 0.22 (1)	K-L	0.1590	0.36 (1)	
K-L	-2026.0	0.0	0.0 0.22 (1)	L-I	0.1590	0.36 (1)	
S-R	0.0	-18.5	-18.5 0.14 (4)				
R-Q	0.1532	-18.5	-18.5 0.33 (1)				
Q-P	0.2653	-18.5	-18.5 0.49 (1)				
P-O	0.2653	-18.5	-18.5 0.49 (1)				
O-N	0.2653	-18.5	-18.5 0.49 (1)				
N-M	0.2653	-18.5	-18.5 0.49 (1)				
M-L	0.1532	-18.5	-18.5 0.33 (1)				
L-K	0.0	-18.5	-18.5 0.14 (4)				

TOTAL WEIGHT = 2 X 148 = 296 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF
 DL = 6.0 PSF
 BOT CH. LL = 0.0 PSF
 DL = 7.4 PSF
 TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
 CALCULATED VERT. DEFL.(LL) = L/999 (0.15")
 ALLOWABLE DEFL.(TL) = L/360 (1.17")
 CALCULATED VERT. DEFL.(TL) = L/999 (0.29")

CSI: TC=0.78/1.00 (D-E:1), BC=0.49/1.00 (Q-O:1),
 WB=0.55/1.00 (S-M:1), SS=0.27/1.00 (C-D:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
 MAX MIN MAX MIN MAX MIN
 MT20 .618 .354 .1867 .788 .1867 .1865

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.90 (B) (INPUT = 0.90)
 JSI METAL= 0.85 (N) (INPUT = 1.00)




Structural component only
 DWG# T-2007084

JOB NAME: 408151 TRUSS NAME: T23 QUANTITY: 2 PLY: 1 JOB DESC: GREEN PARK HOMES TRUSS DESC: Tamarack Roof Truss, Burlington DRWG NO. 1

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:48 2020 Page 1

ID: h2dflgC44wS_E2tqP5_atzIRw-ButWKNcc54tw07vPgVZHSWp40AOPUI99KoiHzNXXf

Scale = 1:57.5



<u>LUMBER</u>				
N. L. G. A. RULES				
CHORDS		SIZE		LUMBER
A - D		2x4	DRY	No.2
D - G		2x4	DRY	No.2
G - I		2x4	DRY	No.2
I - L		2x4	DRY	No.2
U - B		2x4	DRY	No.2
M - K		2x4	DRY	No.2
U - R		2x4	DRY	No.2
R - P		2x4	DRY	No.2
P - M		2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
EXCEPT
DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMV+p	MT20	3.0	4.0		
C TMVW-t	MT20	5.0	6.0	2.50	2.25
D TMVW+m	MT20	5.0	8.0	2.00	1.75
E TMVW-t	MT20	4.0	4.0		
F TMVW-w	MT20	2.0	4.0		
G TS-t	MT20	3.0	6.0		
H TMVW-t	MT20	4.0	4.0		
I TMVW+m	MT20	5.0	8.0	2.00	1.75
J TMVW-t	MT20	5.0	8.0	2.50	2.25
K TMV+p	MT20	3.0	4.0		
M BMVW1-t	MT20	5.0	6.0	2.25	3.00
N BMVW-t	MT20	4.0	4.0		
O BMVW-t	MT20	4.0	6.0		
P BS-t	MT20	3.0	6.0		
Q BS-t	MT20	4.0	9.0		
R BMVW-t	MT20	3.0	6.0		
S BS-t	MT20	4.0	6.0		
T BMVW-t	MT20	4.0	4.0		
U BMVW-t	MT20	5.0	6.0	2.25	3.00

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT VERT	2088	0	0	0
U VERT	2088	0	0	0
M VERT	2088	0	0	0

UNFACTORED REACTIONS

JT	1ST LCASE	MAX/MIN	COMPONENT REACTIONS	PERM/LIVE	WIND	DEAD	SOIL
U	COMBINED	971 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0
M	COMBINED	971 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) U, M

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.77 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.
ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	VERT. LOAD	LC1	MAX. FACTORED (PLF)	CSI (LC)	UNBRAC LENGTH	MEMB.	WEBS	MAX. FACTORED FORCE (LBS)	MAX. FACTORED (PLF)	CSI (LC)
FR-TO												
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00			C-T	0 / 156	0.04 (1)		
B-C	0 / 19	-91.8	-91.8	0.14 (1)	10.00			T-D	0 / 76	0.03 (4)		
C-D	-2023 / 0	-91.8	-91.8	0.20 (1)	4.59	D-S	0 / 1220	0.27 (1)				
D-E	-2308 / 0	-91.8	-91.8	0.58 (1)	3.94	S-E	-850 / 0	0.74 (1)				
E-F	-2534 / 0	-91.8	-91.8	0.57 (1)	3.77	E-Q	0 / 361	0.08 (1)				
F-G	-2534 / 0	-91.8	-91.8	0.57 (1)	3.77	Q-F	-461 / 0	0.40 (1)				
G-H	-2534 / 0	-91.8	-91.8	0.57 (1)	3.77	Q-H	0 / 361	0.08 (1)				
H-I	-2308 / 0	-91.8	-91.8	0.55 (1)	3.94	O-H	-850 / 0	0.74 (1)				
I-J	-2023 / 0	-91.8	-91.8	0.20 (1)	4.59	O-I	0 / 1220	0.27 (1)				
J-K	0 / 19	-91.8	-91.8	0.14 (1)	10.00	N-I	0 / 76	0.03 (4)				
K-L	0 / 41	-91.8	-91.8	0.13 (1)	10.00	N-J	0 / 156	0.04 (1)				
U-B	-246 / 0	0.0	0.0	0.03 (1)	7.81	U-C	-2277 / 0	0.98 (1)				
M-K	-246 / 0	0.0	0.0	0.03 (1)	7.81	J-M	-2277 / 0	0.98 (1)				
U-T	0 / 1433	-18.5	-18.5	0.33 (1)	10.00							
T-S	0 / 1535	-18.5	-18.5	0.35 (1)	10.00							
S-R	0 / 2308	-18.5	-18.5	0.42 (1)	10.00							
R-Q	0 / 2308	-18.5	-18.5	0.42 (1)	10.00							
Q-P	0 / 2308	-18.5	-18.5	0.42 (1)	10.00							
P-O	0 / 2308	-18.5	-18.5	0.42 (1)	10.00							
O-N	0 / 1535	-18.5	-18.5	0.35 (1)	10.00							
N-M	0 / 1433	-18.5	-18.5	0.33 (1)	10.00							

TOTAL WEIGHT = 2 X 162 = 323 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
BOT CH.	LL = 5.0	PSF
	DL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN. G.C.

LOADING IN FLAT SECTION BASED ON A SLOPE OF 5.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-08, CSA 088-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (1.17")
CALCULATED VERT. DEFL. (LL) = L/999 (0.13")
ALLOWABLE DEFL. (TL) = L/600 (1.17")
CALCULATED VERT. DEFL. (TL) = L/999 (0.23")

CSI: TC=0.57/1.00 (E-F:1), BC=0.42/1.00 (O-Q:1), WB=0.98/1.00 (J-M:1), SSI=0.24/1.00 (D-E:1)

DCL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR	SECTION
(PSI)	(PL)	(PL)
MAX MIN	MAX MIN	MAX MIN
MT20	618	354
	1667	786
	1957	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.89 (I) (INPUT = 0.50)
JSI METAL = 0.72 (P) (INPUT = 1.00)




Structural component only
DWG# T-2007085

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408151	T24	2	1	GREEN PARK HOMES	

Tamarack Roof Truss, Burlington

Version 8.310 5 Oct 2019 Mittek Industries, Inc. Sat Apr 25 11:19:49 2020 Page 1

ID:h2dIlgC44wS E2tzqPs_atzIRw-a4RuagpEsO?ne9UbDd4W_QTXEPW57ssaNp3MEjzNCXe



LUMBER	N L G A RULES	CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY	No.2	SPF	
D - F	2x4	DRY	No.2	SPF	
F - H	2x4	DRY	No.2	SPF	
H - K	2x4	DRY	No.2	SPF	
S - B	2x4	DRY	No.2	SPF	
L - J	2x4	DRY	No.2	SPF	
S - Q	2x4	DRY	No.2	SPF	
Q - N	2x4	DRY	No.2	SPF	
N - L	2x4	DRY	No.2	SPF	
ALL WEBS	2x3	DRY	No.2	SPF	
EXCEPT					
S - C	2x4	DRY	No.2	SPF	
I - L	2x4	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
D	TMWW-t	MT20	5.0	6.0	2.50	2.50
C	TTWW+m	MT20	5.0	6.0	2.00	1.75
E	TMWW-t	MT20	4.0	4.0		
F	TS-t	MT20	3.0	8.0		
G	TMWW-t	MT20	2.0	4.0		
H	TTWW+m	MT20	5.0	6.0	2.00	1.75
I	TMWW-t	MT20	5.0	6.0	2.50	2.50
J	TMV+p	MT20	3.0	4.0		
L	BMVW-t	MT20	5.0	6.0		
M	BMVW-t	MT20	4.0	4.0		
N	BS-t	MT20	3.0	6.0		
O	BMVW-t	MT20	4.0	9.0		
P	BMVW-t	MT20	4.0	8.0		
Q	BS-t	MT20	3.0	6.0		
R	BMVW-t	MT20	4.0	4.0		
S	BMVW-t	MT20	5.0	6.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED	MAXIMUM FACTORED	INPUT	REQD
	GROSS REACTION	GROSS REACTION	BRG	BRG
	VERT	HORZ	DOWN	HORZ
JT	2066	0	2066	0
S	2066	0	2066	0
L	2066	0	2066	0

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
S	1458	971 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0
L	1458	971 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.81 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF E-O.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED	FACTORED	MAX.	MEMB.	MAX. FACTORED	FACTORED	MAX.
	FORCE	VERT. LOAD	CS1 (LC)		FORCE	CS1 (LC)	
	(LBS)	(PLF)	(LC)		(LBS)	(LC)	
FR-TO		FROM	TO	FR-TO		FROM	TO
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	C-R	0 / 64
B-C	0 / 26	-91.8	-91.8	0.21 (1)	10.00	R-D	0 / 126
C-D	-2006 / 0	-91.8	-91.8	0.29 (1)	4.50	D-P	0 / 998
D-E	-2162 / 0	-91.8	-91.8	0.73 (1)	3.81	P-E	-650 / 0
E-F	-2162 / 0	-91.8	-91.8	0.73 (1)	3.81	E-O	-2 / 0
F-G	-2162 / 0	-91.8	-91.8	0.73 (1)	3.81	O-G	-949 / 0
G-H	-2162 / 0	-91.8	-91.8	0.73 (1)	3.82	C-H	0 / 996
H-I	-2008 / 0	-91.8	-91.8	0.29 (1)	4.50	M-H	0 / 126
I-J	0 / 26	-91.8	-91.8	0.21 (1)	10.00	M-I	0 / 64
J-K	0 / 41	-91.8	-91.8	0.13 (1)	10.00	S-C	-2291 / 0
S-B	-264 / 0	0.0	0.0	0.03 (1)	7.81	I-L	-2291 / 0
L-J	-264 / 0	0.0	0.0	0.03 (1)	7.81		

S-R	0 / 1487	-18.5	-18.5	0.38 (1)	10.00
R-Q	0 / 1519	-18.5	-18.5	0.39 (1)	10.00
Q-P	0 / 1519	-18.5	-18.5	0.39 (1)	10.00
P-O	0 / 2183	-19.5	-19.5	0.42 (1)	10.00
O-N	0 / 1519	-18.5	-18.5	0.38 (1)	10.00
N-M	0 / 1519	-18.5	-18.5	0.38 (1)	10.00
M-L	0 / 1487	-18.5	-18.5	0.38 (1)	10.00

TOTAL WEIGHT = 2 X 163 = 326 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL	= 25.6 PSF
DL	= 6.0 PSF
BOT CH. LL	= 0.0 PSF
DL	= 7.4 PSF
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.10")
ALLOWABLE VERT. DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/999 (0.21")

CS1: TC=0.73/1.00 (D-E-1), BC=0.42/1.00 (O-P-1),
WB=0.97/1.00 (I-L-1), SS=0.28/1.00 (D-E-1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT


NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX	MIN	MAX
MIN	MAX	MIN
MT20	618	354
	1667	788
	1987	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP = 0.87 (I) (INPUT = 0.90)
JSI METAL = 0.56 (I) (INPUT = 1.00)



Structural component only
DWG# T-2007086

JOB NAME 408151	TRUSS NAME T25	QUANTITY 2	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:19:50 2020 Page 1
 ID:h2dfgC44wS_E2tzqPs_atzllRw-2G?Ho0psdh7eGJ2nKblXd0n8pt_sTb?cTpvms9zNCXcd
 Scale = 1:57.3



LUMBER				DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER				TOTAL WEIGHT = 2 X 182 = 363 lb			
N. L. G. A. RULES	CHORDS	SIZE	LUMBER	BEARINGS				DESIGN CRITERIA			
A - D	2x4	DRY	No.2	FACTORED GROSS REACTION				SPECIFIED LOADS:			
D - F	2x4	DRY	No.2	MAXIMUM FACTORED GROSS REACTION				TOP CH. LL = 25.6 PSF			
F - H	2x4	DRY	No.2	INPUT BRG				DL = 8.0 PSF			
H - K	2x4	DRY	No.2	RECORD BRG				BOT CH. LL = 0.0 PSF			
U - B	2x4	DRY	No.2	UP-LIFT IN-SX				DL = 7.4 PSF			
L - J	2x4	DRY	No.2	IN-SX				TOTAL LOAD = 39.0 PSF			
U - R	2x4	DRY	No.2					SPACING = 24.0 IN. C/C			
R - O	2x4	DRY	No.2					LOADING IN FLAT SECTION BASED ON A SLOPE OF 5.00/12			
O - L	2x4	DRY	No.2					THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015			
ALL WEBS EXCEPT D - O	2x3	DRY	No.2					THIS DESIGN COMPLIES WITH:			
D - O	2x4	DRY	No.2					- PART 9 OF BCBC 2018, CBC 2012, ABC 2019			
E - P	2x4	DRY	No.2					- PART 9 OF CBC 2012 (2019 AMENDMENT)			
P - H	2x4	DRY	No.2					- CSA 086-09, CSA 086-14			
DRY: SEASONED LUMBER.								- TPIC 2011, TPIC 2014			

RY: SEASONED LUMBER.

PLATES (Table is in inches)

TYPE	PLATES	W	LEN	Y	X
TMVW+p	MT20	5.0	6.0	2.00	2.00
TMVW-i	MT20	4.0	4.0	2.00	1.25
TTVW-m	MT20	5.0	6.0	2.00	1.75
TMVW-i	MT20	4.0	4.0		
TS-i	MT20	3.0	6.0		
TMVW+i	MT20	2.0	4.0		
TTVW-m	MT20	5.0	6.0	2.00	1.75
TMVW-i	MT20	4.0	4.0	2.00	1.25
TMVW+p	MT20	5.0	6.0	2.00	2.00
BMV1+p	MT20	3.0	4.0		
BMVW-i	MT20	5.0	6.0		

C, S

BMVW-i	MT20	4.0	4.0		
BS-i	MT20	3.0	6.0		
BMVWW-i	MT20	4.0	9.0		
BS-i	MT20	3.0	6.0		
BMVW-i	MT20	5.0	6.0		
BMV1-p	MT20	3.0	4.0		

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.44 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF E-Q, E-P, G-P.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.		MAX. FACTORED FORCE (LBS)		MAX. FACTORED FORCE (LBS)		MAX. FACTORED FORCE (LBS)	
FR-TO		VERT. LOAD LC1 (PLF)		MAX. UNBRACED LENGTH FR-TO		MAX. UNBRACED LENGTH FR-TO	
A-B	0/41	-91.8	-91.8	0.13 (1)	10.00	T-C	-357/0
B-C	-1994/0	-91.8	-91.8	0.30 (1)	4.53	C-S	0/10 (1)
C-D	-1957/0	-91.8	-91.8	0.29 (1)	4.57	S-D	0/188
D-E	-1923/0	-91.8	-91.8	0.40 (1)	4.44	D-Q	0/810
E-F	-1921/0	-91.8	-91.8	0.37 (1)	4.49	Q-E	-569/0
F-G	-1921/0	-91.8	-91.8	0.37 (1)	4.49	E-P	-3/0
G-H	-1921/0	-91.8	-91.8	0.40 (1)	4.45	P-G	-568/0
H-I	-1957/0	-91.8	-91.8	0.29 (1)	4.57	P-H	0/807
I-J	-1984/0	-91.8	-91.8	0.30 (1)	4.53	H-H	0/189
J-K	0/41	-91.8	-91.8	0.13 (1)	10.00	N-I	-121/0
U-B	-2028/0	0.0	0.0	0.22 (1)	5.94	M-I	-358/0
L-J	-2028/0	0.0	0.0	0.22 (1)	5.94	B-T	0/1617

SMALL BUILDING REQUIREMENTS OF PART 9, NBCO 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCO 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.08")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/998 (0.16")


CSI: TO=0.40/1.00 (D-E-T), BC=0.38/1.00 (P-Q-T),
WB=0.36/1.00 (B-T-I), SSI=0.25/1.00 (D-E-T)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10


COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES



Structural component only
 DWG# T-2007087



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
F - I	2x4	DRY	No.2
R - B	2x4	DRY	No.2
J - H	2x4	DRY	No.2
R - O	2x4	DRY	No.2
O - M	2x4	DRY	No.2
M - J	2x4	DRY	No.2
ALL WEBS EXCEPT	2x3	DRY	No.2
D - N	2x4	DRY	No.2
N - F	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (tablets in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMVW-p	MT20	5.0	8.0	1.50	3.00
C TMWW-t	MT20	4.0	4.0	2.00	1.25
D TTWW-m	MT20	5.0	6.0	2.25	1.50
E TMVW-w	MT20	2.0	4.0		
F TTWW-m	MT20	5.0	6.0	2.25	1.50
G TMVW-t	MT20	4.0	4.0	2.00	1.25
H TMVW-p	MT20	5.0	8.0	1.50	3.00
J BMV1-p	MT20	3.0	4.0		
K BMVW-t	MT20	5.0	6.0		
L BS-1	MT20	4.0	4.0		
M BMVW-t	MT20	3.0	6.0		
N BMVW-t	MT20	4.0	4.0		
O BS-1	MT20	3.0	6.0		
P BMVW-t	MT20	4.0	4.0		
Q BMVW-t	MT20	5.0	6.0		
R BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
R	2068	0	2068	0	5-8	5-8
J	2068	0	2068	0	5-8	5-8

UNFACTORED REACTIONS

JT	1ST CASE		MAX/MIN. COMPONENT REACTIONS		WIND	DEAD	SOIL
	COMBINED	SNOW	LIVE	PERM. LIVE			
R	1458	971/0	0/0	0/0	0/0	488/0	0/0
J	1458	971/0	0/0	0/0	0/0	488/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) R, J

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.96 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF E-N.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS		WEBS	
	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)
FR-TO				
A-B	0/41	-91.8	-91.8	0.13 (1)
B-C	-2021/0	-91.8	-91.8	0.39 (1)
C-D	-1808/0	-91.8	-91.8	0.37 (1)
D-E	-1809/0	-91.8	-91.8	0.74 (1)
E-F	-1809/0	-91.8	-91.8	0.74 (1)
F-G	-1808/0	-91.8	-91.8	0.37 (1)
G-H	-2021/0	-91.8	-91.8	0.39 (1)
H-I	0/41	-91.8	-91.8	0.13 (1)
I-J	-2024/0	0.0	0.0	0.22 (1)
J-H	-2024/0	0.0	0.0	0.22 (1)
R-Q	0/0	-18.5	-18.5	0.10 (4)
Q-P	0/1580	-18.5	-18.5	0.34 (1)
P-O	0/1437	-18.5	-18.5	0.35 (1)
O-N	0/1437	-18.5	-18.5	0.35 (1)
N-M	0/1437	-18.5	-18.5	0.35 (1)
M-L	0/1437	-18.5	-18.5	0.35 (1)
L-K	0/1580	-18.5	-18.5	0.34 (1)
K-J	0/0	-18.5	-18.5	0.10 (4)

TOTAL WEIGHT = 4 X 173 = 693 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF

DL = 6.0 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")

CALCULATED VERT. DEFL.(LL) = L/999 (0.08")

ALLOWABLE DEFL.(TL) = L/360 (1.17")

CALCULATED VERT. DEFL.(TL) = L/999 (0.17")

CSI: TC=0.74/1.00 (D-E:1), BC=0.35/1.00 (L-N:1), WB=0.58/1.00 (E-N:1), SS=0.33/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LBS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 618 354 1667 788 1997 1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.89 (5) (INPUT = 0.90)

JSI METAL = 0.46 (4) (INPUT = 1.00)




Structural component only
DWG# T-2007088

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408151	T27	2	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MTEK Industries, Inc. Sat Apr 25 11:19:53 2020 Page 1

ID:h2dflgC44ws_E2tqPs_atzllRw-TrgPQ2slvcVC7mMST9S9GeHs1uT3o2SIR1ZNUzNCXa



LUMBER	N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY	No.2	SPF	
D - E	2x4	DRY	No.2	SPF	
E - G	2x4	DRY	No.2	SPF	
G - H	2x4	DRY	No.2	SPF	
H - K	2x4	DRY	No.2	SPF	
T - B	2x4	DRY	No.2	SPF	
L - J	2x4	DRY	No.2	SPF	
T - Q	2x4	DRY	No.2	SPF	
Q - O	2x4	DRY	No.2	SPF	
O - L	2x4	DRY	No.2	SPF	
ALL WEBS EXCEPT	2x4	DRY	No.2	SPF	
S - C	2x3	DRY	No.2	SPF	
C - R	2x3	DRY	No.2	SPF	
N - I	2x3	DRY	No.2	SPF	
M - I	2x3	DRY	No.2	SPF	
B - S	2x3	DRY	No.2	SPF	
M - J	2x3	DRY	No.2	SPF	

DRY, SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMVW-p	MT20	5.0	6.0	1.50	3.00
C TMVW-t	MT20	4.0	4.0	2.00	1.25
D TS-t	MT20	3.0	6.0		
E TTWW-m	MT20	5.0	6.0	Edge	3.00
F TMW-w	MT20	2.0	4.0		
G TTWW-m	MT20	5.0	6.0	Edge	3.00
H TS-t	MT20	3.0	6.0		
I TMVW-t	MT20	4.0	4.0	2.00	1.25
J TMVW-p	MT20	5.0	6.0	1.50	3.00
L BMV1-p	MT20	3.0	4.0		
M BMVW-t	MT20	5.0	6.0		
N BMVW-t	MT20	4.0	4.0		
O BS-t	MT20	3.0	6.0		
P BMVWVW-t	MT20	4.0	4.0		
Q BS-t	MT20	3.0	6.0		
R BMVW-t	MT20	4.0	4.0		
S BMVW-t	MT20	5.0	6.0		
T BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
JT	VERT	HORZ	DOWN	HORZ
T	2066	0	2066	0
L	2066	0	2066	0

UNFACTORED REACTIONS

1ST CASE	MAX/MIN	COMPONENT REACTIONS
JT	COMBINED	SNOW
T	1458	971 / 0
L	1458	971 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) T, L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.27 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF C-R, F-P, I-N.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED FORCE (LBS)	VERT. LOAD (PLF)	MAX. FACTORED FORCE (LBS)	VERT. LOAD (PLF)	MAX. FACTORED FORCE (LBS)	VERT. LOAD (PLF)
MEMB.						
FR-TO						
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	S-C
B-C	-2039 / 0	-91.8	-91.8	0.50 (1)	4.27	C-R
C-D	-1844 / 0	-91.8	-91.8	0.46 (1)	4.47	R-E
D-E	-1844 / 0	-91.8	-91.8	0.46 (1)	4.47	E-P
E-F	-1621 / 0	-91.8	-91.8	0.50 (1)	4.60	P-F
F-G	-1621 / 0	-91.8	-91.8	0.50 (1)	4.60	G-H
G-H	-1844 / 0	-91.8	-91.8	0.46 (1)	4.47	H-I
H-I	-1844 / 0	-91.8	-91.8	0.46 (1)	4.47	I-J
I-J	-2039 / 0	-91.8	-91.8	0.50 (1)	4.27	J-K
J-K	0 / 41	-91.8	-91.8	0.13 (1)	10.00	K-L
K-L	-2021 / 0	0.0	0.0	0.21 (1)	5.94	L-M
L-M	-2021 / 0	0.0	0.0	0.21 (1)	5.94	M-N

T-S	0 / 0	-18.5	-18.5	0.14 (4)	10.00
S-R	0 / 1597	-18.5	-18.5	0.33 (1)	10.00
R-Q	0 / 1387	-18.5	-18.5	0.30 (1)	10.00
Q-P	0 / 1387	-18.5	-18.5	0.30 (1)	10.00
P-O	0 / 1387	-18.5	-18.5	0.30 (1)	10.00
O-N	0 / 1387	-18.5	-18.5	0.30 (1)	10.00
N-M	0 / 1597	-18.5	-18.5	0.33 (1)	10.00
M-L	0 / 0	-18.5	-18.5	0.14 (4)	10.00

TOTAL WEIGHT = 2 X 180 = 360 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
DL = 6.0	PSF	
BOT CH.	LL = 0.0	PSF
DL = 7.4	PSF	
TOTAL LOAD = 39.0	PSF	

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.07")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/999 (0.14")

CS: TC=0.50/1.00 (E-F:1), BC=0.33/1.00 (M-N:1), WB=0.45/1.00 (F-P:1), SS=0.28/1.00 (E-F:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX	MIN	MAX
MT20	618	354
	1687	788
	1987	1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (J) (INPUT = 0.90)
JSI METAL= 0.47 (O) (INPUT = 1.00)




Structural component only
DWG# T-2007089

CONTINUED ON PAGE 2

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408151	T28	2	1	TRAUSS DESC.		

Tamareck Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:54 2020 Page 1
ID:h2dfiqC44ws_E2tqPs_atzllRw-x1EndOInGwd3kwMZ0AghhTAWTQH0oB?bX5n7vxxzNCXZ



Scale: 1/4"=1'

LUMBER	CHORDS	SIZE	DRY	LUMBER	DESCR.
N. L. G. A. RULES					
A - D	2x4	DRY	No.2	SPF	
D - G	2x4	DRY	No.2	SPF	
L - B	2x4	DRY	No.2	SPF	
H - F	2x4	DRY	No.2	SPF	
L - J	2x4	DRY	No.2	SPF	
J - H	2x4	DRY	No.2	SPF	

ALL WEBS 2x3 DRY No.2
EXCEPT
DRY: SEASONED LUMBER.

PLATES (table is in inches)	JT TYPE	PLATES	W	LEN	Y	X
B TMV+p	MT20	3.0	4.0			
C TMWW-t	MT20	4.0	6.0			
D ITWW+p	MT20	4.0	6.0			
E TMWW-t	MT20	4.0	6.0			
F TMV+p	MT20	3.0	4.0			
H BMVW-t	MT20	4.0	4.0			
I BMVW-t	MT20	4.0	6.0			
J SS-t	MT20	3.0	6.0			
K BMVW-t	MT20	4.0	6.0			
L BMVW-t	MT20	4.0	4.0			

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	DOWN	UPLIFT	IN-SX
L	1041	0	0	5-8
H	1041	0	0	5-8

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN. COMPONENT REACTIONS						
JT	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
L	734	495 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0
H	734	495 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) L, H

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MEMB.	MAX. FACTORED	FORCE (LBS)	FACTORED	VERT. LOAD (LBS)	MAX. FACTORED	CSF (LBS)	MAX. FACTORED	CSF (LBS)
FR-TO									
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	D-I	0 / 339	0.08 (1)	
B-C	0 / 29	-91.8	-91.8	0.28 (1)	10.00	E-E	-222 / 0	0.09 (1)	
C-D	-764 / 0	-91.8	-91.8	0.20 (1)	6.25	K-D	0 / 339	0.08 (1)	
D-E	-764 / 0	-91.8	-91.8	0.20 (1)	6.25	C-K	-222 / 0	0.09 (1)	
E-F	0 / 29	-91.8	-91.8	0.28 (1)	10.00	L-C	-964 / 0	0.96 (1)	
F-G	0 / 41	-91.8	-91.8	0.13 (1)	10.00	E-H	-964 / 0	0.96 (1)	
L-B	-270 / 0	0.0	0.0	0.03 (1)	7.81				
H-F	-270 / 0	0.0	0.0	0.03 (1)	7.81				
L-K	0 / 632	-18.5	-18.5	0.18 (4)	10.00				
K-J	0 / 459	-18.5	-18.5	0.17 (4)	10.00				
J-I	0 / 459	-18.5	-18.5	0.17 (4)	10.00				
I-H	0 / 632	-18.5	-18.5	0.18 (4)	10.00				

TOTAL WEIGHT = 2 X 82 = 163 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF NBCC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TRC 2011, TPIC 2014

(5% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (LL) = $L/699$ (0.02")
ALLOWABLE DEFL. (TL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (TL) = $L/999$ (0.04")

CSF: TC=0.28/1.00 (B-C:1), BC=0.18/1.00 (H-I:4), WB=0.58/1.00 (E-H:1), SS=0.14/1.00 (C-D:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354 1657 798 1987 1656	

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.78 (C) (INPUT = 0.80)
JSI METAL= 0.26 (C) (INPUT = 1.00)



Structural component only
DWG# T-2007090

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408151	T29	1	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington



Version 8.310 S Ctr 29 2019 MITek Industries, Inc. Sat Apr 25 11:19:55 2020 Page 1
ID:h2dligC44wS_E2t2qPs_atzIIrW-PEoArk1?RElW4xlatBwEhlg9qdOXaSkmlWqSNzNCXY

Scale = 1:54.7

LUMBER	N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - D	2x4 DRY	No.2		
D - G	2x4 DRY	No.2		
L - B	2x4 DRY	No.2		
H - F	2x4 DRY	No.2		
L - J	2x4 DRY	No.2		
J - H	2x4 DRY	No.2		
ALL WEBS	2x3 DRY	No.2		
EXCEPT				

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMV+p	MT20	3.0	4.0		
C TMWW-t	MT20	4.0	4.0	2.00	1.50
D TTWW+p	MT20	5.0	5.0	Edge	
E TMWW-t	MT20	4.0	4.0	2.00	1.50
F TMV+p	MT20	3.0	4.0		
H BMVW1-t	MT20	4.0	4.0		
I BMVW-t	MT20	4.0	4.0		
J BS-t	MT20	3.0	6.0		
K BMVW-t	MT20	4.0	4.0		
L BMVW1-t	MT20	4.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

FACTORED	MAXIMUM FACTORED	INPUT	RECORD
GROSS REACTION	GROSS REACTION	BRG	BRG
JT VERT	JT VERT	JT VERT	JT VERT
L 1041	0	1041	0
H 1041	0	1041	0

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN. COMPONENT REACTIONS	1ST LCASE	MAX/MIN. COMPONENT REACTIONS
JT COMBINED	JT COMBINED	JT COMBINED	JT COMBINED
L 734	495 / 0	0 / 0	0 / 0
H 734	495 / 0	0 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) L, H

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED VERT. LOAD (LBS)	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED VERT. LOAD (LBS)	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED VERT. LOAD (LBS)
FR-TO										
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	D-I	0 / 254	0.06 (1)		
B-C	0 / 28	-91.8	-91.8	0.26 (1)	10.00	J-E	-138 / 14	0.10 (1)		
C-D	-833 / 0	-91.8	-91.8	0.20 (1)	6.25	K-D	0 / 254	0.06 (1)		
D-E	-833 / 0	-91.8	-91.8	0.20 (1)	6.25	C-K	-138 / 14	0.10 (1)		
E-F	0 / 28	-91.8	-91.8	0.26 (1)	10.00	L-C	-875 / 0	0.30 (1)		
F-G	0 / 41	-91.8	-91.8	0.13 (1)	10.00	E-H	-875 / 0	0.30 (1)		
L-B	-276 / 0	0.0	0.0	0.04 (1)	7.81					
H-F	-276 / 0	0.0	0.0	0.04 (1)	7.81					
L-K	0 / 495	-18.5	-18.5	0.17 (4)	10.00					
K-J	0 / 395	-18.5	-18.5	0.16 (4)	10.00					
J-I	0 / 395	-18.5	-18.5	0.16 (4)	10.00					
I-H	0 / 495	-18.5	-18.5	0.17 (4)	10.00					

TOTAL WEIGHT = 91 b (M/F)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6 PSF
DL = 6.0 PSF	
BOT CH.	LL = 0.0 PSF
DL = 7.4 PSF	
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2018 AMENDMENT)
- CSA 086-08, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (0.55")
CALCULATED VERT. DEFL. (LL) = L/999 (0.02")
ALLOWABLE DEFL. (TL) = L/360 (0.55")
CALCULATED VERT. DEFL. (TL) = L/999 (0.04")

CSI: TC=0.26/1.00 (E-F:1), BC=0.17/1.00 (K-L:4),
WB=0.90/1.00 (E-H:1), SSI=0.14/1.00 (E-F:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	818 354 1687 788 1887 1656	

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.88 (E) (INPUT = 0.90)
JSI METAL= 0.34 (C) (INPUT = 1.00)



Structural component only
DWG# T-2007091

JOB NAME 408151	TRUSS NAME T30	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
--------------------	-------------------	---------------	----------	-------------------------------	----------

Tamarack Roof Truss, Burlington



Version 8.3.10 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:56 2020 Page 1

Scale = 1/4\"/>

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - D	2x4	DRY	No.2
D - E	2x6	DRY	No.2
E - H	2x4	DRY	No.2
L - B	2x4	DRY	No.2
I - G	2x4	DRY	No.2
L - K	2x4	DRY	No.2
K - I	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2 EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
C	TMWW-i	MT20	4.0	4.0	2.00	1.75
D	TTW-h	MT20	4.0	6.0		
E	TTWW+m	MT20	5.0	6.0	Edge	
F	TMWW-i	MT20	4.0	6.0		
G	TMV+p	MT20	3.0	4.0		
I	BMVW-i	MT20	4.0	4.0		
J	BMWW-i	MT20	4.0	4.0		
K	BSWWW-i	MT20	6.0	9.0	Edge 3.75	
L	BMVW-i	MT20	4.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
L	VERT 1041	DOWN 1041	0	5-8
I	HORIZ 1041	HORIZ 1041	0	MECHANICAL

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT I. MINIMUM BEARING LENGTH AT JOINT I = 3-6.

UNFACTORED REACTIONS

JT	1ST CASE COMBINED	MAX/MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
L	734	495 / 0	0 / 0	0 / 0	239 / 0	0 / 0
I	734	495 / 0	0 / 0	0 / 0	239 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 8.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF E-K.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. UNBRACED LENGTH (FT)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. UNBRACED LENGTH (FT)	MAX. FACTORED FORCE (LBS)
FR-TO		FROM TO		FR-TO			
A-B	0 / 41	-91.8 -91.8	0.13 (1)	10.00	C-K	-98 / 9	0.09 (1)
B-C	0 / 27	-91.8 -91.8	0.23 (1)	10.00	K-D	0 / 164	0.04 (1)
C-D	-596 / 0	-91.8 -91.8	0.18 (1)	6.25	K-E	-109 / 0	0.07 (4)
D-E	-414 / 0	-91.8 -91.8	0.01 (1)	6.25	J-F	0 / 266	0.07 (4)
E-F	-582 / 0	-91.8 -91.8	0.18 (1)	6.25	J-F	-93 / 15	0.09 (1)
F-G	0 / 27	-91.8 -91.8	0.23 (1)	10.00	L-C	-846 / 0	0.78 (1)
G-H	0 / 41	-91.8 -91.8	0.13 (1)	10.00	F-I	-882 / 0	0.79 (1)
L-B	-265 / 0	0.0 0.0	0.04 (1)	7.81			
I-G	-265 / 0	0.0 0.0	0.04 (1)	7.81			
L-K	0 / 468	-18.5 -18.5	0.38 (4)	10.00			
K-J	0 / 424	-18.5 -18.5	0.30 (4)	10.00			
J-I	0 / 477	-18.5 -18.5	0.30 (4)	10.00			

TOTAL WEIGHT = 97 lb (MIF)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.9	PSF
DL = 6.0	PSF	
BOT CH.	LL = 0.0	PSF
DL = 7.4	PSF	
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.0/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (LL) = $L/989$ (0.01")
ALLOWABLE DEFL. (TL) = $L/360$ (0.55")
CALCULATED VERT. DEFL. (TL) = $L/989$ (0.17")

CSI: $TO=0.23/1.00$ (B-C:1), $EC=0.36/1.00$ (K-L:4), $WB=0.79/1.00$ (F-I:1), $SSI=0.14/1.00$ (J-K:4)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PL)
MAX MIN	MAX MIN	MAX MIN
MT20	619 354	1667 788 1987 1658


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP=0.89 (C) (INPUT = 0.90)
JSI METAL=0.31 (C) (INPUT = 1.00)



Structural component only
DWG# T-2007092



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - D	2x4	DRY	No.2
D - E	2x4	DRY	No.2
E - H	2x4	DRY	No.2
M - B	2x4	DRY	No.2
I - G	2x4	DRY	No.2
M - K	2x4	DRY	No.2
K - I	2x4	DRY	No.2
ALL WEBS EXCEPT	2x3	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
C	TMWW-t	MT20	4.0	4.0	2.00	1.75
D	TTW-m	MT20	4.0	4.0		
E	TTWW+m	MT20	5.0	6.0	2.25	1.50
F	TMWW-t	MT20	4.0	4.0	2.00	1.75
G	TMV+p	MT20	3.0	4.0		
I	BMVW1-t	MT20	4.0	4.0		
J	BMWW-t	MT20	4.0	4.0		
K	BS-t	MT20	3.0	6.0		
L	BMWWW-t	MT20	4.0	8.0		
M	BMVW1-t	MT20	4.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	RECORD BRG
	VERT	HORZ	DOWN	HORZ		
M	1041	0	1041	0	5-8	5-8
I	1041	0	1041	0	0	MECHANICAL

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT I. MINIMUM BEARING LENGTH AT JOINT I = 3-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN COMPONENT REACTIONS	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
M	734	485 / 0	0 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0
I	734	485 / 0	0 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) M

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 8.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MAX. UNBRACED LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CSI (LC)
FR-TO		FROM	TO		FR-TO		
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	C-L	-10 / 34 0.01 (4)
B-C	0 / 22	-91.8	-91.8	0.16 (1)	10.00	L-D	0 / 110 0.03 (4)
C-D	-613 / 0	-91.8	-91.8	0.13 (1)	6.25	L-E	0 / 0 0.00 (1)
D-E	-453 / 0	-91.8	-91.8	0.14 (1)	6.25	J-E	0 / 109 0.03 (4)
E-F	-612 / 0	-91.8	-91.8	0.13 (1)	6.25	J-F	-11 / 34 0.01 (4)
F-G	0 / 22	-91.8	-91.8	0.16 (1)	10.00	M-C	-873 / 0 0.60 (1)
G-H	0 / 41	-91.8	-91.8	0.13 (1)	10.00	F-I	-873 / 0 0.60 (1)
M-B	-245 / 0	0.0	0.0	0.04 (1)	7.81		
I-G	-245 / 0	0.0	0.0	0.04 (1)	7.81		
M-L	0 / 457	-18.5	-18.5	0.21 (4)	10.00		
L-K	0 / 453	-18.5	-18.5	0.20 (4)	10.00		
K-J	0 / 453	-18.5	-18.5	0.20 (4)	10.00		
J-I	0 / 457	-18.5	-18.5	0.21 (4)	10.00		

TOTAL WEIGHT = 82 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL =	25.6	PSF
	DL =	8.0	PSF
BOT CH.	LL =	0.0	PSF
	DL =	7.4	PSF
TOTAL LOAD	=	39.0	PSF

SPACING = 24.0 IN./C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 5.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCC 2010, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.55")
CALCULATED VERT. DEFL.(LL) = L/999 (0.01")
ALLOWABLE DEFL.(TL) = L/360 (0.55")
CALCULATED VERT. DEFL.(TL) = L/999 (0.07")

CSI: TC=0.16/1.00 (F-G:1), BC=0.21/1.00 (L-J:4),
WB=0.60/1.00 (C-M:1), SSI=0.12/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP(DRY) SHEAR	SECTION
(PSI)	(PL)
MAX	MIN
618	354
1687	788
1987	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.87 (C) (INPUT = 0.90)
JSI METAL= 0.31 (C) (INPUT = 1.00)




Structural component only
DWG# T-2007093

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408151	T32	1	1	GREEN PARK HOMES	

Tamareck Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITK Industries, Inc. Sat Apr 25 11:19:58 2020 Page 1
ID:h2dfgC44wS_E2tZqPs_atzIIrW-ppUItWtK98VDYgKF0ldrJL8I2I0k8OBSjIK2izNCXV



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
A - C	2x4	DRY	No.2
C - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
K - B	2x4	DRY	No.2
G - E	2x4	DRY	No.2
K - I	2x4	DRY	No.2
I - G	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	4.0	4.0	1.00	2.00
C	TTWW+m	MT20	5.0	5.0	2.25	1.50
D	TTW-m	MT20	4.0	4.0		
E	TMVW+p	MT20	4.0	4.0	1.00	2.00
G	BMV1+p	MT20	3.0	4.0		
H	BMVWW-I	MT20	4.0	9.0		
I	BS-I	MT20	3.0	6.0		
J	BMVW-I	MT20	4.0	4.0		
K	BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY

BUILDING DESIGNER

BEARINGS

	FACTORED	MAXIMUM FACTORED	INPUT	REQD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	HORZ	UP/LIFT	IN-SX
K	1041	0	0	5-8
G	1041	0	0	MECHANICAL

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT G. MINIMUM BEARING LENGTH AT JOINT G = 3-8.

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
K	734	495 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0
G	734	495 / 0	0 / 0	0 / 0	0 / 0	239 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 8.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF C-H.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED CS (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CS (LC)	
FR-TO		FROM	TO	FR-TO			
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	J-C	-115 / 46
B-C	-819 / 0	-91.8	-91.8	0.35 (1)	6.25	C-H	0 / 0
C-D	-473 / 0	-91.8	-91.8	0.39 (1)	6.25	H-D	-115 / 46
D-E	-819 / 0	-91.8	-91.8	0.35 (1)	6.25	B-J	0 / 526
E-F	0 / 41	-91.8	-91.8	0.13 (1)	10.00	H-E	0 / 526
K-B	-1000 / 0	0.0	0.0	0.18 (1)	7.81		
G-E	-1000 / 0	0.0	0.0	0.15 (1)	7.81		
K-J	0 / 0	-18.5	-18.5	0.13 (4)	10.00		
J-I	0 / 473	-18.5	-18.5	0.17 (4)	10.00		
I-H	0 / 473	-18.5	-18.5	0.17 (4)	10.00		
H-G	0 / 0	-18.5	-18.5	0.13 (4)	10.00		

TOTAL WEIGHT = 79 lb

(M/F)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.8	PSF
	DL = 8.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 39.0	PSF

SPACING = 24.0 IN./C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 085-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.55")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.01")
ALLOWABLE DEFL.(TL) = $L/360$ (0.55")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.03")

CSI: TC=0.39/1.00 (C-D:1), BC=0.17/1.00 (H-J:4), WB=0.12/1.00 (B-J:1), SS=0.21/1.00 (C-D:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)	
MAX MIN	MAX MIN	MAX MIN	
MT20	818 354	1667 788	1987 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.82 (B) (INPUT = 0.90)
JSI METAL = 0.23 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007094

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408151	G33	1	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington		TRUSS DESC.			



LUMBER	CHORDS	SIZE	DRY	LUMBER
N. L. G. A. RULES				
L - B	2x4	DRY	No.2	
A - D	2x4	DRY	No.2	
D - G	2x4	DRY	No.2	
H - F	2x4	DRY	No.2	
L - H	2x4	DRY	No.2	
ALL WEBS	2x3	DRY	No.2	
ALL GABLE WEBS	2x3	DRY	No.2	
DRY: SEASONED LUMBER.				
GABLE STUDS SPACED AT	2-0-0	OC.		

PLATES (table is in inches)	W	LEN	Y	X
JT TYPE				
B TMVW+p	MT20	4.0	4.0	1.00 2.00
C TMVW+w	MT20	2.0	4.0	
D TTW+p	MT20	4.0	8.0	Edge
E TMVW+w	MT20	2.0	4.0	
F TMVW+p	MT20	4.0	4.0	1.00 2.00
G BMV1+p	MT20	3.0	4.0	
H BMVW1-i	MT20	4.0	4.0	
I BMVW1+w	MT20	2.0	4.0	
K BMVW1-i	MT20	4.0	4.0	
L BMV1+p	MT20	3.0	4.0	

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

THIS TRUSS DESIGNED FOR CONTINUOUS BEARINGS.

THIS TRUSS REQUIRES RIGID SHEATHING ON EXPOSED FACE.

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S)

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING									
TOTAL LOAD CASES: (4)									
CHORDS					WEBS				
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. GSI (LC)	MAX. UNBRACED LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. GSI (LC)		
FR-TO		FROM TO			FR-TO				
L-B	-231 / 0	0.0	0.0	0.02 (1)	7.81	J-D	-123 / 0	0.05 (1)	
A-B	0 / 41	-91.8	-91.8	0.13 (1)	10.00	K-C	-236 / 0	0.05 (1)	
B-C	-11 / 0	-91.8	-91.8	0.07 (1)	6.25	I-E	-236 / 0	0.05 (1)	
C-D	-32 / 0	-91.8	-91.8	0.07 (1)	6.25	B-K	0 / 23	0.01 (1)	
D-E	-32 / 0	-91.8	-91.8	0.07 (1)	6.25	I-F	0 / 23	0.01 (1)	
E-F	-11 / 0	-91.8	-91.8	0.07 (1)	6.25				
F-G	0 / 41	-91.8	-91.8	0.13 (1)	10.00				
H-F	-231 / 0	0.0	0.0	0.02 (1)	7.81				
L-K	0 / 0	-18.5	-18.5	0.02 (4)	10.00				
K-J	0 / 13	-18.5	-18.5	0.02 (4)	10.00				
J-I	0 / 13	-18.5	-18.5	0.02 (4)	10.00				
I-H	0 / 0	-18.5	-18.5	0.02 (4)	10.00				

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.5 PSF

DL = 6.0 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2010, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.13/1.00 (F-G:1), BC=0.02/1.00 (J-K:4), WB=0.05/1.00 (C-K:1), SSI=0.08/1.00 (F-G:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS= 1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 789 1987 1688

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.18 (C) (INPUT = 0.80)

JSI METAL= 0.13 (C) (INPUT = 1.00)



Structural component only
DWG# T-2007078

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408151	T33X	1	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington		TRUSS DESC.		Version 8.310 5 Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:19:59 2020 Page 1	



Scale = 1/32"

LUMBER

N. L. G. A. RULES			
CHORDS	SIZE		LUMBER
A - B	2x4	DRY	No.2
B - C	2x4	DRY	No.2
F - A	2x4	DRY	No.2
D - C	2x4	DRY	No.2
F - D	2x4	DRY	No.2
ALL WEBS	2x3	DRY	No.2
EXCEPT			

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW+p	MT20	4.0	4.0	1.00	2.00
B	TTW+p	MT20	4.0	6.0	Edge	
C	TMVW+p	MT20	4.0	4.0	1.00	2.00
D	BMVt+p	MT20	3.0	4.0		
E	BMVW+p	MT20	4.0	9.0		
F	BMVt+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	GROSS REACTION	MAXIMUM FACTORED	INPUT	REQD
JT	VERT	HORZ	DOWN	HORZ	UPLIFT
F	498	0	498	0	0
D	498	0	498	0	0

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
JT	COMBINED	SNOW	LIVE	PERM. LIVE	WIND
F	351	230 / 0	0 / 0	0 / 0	121 / 0
D	351	230 / 0	0 / 0	0 / 0	121 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F, D

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.
ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED	FACTORED	VERT. LOAD	LC1	MAX	MAX	MEMB.	MAX. FACTORED	FACTORED	VERT. LOAD	LC1	MAX	MAX
MEMB.	FORCE (LBS)	VERT. LOAD (PLF)	CSI (LC)	UNBRAC	LENGTH	FR-TO	MEMB.	FORCE (LBS)	VERT. LOAD (PLF)	CSI (LC)	UNBRAC	LENGTH	FR-TO
A-B	-311 / 0	-91.8	-91.8	0.24 (1)	6.25	E-B	-14 / 72	0.03 (4)					
B-C	-311 / 0	-91.8	-91.8	0.24 (1)	6.25	A-E	0 / 246	0.06 (1)					
F-A	-464 / 0	0.0	0.0	0.05 (1)	7.81	E-C	0 / 246	0.06 (1)					
D-C	-464 / 0	0.0	0.0	0.05 (1)	7.81								
F-E	0 / 0	-18.5	-18.5	0.11 (4)	10.00								
E-D	0 / 0	-18.5	-18.5	0.11 (4)	10.00								

TOTAL WEIGHT = 37 lb

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (0.30")
CALCULATED VERT. DEFL. (LL) = L/999 (0.00")
ALLOWABLE DEFL. (TL) = L/360 (0.30")
CALCULATED VERT. DEFL. (TL) = L/999 (0.01")

CSI: TC=0.24/1.00 (A-B:1), BC=0.11/1.00 (E-F:4), WB=0.06/1.00 (C-E:1), SS=0.12/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 L'S BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP (DRY)	SHEAR (PL)	SECTION (PL)
MT20	618	354	1667

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.42 (A) (INPUT = 0.50)
JSI METAL = 0.12 (A) (INPUT = 1.00)




Structural component only
DWG# T-2007095

Tamarack Roof Truss, Burlington


Version 8.310 S Oct 29 2019 MTEK Industries, Inc. Sat Apr 25 11:20:00 2020 Page 1
ID:h2dflgC44wS_E2tzqPs_atzllRw-mBc3uRx8GmODTrpiNRn5xkQXdrLiC2aUv0ER7azNCXT

Scale = 1-100



TOTAL WEIGHT = 2 X 41 = 82 lb

Structural component only
DWG# T-2007096



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
F - A	2x4	DRY No.2	SPF
A - C	2x4	DRY No.2	SPF
C - D	2x4	DRY No.2	SPF
D - F	2x4	DRY No.2	SPF

ALL WEBS 2x3 DRY No.2 SPF
DRY: SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN.)	LOAD (PLF)
TOP CHORDS: (0.122"x3") SPIRAL NAILS		
F - A	12	TOP
A - C	12	TOP
C - D	12	TOP
BOTTOM CHORDS: (0.122"x3") SPIRAL NAILS		
F - D	11	SIDE (97.1)
WEBS: (0.122"x3") SPIRAL NAILS		
B - E	6	SIDE (20.3)
2x3	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

SIDE - PLF SHOWN IS THE EQUIVALENT UDL APPLIED TO ONE SIDE THAT THE CORRESPONDING NAILING PATTERN SHALL BE CAPABLE OF TRANSFERRING. REMAINING PLF MUST BE APPLIED ON THE OPPOSITE SIDE OR ON THE TOP.

PLATES (tablets in inches)

JT TYPE	PLATES	W	LEN	Y	X
A	MT20	4.0	8.0		
B	MT20	2.0	4.0		
C	MT20	4.0	8.0		
D	MT20	3.0	4.0		
E	MT20	4.0	8.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED		MAXIMUM FACTORED		INPUT		REQD	
	GROSS REACTION	DOWN	GROSS REACTION	DOWN	BRG	IN-SX	BRG	IN-SX
JT	VERT	HORZ	VERT	HORZ	UP-LIFT	IN-SX	BRG	IN-SX
F	1016	0	1016	0	0	5-8	5-8	
D	1085	0	1085	0	0	MECHANICAL		

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT D. MINIMUM BEARING LENGTH AT JOINT D = 1-8.

UNFACTORED REACTIONS

JT	MAX/MIN. COMPONENT REACTIONS						
	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
F	726	438 / 0	0 / 0	0 / 0	0 / 0	280 / 0	0 / 0
D	772	478 / 0	0 / 0	0 / 0	0 / 0	283 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.23 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. LC1 MAX. CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. LC1 MAX. CSI (LC)	
FR-TO		FROM TO		FR-TO			
F-A	-965 / 0	0.0	0.0 0.05 (1)	7.81	A-E	0 / 1810	0.22 (1)
A-G	-1708 / 0	-91.8	-91.8 0.26 (1)	8.23	E-B	-482 / 0	0.04 (1)
G-B	-1708 / 0	-91.8	-91.8 0.26 (1)	8.23	E-C	0 / 1810	0.22 (1)
B-C	-1708 / 0	-91.8	-91.8 0.08 (1)	6.25			
D-C	-707 / 0	0.0	0.0 0.04 (1)	7.81			
F-E	0 / 0	-43.5	-43.5 0.05 (4)	10.00			
E-H	0 / 0	-43.5	-43.5 0.22 (1)	10.00			
H-D	0 / 0	-43.5	-43.5 0.22 (1)	10.00			

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
E	3-0-12	-450	-450		FRONT	VERT	TOTAL		C1
G	1-0-12	-404	-404		TOP	VERT	TOTAL		C1
H	5-0-12	-452	-452		FRONT	VERT	TOTAL		C1

CONNECTION REQUIREMENTS

(1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

DESIGN CRITERIA

*** SPECIAL LOADS ANALYSIS ***
GEOMETRY AND/OR BASIC LOADS CHANGED BY USER.
LOADS WERE DERIVED FROM USER INPUT
NO FURTHER MODIFICATIONS WERE MADE

SPECIAL LOADS:

TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

NON STANDARD GIRDER

ADDTL USER-DEFINED LOADS APPLIED TO ALL LOAD CASES.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 085-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (0.20")
CALCULATED VERT. DEFL. (LL) = L/999 (0.02")
ALLOWABLE DEFL. (TL) = L/360 (0.20")
CALCULATED VERT. DEFL. (TL) = L/999 (0.03")

CSI: TC=0.28/1.00 (A-B:1), BC=0.22/1.00 (D-E:1),
WB=0.22/1.00 (A-E:1), SSI=0.16/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT


NAIL VALUES

PLATE GRIP (DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 788 1987 1656

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP = 0.59 (C) (INPUT = 0.90)
JSI METAL = 0.21 (C) (INPUT = 1.00)




Structural component only
DWG# T-2007097 1/2

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408151	T35	2	2	TRUSS DESC.		


Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitak Industries, Inc. Sat Apr 25 11:20:01 2020 Page 2
ID:h2df1gC44wS E2tzaPs atz1IRw-EO9R5nym13W44?Ovw8IKTxzhdFi xTUd8gz f1zNCKS

PLATES (table is in inches)
JT TYPE PLATES W LEN Y X
F BMV1+P MT20 3.0 4.0



Structural component only
DWG# T-2007097 42



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER
P - B	2x4	DRY No.2
A - E	2x4	DRY No.2
E - I	2x4	DRY No.2
J - H	2x4	DRY No.2
P - J	2x4	DRY No.2

ALL WEBS 2x3 DRY No.2

ALL GABLE WEBS 2x3 DRY No.2

DRY: SEASONED LUMBER.

GABLE STUDS SPACED AT 2'-0" O.C.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	4.0	4.0	1.00	2.00
C, D, F, G						
C	TMVW+w	MT20	2.0	4.0		
E	TTW+p	MT20	4.0	6.0	Edge	
H	TMVW+p	MT20	4.0	4.0	1.00	2.00
J	BMV1+p	MT20	3.0	4.0		
K	BMVW1+1	MT20	4.0	4.0		
L, M, N						
L	BMV1+w	MT20	2.0	4.0		
O	BMVW1+1	MT20	4.0	4.0		
P	BMV1+p	MT20	3.0	4.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

THIS TRUSS DESIGNED FOR CONTINUOUS BEARINGS.

THIS TRUSS REQUIRES RIGID SHEATHING ON EXPOSED FACE.

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S).

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CSI (LC)	
FR-TO		FROM TO		FR-TO			
P-B	-274 / 0	0.0	0.03 (1)	N-E	-139 / 0	0.08 (1)	
A-B	0 / 41	-91.8	-91.8 0.13 (1)	N-D	-223 / 0	0.07 (1)	
B-C	-57 / 0	-91.8	-91.8 0.12 (1)	O-C	-75 / 0	0.01 (1)	
C-D	-4 / 0	-91.8	-91.8 0.08 (1)	L-F	-223 / 0	0.07 (1)	
D-E	-22 / 0	-91.8	-91.8 0.08 (1)	K-G	-75 / 0	0.01 (1)	
E-F	-22 / 0	-91.8	-91.8 0.08 (1)	B-O	0 / 20	0.00 (1)	
F-G	-4 / 0	-91.8	-91.8 0.08 (1)	K-H	0 / 20	0.00 (1)	
G-H	-57 / 0	-91.8	-91.8 0.12 (1)				
H-I	0 / 41	-91.8	-91.8 0.13 (1)				
J-H	-274 / 0	0.0	0.03 (1)				
P-O	0 / 0	-18.5	-18.5 0.01 (4)				
O-N	0 / 12	-18.5	-18.5 0.02 (4)				
N-M	0 / 7	-18.5	-18.5 0.02 (4)				
M-L	0 / 7	-18.5	-18.5 0.02 (4)				
L-K	0 / 12	-18.5	-18.5 0.02 (4)				
K-J	0 / 0	-18.5	-18.5 0.01 (4)				

TOTAL WEIGHT = 53 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	DL
LL	25.6	PSF
DL	6.0	PSF
BOT CH.	LL	DL
LL	0.0	PSF
DL	7.4	PSF
TOTAL LOAD	38.0	PSF

SPACING = 24.0 IN. O.C.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

-OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.13/1.00 (H-I:1), BC=0.02/1.00 (K-L:4), WB=0.08/1.00 (E-M:1), SSI=0.08/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES


PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1887 788 1987 1858

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.21 (B) (INPUT = 0.90)

JSI METAL= 0.12 (F) (INPUT = 1.00)



Structural component only
DWG# T-2007079



LUMBER	N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
A - C	2x4 DRY No.2	SPF			
C - F	2x6 DRY No.2	SPF			
F - H	2x6 DRY No.2	SPF			
H - J	2x4 DRY No.2	SPF			
J - B	2x6 DRY No.2	SPF			
K - I	2x6 DRY No.2	SPF			
T - Q	2x8 DRY No.2	SPF			
Q - N	2x6 DRY No.2	SPF			
N - K	2x6 DRY No.2	SPF			

ALL WEBS 2x3 DRY No.2
EXCEPT

DRY: SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN)	LOAD (PLF)
TOP CHORDS: (0.122'X3") SPIRAL NAILS		
A-C	12	SIDE(81.0)
H-J	12	SIDE(61.0)
C-F	12	SIDE(81.0)
F-H	12	SIDE(81.0)
T-B	12	TOP
K-I	12	TOP
Q-N	12	SIDE(183.1)
N-K	12	SIDE(183.1)
BOTTOM CHORDS: (0.122'X3") SPIRAL NAILS		
T-Q	12	SIDE(183.1)
Q-N	12	SIDE(183.1)
N-K	12	SIDE(183.1)
WEBS: (0.122'X3") SPIRAL NAILS		
2x3	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
GROSS REACTION	GROSS REACTION	GROSS REACTION	BRG	BRG
JT VERT	3331	0	0	5-8
T	3331	0	0	5-8
K	3331	0	0	5-8

UNFACTORED REACTIONS	1ST LCASE	MAX/MIN COMPONENT REACTIONS
JT	COMBINED	SNOW LIVE PERM LIVE WIND DEAD SOIL
T	2358	1544 / 0 0 / 0 0 / 0 812 / 0 0 / 0
K	2358	1544 / 0 0 / 0 0 / 0 812 / 0 0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) T, K

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.87 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING
TOTAL LOAD CASES: (4)

CHORDS	MEMB.	FORCE (LBS)	FACTORED	VERT. LOAD LC1	MAX	MAX. UNBRAC	WEBS	MEMB.	FORCE (LBS)	MAX. FACTORED	MAX. CSI (LC)
FR-TO			FROM TO				FR-TO				
A-B	0 / 28	-91.8	-91.8	0.07 (1)	10.00		S-C	-427 / 8	0.05 (1)		
B-C	-5077 / 0	-91.8	-91.8	0.52 (1)	3.87		C-R	0 / 3083	0.38 (1)		
C-U	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33		R-D	-1565 / 0	0.19 (1)		
U-V	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33		G-G	0 / 1071	0.13 (1)		
V-D	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33		M-G	-1565 / 0	0.19 (1)		
D-W	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		L-H	-427 / 8	0.05 (1)		
W-X	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		B-S	0 / 4592	0.57 (1)		
X-Y	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		L-I	0 / 4592	0.57 (1)		
Y-E	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		D-P	0 / 1071	0.13 (1)		
E-Z	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		M-H	0 / 3083	0.38 (1)		
Z-F	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		P-E	-505 / 0	0.06 (1)		
F-AA	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10		E-O	-505 / 0	0.06 (1)		
AA-AB	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10						
AB-G	-7894 / 0	-91.8	-91.8	0.27 (1)	4.10						
G-AC	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33						
AC-AD	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33						
AD-H	-7106 / 0	-91.8	-91.8	0.23 (1)	4.33						
H-I	-5077 / 0	-91.8	-91.8	0.52 (1)	3.87						
I-J	0 / 28	-91.8	-91.8	0.07 (1)	10.00						
T-B	-3255 / 0	0.0	0.0	0.11 (1)	7.69						
K-I	-3255 / 0	0.0	0.0	0.11 (1)	7.69						

T-AE	0 / 0	-18.5	-18.5	0.08 (4)	10.00
AE-AF	0 / 0	-18.5	-18.5	0.06 (4)	10.00
AF-S	0 / 0	-18.5	-18.5	0.06 (4)	10.00
S-AG	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
AG-AH	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
AH-R	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
R-Q	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
Q-AI	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
AI-AJ	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
AJ-P	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
P-AK	0 / 8119	-18.5	-18.5	0.56 (1)	10.00
AK-O	0 / 8119	-18.5	-18.5	0.56 (1)	10.00
O-AL	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
AL-AM	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
AM-N	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
N-M	0 / 7105	-18.5	-18.5	0.52 (1)	10.00
M-AN	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
AN-AO	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
AO-L	0 / 4563	-18.5	-18.5	0.34 (1)	10.00
L-AP	0 / 0	-18.5	-18.5	0.06 (4)	10.00
AP-AQ	0 / 0	-18.5	-18.5	0.06 (4)	10.00

TOTAL WEIGHT = 2 X 170 = 341 lb

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 8.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF NBCC 2010, NBC 2012, ABC 2019
- PART 9 OF NBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (1.17")
CALCULATED VERT. DEFL. (LL) = L/999 (0.21")
ALLOWABLE DEFL. (TL) = L/360 (1.17")
CALCULATED VERT. DEFL. (TL) = L/999 (0.39")

CSI: TC=0.52/1.00 (H=1), BC=0.58/1.00 (D=P=1), WB=0.57/1.00 (B=S-1), SSI=0.16/1.00 (D=E=1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00 COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF


TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 616 364 1667 788 1987 1656

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP= 0.84 (S) (INPUT = 0.90)
JSI METAL= 0.54 (N) (INPUT = 1.00)



Structural component only
DWG# T-2007107 1/2

JOB NAME:	TRUSS NAME:	QUANTITY:	PLY:	JOB DESC:	GREEN PARK HOMES	DRWG NO.:
408152	T40	1	2	TRUSS DESC.:		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:29:32 2020 Page 2
ID:7vF?aG0E03cRUj6X1Srkz1WYK-0EA1x1sxZWS34YelZ2E6M6CTQSHDeTgR0n1CQzNC0X

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW-1	MT20	5.0	8.0		
C	TTWW+m	MT20	5.0	8.0	Edge	
D, E, G						
D	TMVW-1	MT20	5.0	6.0		
F	TS-1	MT20	5.0	6.0		
H	TTWW+m	MT20	5.0	8.0	Edge	
I	TMVW-1	MT20	5.0	8.0		
K	BMV1+p	MT20	3.0	6.0		
L	BMVW-1	MT20	5.0	6.0	2.50	2.50
M, O, P, R						
M	BMVW-1	MT20	5.0	6.0		
N	BS-1	MT20	5.0	6.0		
Q	BS-1	MT20	5.0	6.0		
S	BMVW-1	MT20	5.0	6.0	2.50	2.50
T	BMV1+p	MT20	3.0	6.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

LOADING

TOTAL LOAD CASES: (4)


CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX. CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. UNBRAC. LENGTH FR-TO	MAX. FACTORED FORCE (LBS) CSI (LC)
FR-TO		FROM TO					
AQ-K	0.0	-18.5	-18.5 0.06 (4)			10.00	

FACTORED CONCENTRATED LOADS (LBS)


JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
C	5-10-8	-438	-438	---	FRONT	VERT	TOTAL	---	C1
E	17-7-0	-110	-110	---	FRONT	VERT	TOTAL	---	C1
H	29-3-8	-438	-438	---	FRONT	VERT	TOTAL	---	C1
L	29-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
N	23-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
Q	11-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
S	5-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
U	7-11-4	-110	-110	---	FRONT	VERT	TOTAL	---	C1
V	9-11-4	-110	-110	---	FRONT	VERT	TOTAL	---	C1
W	11-11-4	-110	-110	---	FRONT	VERT	TOTAL	---	C1
X	13-11-4	-110	-110	---	FRONT	VERT	TOTAL	---	C1
Y	15-11-4	-110	-110	---	FRONT	VERT	TOTAL	---	C1
Z	19-2-12	-110	-110	---	FRONT	VERT	TOTAL	---	C1
AA	21-2-12	-110	-110	---	FRONT	VERT	TOTAL	---	C1
AB	23-2-12	-110	-110	---	FRONT	VERT	TOTAL	---	C1
AC	25-2-12	-110	-110	---	FRONT	VERT	TOTAL	---	C1
AD	27-2-12	-110	-110	---	FRONT	VERT	TOTAL	---	C1
AE	1-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AF	3-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AG	7-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AH	9-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AI	13-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AJ	15-11-4	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AK	17-7-0	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AL	19-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AM	21-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AN	25-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AO	27-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AP	31-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1
AQ	33-2-12	-26	-26	---	FRONT	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS

- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.



Structural component only
DWG# T-2007107 7/2



LUMBER					
N. L. G. A. RULES					
CHORDS		SIZE	LUMBER		DESCR
A - C	2x4	DRY	No.2	SPF	
C - F	2x6	DRY	No.2	SPF	
F - H	2x6	DRY	No.2	SPF	
H - J	2x4	DRY	No.2	SPF	
T - B	2x6	DRY	No.2	SPF	
K - I	2x6	DRY	No.2	SPF	
T - Q	2x6	DRY	No.2	SPF	
Q - N	2x6	DRY	No.2	SPF	
N - K	2x6	DRY	No.2	SPF	

ALL WEBS 2x3 DRY No.2
EXCEPT

DRY: SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS SURFACE SPACING (IN) LOAD(PLF)

CHORDS	#ROWS	SURFACE SPACING (IN)	LOAD(PLF)
TOP CHORDS: (0.122"x3") SPIRAL NAILS			
A-C	1	12	SIDE(61.0)
H-J	1	12	TOP
C-F	2	12	SIDE(61.0)
F-H	2	12	TOP
T-B	2	12	TOP
K-I	2	12	TOP
BOTTOM CHORDS: (0.122"x3") SPIRAL NAILS			
T-Q	2	12	SIDE(183.1)
Q-N	2	12	SIDE(0.0)
N-K	2	12	TOP
WEBS: (0.122"x3") SPIRAL NAILS			
2x3	1	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT VERT	4474	0	5-8
T HORZ	0	0	5-8
K VERT	3775	0	5-8
K HORZ	0	0	5-8

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN COMPONENT REACTIONS
JT COMBINED	3182
T SNOW	2088 / 0
K LIVE	2665
K PERM LIVE	1772 / 0
T WIND	0 / 0
K WIND	0 / 0
T DEAD	1073 / 0
K DEAD	893 / 0
T SOIL	0 / 0
K SOIL	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) T, K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.13 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (LBS)	MAX. FACTORED CSI (LC)	MAX. FACTORED UNBRACED LENGTH (FT)	WEBS	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CSI (LC)
FR-TO	A-B	0 / 28	-91.8	-91.8	0.07 (1)	10.00	S-C	-384 / 25	0.05 (1)
FR-TO	B-C	-7183 / 0	-91.8	-91.8	0.71 (1)	3.19	C-R	0 / 4897	0.58 (1)
FR-TO	C-U	-10299 / 0	-91.8	-91.8	0.32 (1)	3.62	R-D	-2057 / 0	0.25 (1)
FR-TO	U-V	-10299 / 0	-91.8	-91.8	0.32 (1)	3.62	G-G	0 / 3811	0.45 (1)
FR-TO	V-D	-10299 / 0	-91.8	-91.8	0.32 (1)	3.62	M-G	-2637 / 0	0.32 (1)
FR-TO	D-W	-12012 / 0	-91.8	-91.8	0.45 (1)	3.27	L-H	-616 / 0	0.08 (1)
FR-TO	W-X	-12012 / 0	-91.8	-91.8	0.45 (1)	3.27	B-S	0 / 6479	0.80 (1)
FR-TO	X-Y	-12012 / 0	-91.8	-91.8	0.45 (1)	3.27	L-I	0 / 5333	0.68 (1)
FR-TO	Y-E	-12012 / 0	-91.8	-91.8	0.45 (1)	3.27	D-P	0 / 2066	0.25 (1)
FR-TO	E-F	-12381 / 0	-91.8	-91.8	0.40 (1)	3.28	M-H	0 / 4950	0.61 (1)
FR-TO	F-G	-12381 / 0	-91.8	-91.8	0.40 (1)	3.28	P-E	-1110 / 0	0.14 (1)
FR-TO	G-H	-9386 / 0	-91.8	-91.8	0.25 (1)	3.84	E-O	0 / 383	0.05 (1)
FR-TO	H-I	-5895 / 0	-91.8	-91.8	0.39 (1)	3.58			
FR-TO	I-J	0 / 28	-91.8	-91.8	0.07 (1)	10.00			
FR-TO	T-B	-4430 / 0	0.0	0.0	0.16 (1)	5.62			
FR-TO	K-I	-3715 / 0	0.0	0.0	0.13 (1)	7.31			
FR-TO	T-Z	0 / 0	-18.5	-18.5	0.08 (4)	10.00			
FR-TO	Z-AA	0 / 0	-18.5	-18.5	0.08 (4)	10.00			
FR-TO	AA-S	0 / 0	-18.5	-18.5	0.08 (4)	10.00			
FR-TO	S-AB	0 / 6432	-18.5	-18.5	0.69 (1)	10.00			
FR-TO	AB-AC	0 / 6432	-18.5	-18.5	0.69 (1)	10.00			
FR-TO	AC-AD	0 / 6432	-18.5	-18.5	0.69 (1)	10.00			
FR-TO	AD-AR	0 / 6432	-18.5	-18.5	0.69 (1)	10.00			
FR-TO	R-Q	0 / 10298	-18.5	-18.5	0.78 (1)	10.00			
FR-TO	Q-AE	0 / 10298	-18.5	-18.5	0.78 (1)	10.00			
FR-TO	AE-AF	0 / 10298	-18.5	-18.5	0.76 (1)	10.00			
FR-TO	AF-P	0 / 10298	-18.5	-18.5	0.76 (1)	10.00			
FR-TO	P-O	0 / 12286	-18.5	-18.5	0.91 (1)	10.00			
FR-TO	O-N	0 / 9385	-18.5	-18.5	0.72 (1)	10.00			
FR-TO	N-M	0 / 9385	-18.5	-18.5	0.72 (1)	10.00			
FR-TO	M-L	0 / 5303	-18.5	-18.5	0.37 (1)	10.00			
FR-TO	L-K	0 / 0	-18.5	-18.5	0.04 (4)	10.00			

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX.	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
C	5-10-8	-438	-438	---	BACK	VERT	TOTAL	---	C1
O	18-5-8	-2436	-2436	---	BACK	VERT	TOTAL	---	C1
P	16-9-12	-17	-17	---	BACK	VERT	TOTAL	---	C1
S	5-11-4	-26	-26	---	BACK	VERT	TOTAL	---	C1
U	7-11-4	-110	-110	---	BACK	VERT	TOTAL	---	C1
V	10-9-12	-82	-82	---	BACK	VERT	TOTAL	---	C1
W	12-9-12	-82	-82	---	BACK	VERT	TOTAL	---	C1

TOTAL WEIGHT = 2 X 170 = 341 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF
DL = 5.0 PSF

BOT CH. LL = 0.0 PSF
DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBCC 2010, NBC 2012, ABC 2019
- PART 9 OF NBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.31")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/740 (0.57")

CSI: TC=0.71/1.00 (B-C:1), BC=0.91/1.00 (C-P:1), WB=0.80/1.00 (B-S:1), SS=0.15/1.00 (R-S:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)


MAX MIN MAX MIN MAX MIN

MT20 618 354 1657 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (S) (INPUT= 0.90)
JSI METAL= 0.93 (N) (INPUT= 1.00)



Structural component only
DWG# T-2007108

JOB NAME 408152	TRUSS NAME T40Z	QUANTITY 1	PLY 2	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington		TRUSS DESC.			

Version 8.310 5 Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:29:34 2020 Page 2
ID:7vF?aG0E03cRUibX1iSrKzWYK-ydH2MiuB57imK3i1? 4iCnCV?E2GhUJzvKGnGJzNCOV

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW-p	MT20	5.0	8.0	2.00	3.50
C	TTWW+m	MT20	6.0	9.0	Edge	
D, E, G						
D	TMVW-i	MT20	5.0	6.0		
F	TS-i	MT20	5.0	6.0		
H	TTWW+m	MT20	6.0	9.0	Edge	
I	TMVW-p	MT20	5.0	8.0	2.00	3.50
K	BMV1+p	MT20	3.0	6.0		
L	BMWW-i	MT20	5.0	8.0	2.50	3.50
M	BMWW-i	MT20	5.0	6.0	2.50	2.00
N	BS-i	MT20	5.0	6.0		
O	BMWW-i	MT20	5.0	6.0	2.75	2.75
P	BMWW-i	MT20	5.0	6.0	2.75	2.75
Q	BS-i	MT20	5.0	6.0		
R	BMWW-i	MT20	5.0	6.0	2.50	2.00
S	BMWW-i	MT20	5.0	8.0	2.50	3.50
T	BMV1+p	MT20	3.0	6.0		


Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
X	14-9-12	-82	-82	---	BACK	VERT	TOTAL	---	C1
Y	16-9-12	-82	-82	---	BACK	VERT	TOTAL	---	C1
Z	1-11-4	-25	-26	---	BACK	VERT	TOTAL	---	C1
AA	3-11-4	-26	-26	---	BACK	VERT	TOTAL	---	C1
AB	7-11-4	-26	-26	---	BACK	VERT	TOTAL	---	C1
AC	8-10-8	-639	-639	---	BACK	VERT	TOTAL	---	C1
AD	10-9-12	-17	-17	---	BACK	VERT	TOTAL	---	C1
AE	12-9-12	-17	-17	---	BACK	VERT	TOTAL	---	C1
AF	14-9-12	-17	-17	---	BACK	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS


- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.



Structural component only
DWG# T-2007108

JOB NAME 408152	TRUSS NAME T41	QUANTITY 2	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRAUSS DESC.	

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:35 2020 Page 1
 ID:7vF7aG0E03CRUJ6X1jSkzjWYK-QprQa2vprRqdxDHDYhbxk_kd2eSiQx967_0NplzNCOU
 Scale = 1:57.3



LUMBER			
N. L. G. A. RULES			
CHORDS	SIZE	LUMBER	
A - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
F - H	2x4	DRY	No.2
H - K	2x4	DRY	No.2
S - B	2x4	DRY	No.2
L - J	2x4	DRY	No.2
S - Q	2x4	DRY	No.2
Q - N	2x4	DRY	No.2
N - L	2x4	DRY	No.2
ALL WEBS 2x3 DRY No.2			
EXCEPT			
S - C	2x4	DRY	No.2
I - L	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)					
JT	TYPE	PLATES	W	LEN	Y X
B	TMV-p	MT20	3.0	4.0	
C	TMVW-t	MT20	5.0	8.0	2.50 2.75
D	TTWW-m	MT20	5.0	8.0	2.25 2.75
E	TMVW-t	MT20	4.0	4.0	
F	TS-t	MT20	3.0	6.0	
G	TMVW-w	MT20	2.0	4.0	
H	TTWW-m	MT20	5.0	8.0	2.25 2.75
I	TMVW-t	MT20	5.0	8.0	2.50 2.75
J	TMV-p	MT20	3.0	4.0	
L	BMVW1-t	MT20	4.0	9.0	Edge
M	BMVW1-t	MT20	4.0	4.0	
N	BS-t	MT20	3.0	6.0	
O	BMVW1-t	MT20	4.0	9.0	
P	BMVW1-t	MT20	4.0	6.0	
Q	BS-t	MT20	3.0	6.0	
R	BMVW1-t	MT20	4.0	4.0	
S	BMVW1-t	MT20	4.0	9.0	Edge

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQD BRG	
JT	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	IN-SX	IN-SX
S	2063	0	2063	0	0	5-8	5-8	5-8	5-8
L	2063	0	2063	0	0	5-8	5-8	5-8	5-8

UNFACTORED REACTIONS

1ST CASE		MAX/MIN. COMPONENT REACTIONS		LIVE		PERM. LIVE		WIND		DEAD		SOIL	
JT	COMBINED	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW	SNOW
S	1457	969 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0	0 / 0	0 / 0
L	1457	969 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0	0 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLINE SPACING = 2.94 FT.
 MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (LBS)	MAX. FACTORED CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CSI (LC)	
FR-TO				FR-TO			
A-B	0 / 28	-91.8	-91.8 0.12 (1)	10.00	C-R	0 / 93	0.03 (4)
B-C	0 / 16	-91.8	-91.8 0.20 (1)	10.00	R-D	0 / 121	0.04 (4)
C-D	-2799 / 0	-91.8	-91.8 0.32 (1)	3.88	D-P	0 / 1267	0.29 (1)
D-E	-3508 / 0	-91.8	-91.8 0.95 (1)	2.94	P-E	-643 / 0	0.25 (1)
E-F	-3507 / 0	-91.8	-91.8 0.93 (1)	2.94	E-O	-2 / 0	0.00 (1)
F-G	-3507 / 0	-91.8	-91.8 0.93 (1)	2.94	O-G	-643 / 0	0.25 (1)
G-H	-3507 / 0	-91.8	-91.8 0.94 (1)	2.94	G-H	0 / 1266	0.28 (1)
H-I	-2799 / 0	-91.8	-91.8 0.32 (1)	3.88	M-H	0 / 121	0.04 (4)
I-J	0 / 18	-91.8	-91.8 0.20 (1)	10.00	M-I	0 / 93	0.03 (4)
J-K	0 / 28	-91.8	-91.8 0.12 (1)	10.00	S-C	-2974 / 0	0.83 (1)
S-B	-270 / 0	0.0	0.0 0.03 (1)	7.81	I-L	-2974 / 0	0.83 (1)
L-J	-270 / 0	0.0	0.0 0.03 (1)	7.81			
S-R	0 / 2417	-18.5	-18.5 0.53 (1)	10.00			
R-Q	0 / 2489	-18.5	-18.5 0.54 (1)	10.00			
Q-P	0 / 2489	-18.5	-18.5 0.54 (1)	10.00			
P-O	0 / 3508	-18.5	-18.5 0.94 (1)	10.00			
O-N	0 / 2489	-18.5	-18.5 0.54 (1)	10.00			
N-M	0 / 2489	-18.5	-18.5 0.54 (1)	10.00			
M-L	0 / 2417	-18.5	-18.5 0.53 (1)	10.00			

TOTAL WEIGHT = 2 X 139 = 278 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	6.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (1.17")
 CALCULATED VERT. DEFL. (LL) = $L/999$ (0.21")
 ALLOWABLE DEFL. (TL) = $L/360$ (1.17")
 CALCULATED VERT. DEFL. (TL) = $L/999$ (0.41")

CSI: TC=0.95/1.00 (D-E-1), BC=0.64/1.00 (O-P-1),
 WB=0.83/1.00 (I-L-1), SS=0.28/1.00 (D-E-1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY) SHEAR	SECTION
(PSI)	(PL)
MAX MIN MAX MIN MAX MIN	
MT20	618 354 1667 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (L) (INPUT = 0.90)
 JSI METAL= 0.77 (N) (INPUT = 1.00)



Structural component only
 DWG# T-2007109

JOB NAME 408152	TRUSS NAME T42	QUANTITY 2	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:36 2020 Page 1	
ID:7vF7aG0E03cRUj6X1jSkzWYK-u?PpnOvRckyUZNSP6PAHCHhN1r19RDGMelwLCzNCOT				Scale = 1:57.3	



LUMBER			
N. L. G. A. RULES	CHORDS	SIZE	LUMBER
A - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
F - I	2x4	DRY	No.2
I - R	2x4	DRY	No.2
R - O	2x4	DRY	No.2
O - M	2x4	DRY	No.2
M - J	2x4	DRY	No.2
ALL WEBS EXCEPT	2x3	DRY	No.2

PLATES (table is in inches)				
JT	TYPE	PLATES	W	LEN Y X
B	TMWW-p	MT20	5.0	8.0 Edge 3.50
C	TMWW-l	MT20	4.0	4.0 2.00 1.75
D	TTWW-m	MT20	5.0	8.0 2.25 3.75
E	TMWW-w	MT20	2.0	4.0
F	TTWW-m	MT20	5.0	8.0 2.25 3.75
G	TMWW-l	MT20	4.0	4.0 2.00 1.75
H	TMWW-p	MT20	5.0	8.0 Edge 3.50
J	BMV1-p	MT20	3.0	4.0
K	BMWW-l	MT20	5.0	6.0 2.50 2.00
L	BMWW-l	MT20	4.0	4.0
M	BS-l	MT20	3.0	6.0
N	BMWWW-l	MT20	4.0	3.0
O	BS-l	MT20	3.0	8.0
P	BMWW-l	MT20	4.0	4.0
Q	BMWW-l	MT20	5.0	6.0 2.50 2.00
R	BMV1-p	MT20	3.0	4.0

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	HORZ	DOWN	HORZ	UPLIFT
R	2063	0	2063	0	0
J	2063	0	2063	0	0

UNFACTORED REACTIONS		1ST CASE	MAX/MIN. COMPONENT REACTIONS
JT	COMBINED	SNOW	LIVE
R	1457	969 / 0	0 / 0
J	1457	969 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) R, J

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 2.78 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING
TOTAL LOAD CASES: (4)

CHORDS		MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC1)	MAX. FACTORED VERT. LOAD (LC2)	MAX. FACTORED VERT. LOAD (LC3)	MAX. FACTORED VERT. LOAD (LC4)	MAX. FACTORED VERT. LOAD (LC5)	MAX. FACTORED VERT. LOAD (LC6)	MAX. FACTORED VERT. LOAD (LC7)	MAX. FACTORED VERT. LOAD (LC8)	MAX. FACTORED VERT. LOAD (LC9)	MAX. FACTORED VERT. LOAD (LC10)
MEMB.	FR-TO	FROM	TO	FROM	TO	FROM	TO	FROM	TO	FROM	TO	FROM	TO
A-B	0 / 28	-91.8	-91.8	0.12 (1)	10.00	0	0	0	0	0	0	0	0
B-C	-2834 / 0	-91.8	-91.8	0.39 (1)	3.81	0	0	0	0	0	0	0	0
C-D	-2687 / 0	-91.8	-91.8	0.37 (1)	3.91	0	0	0	0	0	0	0	0
D-E	-3080 / 0	-91.8	-91.8	0.97 (1)	2.78	0	0	0	0	0	0	0	0
E-F	-2887 / 0	-91.8	-91.8	0.37 (1)	3.91	0	0	0	0	0	0	0	0
F-G	-2834 / 0	-91.8	-91.8	0.39 (1)	3.81	0	0	0	0	0	0	0	0
G-H	-2018 / 0	-91.8	-91.8	0.12 (1)	10.00	0	0	0	0	0	0	0	0
H-I	0 / 28	0.0	0.0	0.20 (1)	5.94	0	0	0	0	0	0	0	0
I-J	-2018 / 0	0.0	0.0	0.20 (1)	5.94	0	0	0	0	0	0	0	0
J-K	0 / 0	-18.5	-18.5	0.10 (4)	10.00	0	0	0	0	0	0	0	0
K-L	0 / 2555	-18.5	-18.5	0.51 (1)	10.00	0	0	0	0	0	0	0	0
L-M	0 / 2386	-18.5	-18.5	0.49 (1)	10.00	0	0	0	0	0	0	0	0
M-N	0 / 2386	-18.5	-18.5	0.49 (1)	10.00	0	0	0	0	0	0	0	0
N-O	0 / 2386	-18.5	-18.5	0.49 (1)	10.00	0	0	0	0	0	0	0	0
O-P	0 / 2386	-18.5	-18.5	0.49 (1)	10.00	0	0	0	0	0	0	0	0
P-Q	0 / 2555	-18.5	-18.5	0.51 (1)	10.00	0	0	0	0	0	0	0	0
Q-R	0 / 0	-18.5	-18.5	0.10 (4)	10.00	0	0	0	0	0	0	0	0

TOTAL WEIGHT = 2 X 139 = 277 lb

DESIGN CRITERIA	
SPECIFIED LOADS:	
TOP CH. LL	= 25.6 PSF
DL	= 6.0 PSF
BOT CH. LL	= 0.0 PSF
DL	= 7.4 PSF
TOTAL LOAD	= 39.0 PSF
SPACING	= 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 085-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/999 (0.17")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/999 (0.34")

CS: TC=0.97/1.00 (D-E:1), BC=0.51/1.00 (K-L:1), WB=0.50/1.00 (H-K:1), SS=0.34/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00


TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES	
PLATE GRIP (DRY)	SHEAR SECTION
(PSI)	(PLI)
MAX MIN MAX MIN MAX MIN	
MT20	618 354 1667 798 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.87 (D) (INPUT = 0.90)
JSI METAL = 0.75 (O) (INPUT = 1.00)



Structural component only
DWG# T-2007110

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408152	T43	2	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington					
Version 8.310 S Oct 29 2019 MTEK Industries, Inc. Sat Apr 25 11:29:37 2020 Page 1					
ID:7vF7aG0E03cRU6X1jSrkzWYK-MCzB_kw3N24LBWQog6dPpPq2FRBxuiKPbiVTiezNCOS					
35-2.0 38 3-8 1.3-8 1.3-8					
Scale = 1:57.3					



LUMBER		DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER				TOTAL WEIGHT = 2 X 145 = 289 lb	
N. L. G. A. RULES		BEARINGS				(M/F)	
CHORDS	SIZE	LUMBER	DESCR.	FACTORED	MAXIMUM FACTORED	INPUT	REQD

A - D	2x4	DRY	No.2	SPF	FACTORED	MAXIMUM FACTORED	INPUT	REQD
D - F	2x4	DRY	No.2	SPF	GROSS REACTION	GROSS REACTION	BRG	BRG
F - J	2x4	DRY	No.2	SPF	JT VERT	HORZ	DOWN	HORZ
R - B	2x4	DRY	No.2	SPF	R	2063	0	0
J - H	2x4	DRY	No.2	SPF	J	2063	0	0
R - O	2x4	DRY	No.2	SPF				
O - M	2x4	DRY	No.2	SPF				
M - J	2x4	DRY	No.2	SPF				
ALL WEBS	2x3	DRY	No.2	SPF	UNFACTORED REACTIONS			
EXCEPT					1ST LCASE	MAX MIN	COMPONENT REACTIONS	
					JT COMBINED	SNOW	LIVE	PERM. LIVE
					R	1457	989 / 0	0 / 0
					J	1457	989 / 0	0 / 0

DRY; SEASONED LUMBER.

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) R, J

BRACING

TOP CHORD TO BE SHEATHED OR MAX. FURLIN SPACING = 3.58 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

PLATES (tablets in inches)		CHORDS				WEBS			
JT TYPE	PLATES	W	LEN	Y	X	MEMB.	FORCE	MAX	FACTORED
B TMVW-p	MT20	5.0	8.0	Edge	3.50	FR-TO	FROM	TO	LENGTH
C TMVW-t	MT20	4.0	4.0	2.00	1.75	A-B	0 / 28	-91.8	0.12 (1)
D TTWV-m	MT20	5.0	8.0	2.25	2.00	B-C	-2889 / 0	-91.8	0.58 (1)
E TMVW-w	MT20	2.0	4.0			C-D	-2539 / 0	-91.8	0.52 (1)
F TTWV-m	MT20	5.0	8.0	2.25	2.00	D-E	-2539 / 0	-91.8	0.48 (1)
G TMVW-t	MT20	4.0	4.0	2.00	1.75	E-F	-2539 / 0	-91.8	0.48 (1)
H TMVW-p	MT20	5.0	8.0	Edge	3.50	F-G	-2539 / 0	-91.8	0.52 (1)
J BMV1-p	MT20	3.0	4.0			G-H	-2889 / 0	-91.8	0.58 (1)
K BMVW-t	MT20	5.0	8.0	2.50	2.25	H-I	0 / 28	-91.8	0.12 (1)
L BMVW-t	MT20	4.0	4.0			I-J	-2014 / 0	0.0	0.20 (1)
M BS-t	MT20	3.0	6.0			J-H	-2014 / 0	0.0	0.20 (1)
N BMVW-w	MT20	4.0	4.0			R-Q	0 / 0	-18.5	0.15 (4)
O BS-t	MT20	3.0	6.0			Q-P	0 / 2609	-18.5	0.49 (1)
P BMVW-t	MT20	4.0	4.0			P-O	0 / 2249	-18.5	0.43 (1)
Q BMVW-t	MT20	5.0	8.0	2.50	2.25	O-N	0 / 2249	-18.5	0.43 (1)
R BMV1-p	MT20	3.0	4.0			N-M	0 / 2249	-18.5	0.43 (1)
						M-L	0 / 2249	-18.5	0.43 (1)
						L-K	0 / 2609	-18.5	0.49 (1)
						K-J	0 / 0	-18.5	0.15 (4)

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

ALLOWABLE DEFL (LL) = L/360 (1.17")

CALCULATED VERT. DEFL (LL) = L/999 (0.15")

ALLOWABLE DEFL (TL) = L/360 (1.17")

CALCULATED VERT. DEFL (TL) = L/999 (0.28")

CSI: TC=0.58/1.00 (G-H:1), BC=0.48/1.00 (K-L:1), WB=0.59/1.00 (B-Q:1), SSI=0.25/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP (DRY) SHEAR SECTION

(PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 618 354 1667 768 1987 1665

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP = 0.89 (C) (INPUT = 0.90)

JSI METAL = 0.69 (M) (INPUT = 1.00)




Structural component only
DWG# T-2007111

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408152	T44	2	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 3.310 5 Oct 28 2019 MITek Industries, Inc. Sat Apr 25 11:29:38 2020 Page 1
ID:7vF7aG0E03cRUj6X1jSkz1WYK-rOXZC4xi8MCCog7oEq9eMdMA6rWedKWYqyF1P4zNCOR
Scale = 1/8" = 1'-0"



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY	No.2	SPF
D - E	2x4	DRY	No.2	SPF
E - G	2x4	DRY	No.2	SPF
G - H	2x4	DRY	No.2	SPF
H - K	2x4	DRY	No.2	SPF
K - S	2x4	DRY	No.2	SPF
L - J	2x4	DRY	No.2	SPF
S - Q	2x4	DRY	No.2	SPF
Q - N	2x4	DRY	No.2	SPF
N - L	2x4	DRY	No.2	SPF
ALL WEBS	2x3	DRY	No.2	SPF

EXCEPT

DRY, SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B	TMVW-p	MT20	5.0	8.0	Edge 3.50
C	TMWW-t	MT20	4.0	4.0	2.00 1.75
D	TS-t	MT20	3.0	6.0	
E	TTW-m	MT20	4.0	6.0	
F	TMWW-t	MT20	4.0	4.0	
G	TTW-m	MT20	4.0	6.0	
H	TS-t	MT20	3.0	8.0	
I	TMWW-t	MT20	4.0	4.0	2.00 1.75
J	TMVW-p	MT20	5.0	8.0	Edge 3.50
L	BMV-t	MT20	3.0	4.0	
M	BMWW-t	MT20	5.0	6.0	2.50 2.25
N	BS-t	MT20	3.0	6.0	
O	BMWW-t	MT20	4.0	9.0	
P	BMWW-t	MT20	4.0	9.0	
Q	BS-t	MT20	3.0	6.0	
R	BMWW-t	MT20	5.0	8.0	2.50 2.25
S	BMV-t	MT20	3.0	4.0	

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
JT	VERT	HORZ	DOWN	HORZ
S	2063	0	2063	0
L	2063	0	2063	0

UNFACTORED REACTIONS

JT	1ST LCASE COMBINED	MAX MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
S	1457	969 / 0	0 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0
L	1457	969 / 0	0 / 0	0 / 0	0 / 0	0 / 0	488 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, L

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF G-P, F-P, F-O, I-O.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PL)	MAX. FACTORED VERT. LOAD (LC1)	MAX. FACTORED VERT. LOAD (LC)	UNBRACED LENGTH	WEBS	MAX. FACTORED FORCE (LBS)	MAX. FACTORED VERT. LOAD (LC)
FR-TO						FR-TO		
A-B	0 / 28	-91.8	-91.8	0.12 (1)	10.00	R-C	-182 / 52	0.06 (1)
B-C	-2906 / 0	-91.8	-91.8	0.83 (1)	3.25	C-P	-637 / 0	0.29 (1)
C-D	-2373 / 0	-91.8	-91.8	0.72 (1)	3.66	P-E	0 / 674	0.15 (1)
D-E	-2373 / 0	-91.8	-91.8	0.72 (1)	3.66	F-P	-222 / 0	0.11 (1)
E-F	-2100 / 0	-91.8	-91.8	0.19 (1)	4.53	F-O	-222 / 0	0.11 (1)
F-G	-2100 / 0	-91.8	-91.8	0.19 (1)	4.53	O-G	0 / 874	0.15 (1)
G-H	-2373 / 0	-91.8	-91.8	0.72 (1)	3.66	O-I	-637 / 0	0.29 (1)
H-I	-2373 / 0	-91.8	-91.8	0.72 (1)	3.66	M-I	-182 / 52	0.06 (1)
I-J	-2906 / 0	-91.8	-91.8	0.83 (1)	3.25	B-R	0 / 2849	0.60 (1)
J-K	0 / 28	-91.8	-91.8	0.12 (1)	10.00	M-J	0 / 2849	0.60 (1)
S-B	-2008 / 0	0.0	0.0	0.20 (1)	5.98			
L-J	-2008 / 0	0.0	0.0	0.20 (1)	5.98			
S-R	0 / 0	-18.5	-18.5	0.20 (4)	10.00			
R-Q	0 / 2630	-18.5	-18.5	0.52 (1)	10.00			
Q-P	0 / 2630	-18.5	-18.5	0.52 (1)	10.00			
P-O	0 / 2193	-18.5	-18.5	0.45 (1)	10.00			
O-N	0 / 2630	-18.5	-18.5	0.52 (1)	10.00			
N-M	0 / 2630	-18.5	-18.5	0.52 (1)	10.00			
M-L	0 / 0	-18.5	-18.5	0.20 (4)	10.00			

TOTAL WEIGHT = 2 X 146 = 291 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
DL = 6.0	PSF	
BOT CH.	LL = 0.0	PSF
DL = 7.4	PSF	
TOTAL LOAD = 39.0	PSF	

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-08, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")
CALCULATED VERT. DEFL.(LL) = L/989 (0.14")
ALLOWABLE DEFL.(TL) = L/360 (1.17")
CALCULATED VERT. DEFL.(TL) = L/989 (0.30")

CSI: TC=0.83/1.00 (I-J:1), BC=0.52/1.00 (M-O:1), WB=0.60/1.00 (B-R:1), SSI=0.28/1.00 (I-J:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT

NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MT20	518	354
	1667	788
	1987	1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.88 (M) (INPUT = 0.90)
JSI METAL= 0.79 (N) (INPUT = 1.00)



Structural component only
DWG# T-2007112



LUMBER

N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY	No.2	SPF
D - F	2x4	DRY	No.2	SPF
F - G	2x4	DRY	No.2	SPF
G - I	2x4	DRY	No.2	SPF
I - L	2x4	DRY	No.2	SPF
L - B	2x4	DRY	No.2	SPF
M - K	2x4	DRY	No.2	SPF
T - R	2x4	DRY	No.2	SPF
R - O	2x4	DRY	No.2	SPF
O - M	2x4	DRY	No.2	SPF
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0	
C	TMVW-t	MT20	5.0	6.0	2.50
D	TS-t	MT20	3.0	6.0	
E	TMVW-t	MT20	4.0	4.0	2.00
F	TTW-h	MT20	4.0	4.0	2.00
G	TTWV-m	MT20	5.0	6.0	2.00
H	TMVW-t	MT20	4.0	4.0	2.00
I	TS-t	MT20	3.0	6.0	
J	TMVW-t	MT20	5.0	6.0	2.50
K	TMV+p	MT20	3.0	4.0	
M	BMVW-t	MT20	5.0	6.0	2.25
N, P, S					
N	BMVW-t	MT20	4.0	4.0	
O	BS-t	MT20	3.0	6.0	
Q	BMVW-t	MT20	4.0	9.0	
R	BS-t	MT20	3.0	6.0	
T	BMVW-t	MT20	5.0	6.0	2.25

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT VERT 2083	DOWN 2083	0	0
T 2083	HORIZ 0	0	0
M 2083	UP/LIFT 0	5-8	5-8

UNFACTORED REACTIONS

1ST LCASE	MAX/MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
JT COMBINED		1457	969 / 0	0 / 0	0 / 0	488 / 0	0 / 0
T		1457	969 / 0	0 / 0	0 / 0	488 / 0	0 / 0
M							

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) T, M

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.88 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF E-Q, H-P, C-T, J-M.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSF (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSF (LC)	
FR-TO				FR-TO			
A-B	0 / 28	-91.8	-91.8 0.12 (1)	C-S	-110 / 37	0.04 (1)	
B-C	0 / 19	-91.8	-91.8 0.32 (1)	S-E	0 / 276	0.08 (1)	
C-D	-2758 / 0	-91.8	-91.8 0.40 (1)	E-Q	-881 / 0	0.31 (1)	
D-E	-2758 / 0	-91.8	-91.8 0.40 (1)	Q-F	0 / 513	0.14 (1)	
E-F	-2167 / 0	-91.8	-91.8 0.36 (1)	F-G	0 / 4	0.00 (1)	
F-G	-1925 / 0	-91.8	-91.8 0.18 (1)	G-H	0 / 609	0.14 (1)	
G-H	-2166 / 0	-91.8	-91.8 0.36 (1)	H-I	-892 / 0	0.31 (1)	
H-I	-2780 / 0	-91.8	-91.8 0.40 (1)	I-J	0 / 278	0.06 (1)	
I-J	-2760 / 0	-91.8	-91.8 0.40 (1)	J-K	-110 / 37	0.04 (1)	
J-K	0 / 19	-91.8	-91.8 0.32 (1)	K-L	-3040 / 0	0.85 (1)	
K-L	0 / 28	-91.8	-91.8 0.12 (1)	L-M	-3041 / 0	0.85 (1)	
T-B	-325 / 0	0.0	0.0 0.03 (1)				
M-K	-328 / 0	0.0	0.0 0.03 (1)				
T-S	0 / 2536	-18.5	-18.5 0.55 (1)				
S-R	0 / 2362	-18.5	-18.5 0.53 (1)				
R-Q	0 / 2362	-18.5	-18.5 0.53 (1)				
Q-P	0 / 1924	-18.5	-18.5 0.40 (1)				
P-O	0 / 2362	-18.5	-18.5 0.53 (1)				
O-N	0 / 2362	-18.5	-18.5 0.53 (1)				
N-M	0 / 2537	-18.5	-18.5 0.55 (1)				

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF

DL = 6.0 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 8.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(65 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (1.17")

CALCULATED VERT. DEFL.(LL) = L/999 (0.15")

ALLOWABLE DEFL.(TL) = L/360 (1.17")

CALCULATED VERT. DEFL.(TL) = L/989 (0.32")

CSI: TC=0.40/1.00 (H-H:1), BC=0.56/1.00 (M-N:1), WS=0.85/1.00 (J-M:1), SSI=0.20/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 518 354 1867 788 1987 1856

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.89 (M) (INPUT = 0.90)

JSI METAL = 0.83 (O) (INPUT = 1.00)



Structural component only
DWG# T-2007113



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	No.2
A - D	2x4	DRY	No.2
D - F	2x4	DRY	No.2
F - H	2x4	DRY	No.2
H - K	2x4	DRY	No.2
S - B	2x4	DRY	No.2
L - J	2x4	DRY	No.2
S - Q	2x4	DRY	No.2
O - N	2x4	DRY	No.2
N - L	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2

EXCEPT

S - C 2x4 DRY No.2

I - L 2x4 DRY No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
C	TMVW+1	MT20	5.0	3.0	2.25	2.00
D	TS-1	MT20	3.0	3.0		
E	TMVW+1	MT20	5.0	3.0		
F	TMVW+1	MT20	4.0	3.0	Edge	
G	TMVW+1	MT20	5.0	3.0		
H	TS-1	MT20	3.0	3.0		
I	TMVW+1	MT20	5.0	3.0	2.25	2.00
J	TMV+p	MT20	3.0	4.0		
L	BMVW+1	MT20	4.0	3.0	Edge	
M	O.P.R.					
N	BMVW+1	MT20	4.0	3.0		
O	BS-1	MT20	3.0	3.0		
Q	BS-1	MT20	3.0	3.0		
S	BMVW+1	MT20	4.0	3.0	Edge	

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
S	2083 0	2083 0	5-8	5-8
L	2083 0	2083 0	5-8	5-8

UNFACTORED REACTIONS

JT	1ST CASE	MAX. MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
S	1457	969 / 0	0 / 0	0 / 0	488 / 0	0 / 0
L	1457	969 / 0	0 / 0	0 / 0	488 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) S, L

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.75 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF C-S, L.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING
TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED CSI (L/C)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CSI (L/C)	
FR-TO		FROM TO	LENGTH	FR-TO			
A-B	0 / 28	-91.8 -91.8	0.12 (1)	F-Q	0 / 866	0.19 (1)	
B-C	0 / 22	-91.8 -91.8	0.40 (1)	C-G	-728 / 0	0.72 (1)	
C-D	-2808 / 0	-91.8 -91.8	0.49 (1)	G-M	0 / 391	0.09 (1)	
D-E	-2808 / 0	-91.8 -91.8	0.49 (1)	M-I	-192 / 18	0.05 (1)	
E-F	-2822 / 0	-91.8 -91.8	0.46 (1)	P-F	0 / 866	0.19 (1)	
F-G	-2822 / 0	-91.8 -91.8	0.46 (1)	E-P	-728 / 0	0.72 (1)	
G-H	-2808 / 0	-91.8 -91.8	0.49 (1)	R-E	0 / 391	0.09 (1)	
H-I	-2808 / 0	-91.8 -91.8	0.49 (1)	C-R	-192 / 18	0.05 (1)	
I-J	0 / 22	-91.8 -91.8	0.40 (1)	S-C	-3084 / 0	0.72 (1)	
J-K	0 / 28	-91.8 -91.8	0.12 (1)	I-L	-3084 / 0	0.72 (1)	
S-B	-344 / 0	0.0 0.0	0.03 (1)				
L-J	-344 / 0	0.0 0.0	0.03 (1)				
S-R	0 / 2574	-18.5 -18.5	0.53 (1)				
R-Q	0 / 2291	-18.5 -18.5	0.47 (1)				
Q-P	0 / 2291	-18.5 -18.5	0.47 (1)				
P-O	0 / 1762	-18.5 -18.5	0.38 (1)				
O-N	0 / 2291	-18.5 -18.5	0.47 (1)				
N-M	0 / 2291	-18.5 -18.5	0.47 (1)				
M-L	0 / 2574	-18.5 -18.5	0.53 (1)				

TOTAL WEIGHT = 6 X 152 = 910 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	PSF
DL	25.6	PSF
DL	6.0	PSF
BOT CH.	LL	PSF
DL	0.0	PSF
DL	7.4	PSF
TOTAL LOAD	39.0	PSF

SPACING = 24.0 IN./C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (1.17")
CALCULATED VERT. DEFL. (LL) = L/999 (0.14")
ALLOWABLE DEFL. (TL) = L/360 (1.17")
CALCULATED VERT. DEFL. (TL) = L/999 (0.28")

CSI: TC=0.48/1.00 (C-E:1), BC=0.59/1.00 (L-M:1), WB=0.72/1.00 (E-P:1), SSI=0.22/1.00 (I-J:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT

NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 788
		1987 1655

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP = 0.87 (C) (INPUT = 0.90)
JSI METAL = 0.77 (I) (INPUT = 1.00)



Structural component only
DWG# T-2007114


JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408152	T47	1	2	GREEN PARK HOMES	

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:29:42 2020 Page 2
 ID:7vF?aG0E03cRUI6X1ISkziWYK-j9m42R CCaleHIJZTIDaWTxzGSvYZDD8kZDEYrznCON

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW-p	MT20	4.0	6.0	1.00	3.00
C	TTWW-m	MT20	5.0	6.0	2.25	2.00
D	TMW+w	MT20	2.0	4.0		
E	TTWW-m	MT20	5.0	6.0	2.25	2.00
F	TMVW+p	MT20	4.0	4.0	1.50	2.00
G	BMV1+p	MT20	3.0	6.0		
H	BMWW-t	MT20	5.0	6.0		
I	BS-t	MT20	5.0	6.0		
J	BMWWW-t	MT20	5.0	6.0		
K	BMWW-t	MT20	5.0	6.0		
L	BMV1+p	MT20	3.0	6.0		




Structural component only
 DWG# T-2007115 *HL*

Structural component only
DWG# T-2007116

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408152	T49	1	1	GREEN PARK HOMES	

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:44 2020 Page 1
ID:17vF7aG0E03cRUj6X1jSrKzIWyK-IYUqS70SkCzMxbTya4F2bucKSQdH15VRClLdkzNCOU



Scale: 3/8\"

LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
A - D	2x4	DRY No.2	SPF
D - F	2x4	DRY No.2	SPF
K - B	2x4	DRY No.2	SPF
G - F	2x4	DRY No.2	SPF
K - I	2x4	DRY No.2	SPF
I - G	2x4	DRY No.2	SPF

ALL WEBS 2x3 DRY No.2 EXCEPT

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW-t	MT20	4.0	6.0	2.00	3.00
C	TMVW-t	MT20	4.0	4.0	2.00	1.75
D	TTW-p	MT20	4.0	4.0		
E	TMVW-t	MT20	4.0	6.0		
F	TMVW-p	MT20	3.0	4.0		
G	BMVW1-t	MT20	4.0	4.0		
H	BMVW1-t	MT20	4.0	3.0		
I	BS-t	MT20	3.0	6.0		
J	BMVW-t	MT20	4.0	6.0		
K	BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECRD BRG
JT	VERT	HORZ	DOWN	HORZ
K	1039	0	1039	0
G	914	0	914	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT G. MINIMUM BEARING LENGTH AT JOINT G = 3-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
K	732	494 / 0	0 / 0	0 / 0	0 / 0	238 / 0	0 / 0	0 / 0
G	846	424 / 0	0 / 0	0 / 0	0 / 0	222 / 0	0 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) K

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 5.66 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED CS1 (LC)	MAX. UNBRACED LENGTH FR-TO	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CS1 (LC)
A-B	0 / 28	-91.8	-91.8 0.12 (1)	10.00	J-C	-114 / 23	0.02 (1)
B-C	-1135 / 0	-91.8	-91.8 0.26 (1)	5.66	C-H	-418 / 0	0.22 (1)
C-D	-799 / 0	-91.8	-91.8 0.25 (1)	6.25	H-D	0 / 407	0.09 (1)
D-E	-793 / 0	-91.8	-91.8 0.15 (1)	6.25	H-E	-39 / 37	0.02 (1)
E-F	0 / 17	-91.8	-91.8 0.19 (1)	10.00	B-J	0 - 1051	0.24 (1)
K-B	-998 / 0	0.0	0.0 0.10 (1)	7.61	E-G	-1026 / 0	0.44 (1)
G-F	-129 / 0	0.0	0.0 0.02 (1)	7.61			
K-J	0 / 0	-18.5	-18.5 0.10 (4)	10.00			
J-I	0 / 1034	-18.5	-18.5 0.29 (4)	10.00			
I-H	0 / 1034	-18.5	-18.5 0.29 (4)	10.00			
H-G	0 / 722	-18.5	-18.5 0.26 (4)	10.00			

TOTAL WEIGHT = 67 lb

(M)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL =	25.8	PSF
	DL =	6.0	PSF
BOT CH.	LL =	0.0	PSF
	DL =	7.4	PSF
TOTAL LOAD	=	39.0	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCSC 2018, CBC 2012, ABC 2018
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.56")
CALCULATED VERT. DEFL.(LL) = L/999 (0.03")
ALLOWABLE DEFL.(TL) = L/360 (0.56")
CALCULATED VERT. DEFL.(TL) = L/999 (0.10")

CSI: TC=0.26/1.00 (B-C:1), BC=0.29/1.00 (H-J:4), WB=0.44/1.00 (E-G:1), SSI=0.19/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
	(PSI)	(PLI)	(PLI)
MAX	MIN	MAX	MIN
MT20	518	354	1667
	788	1987	1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.84 (G) (INPUT = 0.80)
JSI METAL= 0.36 (I) (INPUT = 1.00)



Structural component only
DWG# T-2007117

Structural component only
DWG# T-2007118



LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
F - A	2x4	DRY No.2	SPF
A - C	2x4	DRY No.2	SPF
D - C	2x4	DRY No.2	SPF
F - D	2x4	DRY No.2	SPF

ALL WEBS 2x3 DRY No.2
DRY: SEASONED LUMBER.

PLATES (table in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW-t	MT20	4.0	6.0		
B	TMVW-w	MT20	2.0	4.0		
C	TMVW-t	MT20	4.0	6.0		
D	BMV1-p	MT20	3.0	4.0		
E	BMVWW-t	MT20	4.0	9.0		
F	BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

PROVIDE ADEQUATE DRAINAGE TO PREVENT PONDING

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQD BRG	
	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	IN-SX
F	620	0	620	0	0	5-8	5-8	5-8
D	620	0	620	0	0	5-8	5-8	5-8

UNFACTORED REACTIONS

JT	COMBINED	MAX./MIN. COMPONENT REACTIONS		WIND	DEAD	SOIL
		SNOW	LIVE			
F	448	239 / 0	0 / 0	0 / 0	209 / 0	0 / 0
D	448	239 / 0	0 / 0	0 / 0	209 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F, D

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 5.52 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. LC1 (LC)	MAX. UNBRACED LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. LC1 (LC)
FR-TO		FROM TO			FR-TO		
F-A	-693 / 0	0.0	0.0	0.11 (1)	7.81	A-E	0 / 792
A-B	-695 / 0	-114.3	-114.3	0.55 (1)	5.52	E-B	-858 / 0
B-C	-695 / 0	-114.3	-114.3	0.55 (1)	5.52	E-C	0 / 792
D-C	-693 / 0	0.0	0.0	0.11 (1)	7.81		
F-E	0 / 0	-18.5	-18.5	0.13 (4)	10.00		
E-D	0 / 0	-18.5	-18.5	0.13 (4)	10.00		

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.8 PSF
DL = 15.0 PSF	
BOT CH.	LL = 0.0 PSF
DL = 7.4 PSF	
TOTAL LOAD	= 48.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 0.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2019, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 065-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.8 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.31")
CALCULATED VERT. DEFL.(LL) = L/899 (0.01")
ALLOWABLE DEFL.(TL) = L/360 (0.31")
CALCULATED VERT. DEFL.(TL) = L/999 (0.03")

CSI: TC=0.55/1.00 (B-C:1), BC=0.13/1.00 (E-F:4), WB=0.24/1.00 (A-E:1), SS=0.34/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00
FLAT ROOF FACTOR = 0.75

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PLI)	MAX MIN	MAX MIN	MAX MIN
MT20	618	354	1667	788	1987

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP = 0.61 (A) (INPUT = 0.90)
JSI METAL = 0.24 (A) (INPUT = 1.00)



Structural component only
DWG# T-2007120

JOB NAME 408152	TRUSS NAME G52	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington					

Version 8.310 5 Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:29:28 2020 Page 1
ID:7vF7aG0E03cRU6X1jSrkzjWYK-7Twn6fpQVHydc8EteizlyWyePpDiHyU4WOpV3izNCOB



LUMBER			
N. L. G. A. RULES	CHORDS	SIZE	LUMBER
L - A	2x4	DRY	No.2
A - F	2x4	DRY	No.2
G - F	2x4	DRY	No.2
L - G	2x4	DRY	No.2
ALL WEBS	2x3	DRY	No.2
ALL GABLE WEBS	2x3	DRY	No.2
DRY: SEASONED LUMBER.			

GABLE STUDS SPACED AT 2'-0" O.C.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
A TMV+p	MT20	3.0	4.0		
B, C, D, E					
B TMV+w	MT20	2.0	4.0		
F TMV+p	MT20	3.0	4.0		
G BMV1+p	MT20	3.0	4.0		
H, I, J, K					
H BMV1+w	MT20	2.0	4.0		
L BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

PROVIDE ADEQUATE DRAINAGE TO PREVENT PONDING.

BEARINGS

THIS TRUSS DESIGNED FOR CONTINUOUS BEARINGS.

THIS TRUSS REQUIRES RIGID SHEATHING ON EXPOSED FACE.

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S)

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD LC1 (PLF)	MAX. CS1 (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CS1 (LC)	
FR-TO		FROM TO	LENGTH	FR-TO			
L-A	-101 / 0	0.0	0.03 (1)	7.61	K-B	-245 / 0	0.06 (1)
A-B	-8 / 0	-114.3	-114.3 0.08 (1)	10.00	J-C	-224 / 0	0.05 (1)
B-C	-8 / 0	-114.3	-114.3 0.08 (1)	10.00	I-D	-237 / 0	0.05 (1)
C-D	-8 / 0	-114.3	-114.3 0.07 (1)	10.00	H-E	-196 / 0	0.04 (1)
D-E	-8 / 0	-114.3	-114.3 0.07 (1)	10.00			
E-F	-8 / 0	-114.3	-114.3 0.05 (1)	10.00			
F-G	-64 / 0	0.0	0.0 0.02 (1)	7.61			
L-K	0 / 8	-18.5	-18.5 0.02 (4)	10.00			
K-J	0 / 8	-18.5	-18.5 0.02 (4)	10.00			
J-I	0 / 8	-18.5	-18.5 0.02 (4)	10.00			
I-H	0 / 8	-18.5	-18.5 0.02 (4)	10.00			
H-G	0 / 8	-18.5	-18.5 0.02 (1)	10.00			

TOTAL WEIGHT = 34 lb

[MIR]

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
DL = 15.0	PSF	
BOT CH.	LL = 0.0	PSF
DL = 7.4	PSF	
TOTAL LOAD = 48.0	PSF	

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 0.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.08/1.00 (A-B:1), BC=0.02/1.00 (K-L:4), WB=0.06/1.00 (B-K:1), SSI=0.13/1.00 (A-B:1)

COL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00
FLAT ROOF FACTOR = 0.75

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PLI)	MAX MIN	MAX MIN	MAX MIN
MT20	618	354	1667	788	1987 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.17 (K) (INPUT = 0.90)
JSI METAL = 0.07 (K) (INPUT = 1.00)



Structural component only
DWG# T-2007104

Tamarack Roof Truss, Burlington



LUMBER	N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
F - A	2x4	DRY	No.2	SPF	
A - C	2x8	DRY	No.2	SPF	
D - C	2x4	DRY	No.2	SPF	
F - D	2x6	DRY	No.2	SPF	
ALL WEBS	2x3	DRY	No.2	SPF	
DRY: SEASONED LUMBER.					

PLATES (table is in inches)	JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW-t	MT20	5.0	6.0			
B	TMVW-w	MT20	3.0	6.0			
C	TMVW-t	MT20	5.0	6.0			
D	BMV1-p	MT20	3.0	6.0			
E	BMVW-w	MT20	5.0	8.0			
F	BMV1-p	MT20	3.0	6.0			

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

PROVIDE ADEQUATE DRAINAGE TO PREVENT PONDING

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
F	988	0	988	0
D	1012	0	1012	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT F, D. MINIMUM BEARING LENGTH AT JOINT F = 3-8, JOINT D = 3-8.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
F	705	427 / 0	0 / 0	0 / 0	0 / 0	0 / 0	279 / 0	0 / 0
D	722	439 / 0	0 / 0	0 / 0	0 / 0	0 / 0	283 / 0	0 / 0

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED LC1 MAX (LC)	MAX. UNBRACED LENGTH	MEMB.	WEBS MAX. FACTORED FORCE (LBS)	FACTORED LC1 MAX (LC)
F-A	-846 / 0	0.0	0.0 0.23 (1)	7.45	A-E	0 / 1072	0.35 (1)
A-B	-889 / 0	-114.3	-114.3 0.24 (1)	6.25	E-B	-632 / 0	0.18 (1)
B-C	-889 / 0	-114.3	-114.3 0.24 (1)	6.25	E-C	0 / 1072	0.35 (1)
D-C	-846 / 0	0.0	0.0 0.23 (1)	7.45			
F-G	0 / 0	-18.5	-18.5 0.24 (1)	10.00			
G-H	0 / 0	-18.5	-18.5 0.24 (1)	10.00			
H-E	0 / 0	-18.5	-18.5 0.24 (1)	10.00			
E-I	0 / 0	-18.5	-18.5 0.24 (1)	10.00			
I-J	0 / 0	-18.5	-18.5 0.24 (1)	10.00			
J-D	0 / 0	-18.5	-18.5 0.24 (1)	10.00			

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX.	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
G	1-9-12	-190	-190	---	FRONT	VERT	TOTAL	---	C1
H	3-9-12	-190	-190	---	FRONT	VERT	TOTAL	---	C1
I	5-9-12	-190	-190	---	FRONT	VERT	TOTAL	---	C1
J	7-9-12	-190	-190	---	FRONT	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

TOTAL WEIGHT = 51 lb (M/R)

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6	PSF
	DL = 15.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.4	PSF
TOTAL LOAD	= 48.0	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 0.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-08, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.31")
CALCULATED VERT. DEFL.(LL) = $L/989$ (0.02")
ALLOWABLE DEFL.(TL) = $L/360$ (0.31")
CALCULATED VERT. DEFL.(TL) = $L/989$ (0.04")

CSI: TC=0.24/1.00 (B-C:1), BC=0.24/1.00 (D-E:1), WB=0.35/1.00 (A-E:1), SSI=0.29/1.00 (E-F:1)

DCL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00
FLAT ROOF FACTOR = 0.75

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT

NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1857 738
	1987	1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.76 (E) (INPUT = 0.90)
JSI METAL = 0.32 (E) (INPUT = 1.00)



Structural component only
DWG# T-2007121



LUMBER	CHORDS	SIZE	LUMBER	DESCR.
N. L. G. A. RULES	A - C	2x4	DRY	No.2
	D - C	2x4	DRY	No.2
	A - D	2x6	DRY	No.2
ALL WEBS	2x3	DRY	No.2	SPF
DRY: SEASONED LUMBER.				

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN)	LOAD(PLF)
TOP CHORDS : (0.122"x3") SPIRAL NAILS		
A - C	12	TOP
C - D	12	TOP
BOTTOM CHORDS : (0.122"x3") SPIRAL NAILS		
A - D	12	SIDE(0.0)
WEBS : (0.122"x3") SPIRAL NAILS		
2x3	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

GIRDER NAILING ASSUMES NAILED HANGERS ARE FASTENED WITH MIN. 3-0 INCH NAILS.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

SIDE - PLF SHOWN IS THE EQUIVALENT UDL APPLIED TO ONE SIDE THAT THE CORRESPONDING NAILING PATTERN SHALL BE CAPABLE OF TRANSFERRING. REMAINING PLF MUST BE APPLIED ON THE OPPOSITE SIDE OR ON THE TOP.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
A - C	MT20	5.0	8.0	3.50	
B - D	MT20	5.0	6.0	2.50	2.25
C - E	MT20	3.0	4.0		
D - F	MT20	5.0	6.0	2.50	2.75
E - G	MT20	3.0	10.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

FACTORED	MAXIMUM FACTORED	INPUT	RECORD
GROSS REACTION	GROSS REACTION	BRG	BRG
JT VERT	DOWN	UP/LIFT	IN-SX
A	3467	0	0
D	2454	0	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT D. MINIMUM BEARING LENGTH AT JOINT D = 4-0.

UNFACTORED REACTIONS

1ST CASE	MAX/MIN	COMPONENT REACTIONS
JT COMBINED	SNOW	LIVE
A	2449	1822 / 0
D	1735	1144 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) A

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.16 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED	FACTORED	MEMB.	MAX. FACTORED
MEMB.	FORCE (LBS)	VERT. LOAD (PLF)	FORCE (LBS)	MAX. FORCE (LBS)
FR-TO	FROM	TO	FR-TO	TO
A - G	-4978 / 0	-91.8	-91.8	0.19 (1)
G - B	-3863 / 0	-91.8	-91.8	0.17 (1)
B - C	-13 / 0	-91.8	-91.8	0.07 (1)
D - C	-129 / 0	0.0	0.0	0.02 (1)
A - F	0 / 3490	-18.5	-18.5	0.25 (1)
F - H	0 / 3490	-18.5	-18.5	0.88 (1)
H - I	0 / 3490	-18.5	-18.5	0.88 (1)
I - J	0 / 3490	-18.5	-18.5	0.88 (1)
J - E	0 / 3490	-18.5	-18.5	0.68 (1)
E - K	0 / 3490	-18.5	-18.5	0.49 (1)
K - D	0 / 3490	-18.5	-18.5	0.49 (1)

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
H	1-4-0	-1378	-1378	---	BACK	VERT	TOTAL	---	C1
I	2-0-0	-1000	-1000	---	FRONT	VERT	TOTAL	---	C1
J	3-0-4	-984	-984	---	FRONT	VERT	TOTAL	---	C1
K	3-3-4	-896	-896	---	BACK	VERT	TOTAL	---	C1
	5-3-4	-896	-896	---	BACK	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

TOTAL WEIGHT = 2 X 30 = 60 lb

DESIGN CRITERIA

*** SPECIAL LOADS ANALYSIS ***
GEOMETRY AND/OR BASIC LOADS CHANGED BY USER.
LOADS WERE DERIVED FROM USER INPUT
NO FURTHER MODIFICATIONS WERE MADE

SPECIFIED LOADS:

TOP CH.	LL	= 25.6	PSF
	DL	= 8.0	PSF
BOT CH.	LL	= 0.0	PSF
	DL	= 7.4	PSF
TOTAL LOAD	=	39.0	PSF

SPACING = 24.0 IN. C/C

*** NON STANDARD GIRDER ***

ADDTL. USER-DEFINED LOADS APPLIED TO ALL LOAD CASES.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-08, CSA 086-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = 1/360 (0.23")
CALCULATED VERT. DEFL.(LL) = 1/999 (0.03")
ALLOWABLE DEFL.(TL) = 1/360 (0.23")
CALCULATED VERT. DEFL.(TL) = 1/999 (0.05")

CSI: TC=0.19/1.00 (A-G:1), BC=0.68/1.00 (E-F:1), WB=0.53/1.00 (B-D:1), SS=0.90/1.00 (E-F:1)

DCL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)
MT20	618	354
	1667	788
	1967	1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.88 (B) (INPUT = 0.90)
JSI METAL= 0.70 (A) (INPUT = 1.00)



Structural component only
DWG# T-2007122



LUMBER

N.L.G.A. RULES

CHORDS	SIZE	DRY	LUMBER	DESCR.
AC - B	2x4	DRY	No.2	SPF
A - H	2x4	DRY	No.2	SPF
H - J	2x4	DRY	No.2	SPF
J - O	2x4	DRY	No.2	SPF
P - O	2x4	DRY	No.2	SPF
AC - T	2x4	DRY	No.2	SPF
T - P	2x4	DRY	No.2	SPF

ALL WEBS 2x3 DRY No.2 SPF

ALL GABLE WEBS 2x3 DRY No.2 SPF

DRY: SEASONED LUMBER.

GABLE STUDS SPACED AT 2-0-0 OC.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMV+p	MT20	3.0	4.0		
C, D, E, F, G, I, K, L, M, N	MT20	2.0	4.0		
H TS-t	MT20	3.0	8.0		
J TTW-m	MT20	4.0	4.0		
O TMV+p	MT20	3.0	4.0		
P BMV1+p	MT20	3.0	4.0		
Q, R, S, U, V, W, X, Y, Z, AA, AB	MT20	2.0	4.0		
T BS-t	MT20	3.0	6.0		
AC BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

THIS TRUSS DESIGNED FOR CONTINUOUS BEARINGS.

THIS TRUSS REQUIRES RIGID SHEATHING ON EXPOSED FACE.

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S)

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 LATERAL BRACE(S) AT 1/2 LENGTH OF O-P.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

MEMB.	MAX. FACTORED FORCE (LBS)	CHORDS		WEBS	
		FROM	TO	FROM	TO
FR-TO					
AC-B	-224 / 0	0.0	0.0	0.02 (1)	7.81
A-B	0 / 28	-91.8	-91.8	0.12 (1)	10.00
B-C	-28 / 0	-91.8	-91.8	0.04 (1)	6.25
C-D	-19 / 0	-91.8	-91.8	0.04 (1)	6.25
D-E	-15 / 0	-91.8	-91.8	0.04 (1)	6.25
E-F	-11 / 0	-91.8	-91.8	0.04 (1)	6.25
F-G	-8 / 0	-91.8	-91.8	0.04 (1)	10.00
G-H	-6 / 0	-91.8	-91.8	0.04 (1)	10.00
H-I	-6 / 0	-91.8	-91.8	0.04 (1)	10.00
I-J	-6 / 0	-91.8	-91.8	0.04 (1)	10.00
J-K	-2 / 0	-91.8	-91.8	0.03 (1)	10.00
K-L	-2 / 0	-91.8	-91.8	0.04 (1)	10.00
L-M	-2 / 0	-91.8	-91.8	0.04 (1)	10.00
M-N	-2 / 0	-91.8	-91.8	0.04 (1)	10.00
N-O	-2 / 0	-91.8	-91.8	0.04 (1)	10.00
O-P	-81 / 0	0.0	0.0	0.01 (1)	6.25
AC-AB	0 / 24	-18.5	-18.5	0.02 (4)	10.00
AB-AA	0 / 17	-18.5	-18.5	0.02 (4)	10.00
AA-Z	0 / 13	-18.5	-18.5	0.02 (4)	10.00
Z-Y	0 / 10	-18.5	-18.5	0.02 (4)	10.00
Y-X	0 / 7	-18.5	-18.5	0.01 (4)	10.00
X-W	0 / 5	-18.5	-18.5	0.02 (4)	10.00
W-V	0 / 4	-18.5	-18.5	0.02 (4)	10.00
V-U	0 / 2	-18.5	-18.5	0.01 (4)	10.00
U-T	0 / 2	-18.5	-18.5	0.02 (4)	10.00
T-S	0 / 2	-18.5	-18.5	0.02 (4)	10.00
S-R	0 / 2	-18.5	-18.5	0.02 (4)	10.00
R-Q	0 / 2	-18.5	-18.5	0.02 (4)	10.00
Q-P	0 / 2	-18.5	-18.5	0.02 (4)	10.00

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF

DL = 6.0 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 6.00/12

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CS: TC=0.12/1.00 (A-B:1), BC=0.02/1.00 (Q-R:4), WB=0.25/1.00 (N-Q:1), SS=0.09/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10

COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 615 354 1657 789 1987 1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.60 (J) (INPUT = 0.90)

JSI METAL= 0.08 (J) (INPUT = 1.00)





LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
A - C	2x4	DRY	No.2
O - E	2x4	DRY	No.2
A - G	2x4	DRY	No.2
G - E	2x4	DRY	No.2

ALL WEBS 2x3 DRY
DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TBM1-h	MT20	3.0	4.0		
B	TMW-w	MT20	2.0	4.0		
C	TTWW-w	MT20	4.0	6.0		Edge
D	TMW-w	MT20	2.0	4.0		
E	TBM1-h	MT20	3.0	4.0		
F	BMWW1-l	MT20	4.0	6.0		
G	BS-l	MT20	3.0	4.0		
H	BMWW1-l	MT20	4.0	6.0		

Edge - INDICATES REFERENCE CORNER OF PLATE TOUCHES EDGE OF CHORD.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
A	134	0	134	0	18-1-0 (9-11-12)1-0	
E	134	0	134	0	18-1-0 (9-11-12)1-0	
F	883	0	883	0	18-1-0 (9-11-12)1-0	
H	883	0	883	0	18-1-0 (9-11-12)1-0	

VALUE IN PARENTHESIS INDICATES EFFECTIVE BEARING LENGTH

UNFACTORED REACTIONS

JT	1ST CASE COMBINED	MAX/MIN. COMPONENT REACTIONS					
		SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
A	94	68 / 0	0 / 0	0 / 0	0 / 0	26 / 0	0 / 0
E	94	68 / 0	0 / 0	0 / 0	0 / 0	26 / 0	0 / 0
F	611	395 / 0	0 / 0	0 / 0	0 / 0	216 / 0	0 / 0
H	611	395 / 0	0 / 0	0 / 0	0 / 0	216 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) A, E, F, H

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 6.25 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)	
FR-TO		FROM TO	LENGTH	FR-TO			
A-B	0 / 240	-91.8 -91.8 0.12 (1)	10.00	C-F	-428 / 0	0.18 (1)	
B-C	0 / 301	-91.8 -91.8 0.34 (1)	10.00	F-D	-436 / 0	0.08 (1)	
C-D	0 / 509	-91.8 -91.8 0.37 (1)	10.00	H-C	-428 / 0	0.18 (1)	
D-L	0 / 503	-91.8 -91.8 0.37 (1)	10.00	B-H	-436 / 0	0.08 (1)	
E	0 / 301	-91.8 -91.8 0.34 (1)	10.00	I-J	-76 / 35	0.00 (1)	
	0 / 240	-91.8 -91.8 0.12 (1)	10.00	K-L	-76 / 35	0.00 (1)	
A-I	-255 / 0	-18.5 -18.5 0.11 (1)	6.25				
H	-243 / 0	-18.5 -18.5 0.13 (4)	6.25				
I-G	-246 / 0	-18.5 -18.5 0.13 (4)	6.25				
F	-248 / 0	-18.5 -18.5 0.13 (4)	6.25				
K	-243 / 0	-18.5 -18.5 0.13 (4)	6.25				
E	-255 / 0	-18.5 -18.5 0.11 (1)	6.25				

TOTAL WEIGHT = 2 X 54 = 107 lb

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. O.C.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF CBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 085-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 0.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.37/1.00 (C-D:1), BC=0.13/1.00 (F-K:4), WB=0.18/1.00 (C-H:1), SS=0.17/1.00 (D-L:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS= 1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MT20 618 354 1667 788 1987 1886

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.48 (H) (INPUT = 0.90)
JSI METAL= 0.15 (C) (INPUT = 1.00)



JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	P1	17	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.316 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:45 2020 Page 1
ID:17VF7aG0E03cRUj6X1jSkziWYK-Z4ZngXQw0m_40cBoEZJOUT3e9d5nBxS8vV0A14zNChe



LUMBER

N.L.G.A. RULES

CHORDS

A - C 2x4 DRY No.2

C - E 2x4 DRY No.2

A - G 2x4 DRY No.2

G - E 2x4 DRY No.2

ALL WEBS 2x3 DRY No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TBM1-h	MT20	3.0	4.0		
B	TBM1-h	MT20	4.0	4.0	2.00	1.75
C	TBM1-h	MT20	4.0	4.0		
D	TBM1-h	MT20	4.0	4.0	2.00	1.75
E	TBM1-h	MT20	3.0	4.0		
F	TBM1-h	MT20	2.0	4.0		
G	TBM1-h	MT20	3.0	4.0		
H	TBM1-h	MT20	4.0	4.0		
I	TBM1-h	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY

BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	HORZ	DOWN	HORZ
A	124	0	124	0
E	124	0	124	0
H	415	0	415	0
F	666	0	666	0
I	666	0	666	0

VALUE IN PARENTHESIS INDICATES EFFECTIVE BEARING LENGTH

UNFACTORED REACTIONS

JT	1ST LOASE	MAX/MIN COMPONENT REACTIONS	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
JT	COMBINED							
A	87	59 / 0	0 / 0	0 / 0	0 / 0	28 / 0	0 / 0	0 / 0
E	87	59 / 0	0 / 0	0 / 0	0 / 0	28 / 0	0 / 0	0 / 0
H	293	192 / 0	0 / 0	0 / 0	0 / 0	101 / 0	0 / 0	0 / 0
F	471	307 / 0	0 / 0	0 / 0	0 / 0	164 / 0	0 / 0	0 / 0
I	471	307 / 0	0 / 0	0 / 0	0 / 0	164 / 0	0 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) A, E, H, F, I

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 6.25 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED HORIZ. LOAD (PLF)	MAX. FACTORED UNBRACED LENGTH (FT)	MEMB.	WEBS	MAX. FACTORED FORCE (LBS)	MAX. FACTORED HORIZ. LOAD (PLF)
FR-TO						FR-TO			
A-K	0 / 240	-91.8	-91.8	0.07 (1)	10.00	H-C	-445 / 0	0.13 (1)	
K-B	0 / 292	-91.8	-91.8	0.32 (1)	10.00	H-D	0 / 59	0.01 (1)	
B-C	0 / 188	-91.8	-91.8	0.30 (1)	10.00	F-D	-526 / 0	0.08 (1)	
C-D	0 / 188	-91.8	-91.8	0.30 (1)	10.00	G-H	0 / 59	0.01 (1)	
D-M	0 / 292	-91.8	-91.8	0.32 (1)	10.00	I-B	-526 / 0	0.08 (1)	
M-E	0 / 240	-91.8	-91.8	0.07 (1)	10.00	J-K	-128 / 6	0.00 (1)	
A-J	-258 / 0	-18.5	-18.5	0.14 (1)	6.25	L-M	-128 / 6	0.00 (1)	
J-I	-240 / 0	-18.5	-18.5	0.14 (1)	6.25				
I-H	-240 / 0	-18.5	-18.5	0.11 (1)	6.25				
H-G	-240 / 0	-18.5	-18.5	0.11 (1)	6.25				
G-F	-240 / 0	-18.5	-18.5	0.11 (1)	6.25				
F-L	-240 / 0	-18.5	-18.5	0.14 (1)	6.25				
L-E	-258 / 0	-18.5	-18.5	0.14 (1)	6.25				

TOTAL WEIGHT = 17 X 55 = 943 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF

DL = 6.0 PSF

BOT CH. LL = 0.0 PSF

DL = 7.4 PSF

TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF NBC 2018, CBC 2012, ABC 2019

- PART 9 OF CBC 2012 (2019 AMENDMENT)

- CSA 088-09, CSA 088-14

- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.32/1.00 (D-M:1), BC=0.14/1.00 (F-L:1), WB=0.13/1.00 (C-H:1), SS=0.17/1.00 (D-M:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY) SHEAR SECTION

(PSI) (PLI) (PLI)

MAX MIN MAX MIN MAX MIN


MT20 618 354 1667 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.51 (B) (INPUT = 0.90)

JSI METAL= 0.13 (C) (INPUT = 1.00)




Structural component only
DWG# T-2007062

JOB NAME: 408151 TRUSS NAME: PB20 QUANTITY: 2 PLY: 1 JOB DESC: GREEN PARK HOMES TRUSS DESC: Tamarack Roof Truss, Burlington DRWG NO. 14103

Version 8.310 S Oct 28 2019 M/Tek Industries, Inc. Sat Apr 25 11:19:42 2020 Page 1
ID:h2dflgC44wS_E2tqPs_atzIRw-HkWF6HrVE7m14RF.#StCxnPKbCR_v_omDtUdZNCXl

Scale = 1/25.3




LUMBER				DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER				TOTAL WEIGHT = 2 X 45 = 90 lb	
N.L.G.A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.	SPF	BEARINGS		
A - C	2x4	DRY	No.2	SPF	SPF	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	RECORD BRG
C - E	2x4	DRY	No.2	SPF	SPF	VERT	HORZ	DOWN	UP/LIFT
B - F	2x4	DRY	No.2	SPF	SPF	B	189	0	189
						F	189	0	189
						J	288	0	288
						I	683	0	683
						H	288	0	288

PLATES (table is in inches)				UNFACTORED REACTIONS				DESIGN CRITERIA	
JT	TYPE	PLATES	W	LEN	Y	X	JT	1ST CASE	MAX/MIN. COMPONENT REACTIONS
B	TMB1-L	MT20	3.0	4.0	1.50	2.00	B	116	93/0
C	TTWW+m	MT20	5.0	6.0	2.25	1.50	F	116	93/0
D	TTWW+m	MT20	2.0	4.0			J	207	118/0
E	TTWW+m	MT20	5.0	6.0	2.25	1.50	I	481	327/0
F	TMB1-L	MT20	3.0	4.0	1.50	2.00	H	207	118/0
H	BMW1-w	MT20	2.0	4.0					
I	BMW1-w	MT20	4.0	9.0					
J	BMW1-w	MT20	2.0	4.0					

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) B, F, J, I, H

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

LOADING				CHORDS				WEBS			
TOTAL LOAD CASES: (4)				MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PL)	MAX. FACTORED CS1 (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED CS1 (LC)	
				FR-TO		FROM TO		FR-TO		FROM TO	
				A-B	0/14	-91.8	-91.8	J-C	-194/0	0.03 (1)	
				B-L	-31/4	-91.8	-91.8	C-I	-22/0	0.01 (1)	
				L-C	-60/0	-91.8	-91.8	I-D	-576/0	0.08 (1)	
				C-D	-6/0	-91.8	-91.8	D-E	-22/0	0.01 (1)	
				D-E	-6/0	-91.8	-91.8	E-N	-194/0	0.03 (1)	
				E-N	-60/0	-91.8	-91.8	N-F	-121/0	0.00 (1)	
				N-F	-31/4	-91.8	-91.8	F-G	-121/0	0.00 (1)	
				F-G	0/14	-91.8	-91.8				
				B-K	0/42	-18.5	-18.5				
				K-J	0/42	-18.5	-18.5				
				J-I	0/29	-18.5	-18.5				
				I-H	0/29	-18.5	-18.5				
				H-M	0/42	-18.5	-18.5				
				M-F	0/42	-18.5	-18.5				



Structural component only
DWG# T-2007080

CS1: TC=0.39/1.00 (C-D:1), BC=0.10/1.00 (I-J:4), WB=0.08/1.00 (D-I:1), SSI=0.22/1.00 (D-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 818 354 1687 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.30 (D) (INPUT = 0.90)
JSI METAL= 0.12 (D) (INPUT = 1.00)

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	U1	21	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:42 2020 Page 1
ID:7vF?aG0E03cRUj6X1jSrKzIWK-9Vif1WN1jrcVxKTDZRHsrR4TQ3I_cmhDXnWhizNCnh



Scale = 1/22.5

LUMBER

N. L. G. A. RULES			
CHORDS	SIZE		LUMBER
E - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
E - D	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
E	BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS							
JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION			INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX
E	525	0	525	0	0	5-8	5-8
C	202	0	202	0	0	1-8	1-8
D	45	0	50	0	0	1-8	1-8

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

JT	1ST CASE COMBINED	MAX./MIN. COMPONENT REACTIONS					
		SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
E	369	257 / 0	0 / 0	0 / 0	0 / 0	111 / 0	0 / 0
C	139	113 / 0	0 / 0	0 / 0	0 / 0	26 / 0	0 / 0
D	35	0 / 0	0 / 0	0 / 0	0 / 0	35 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (LBS)	LC1 MAX (PLF)	MAX. UNBRACED LENGTH (FT)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. UNBRACED LENGTH (FT)
FR-TO		FROM	CSI (LC)		FR-TO		CSI (LC)
E-B	-461 / 0	0.0	0.0	0.13 (4)	7.81		
A-B	0 / 28	-91.8	-91.8	0.12 (1)	10.00		
B-C	-30 / 0	-91.8	-91.8	0.54 (1)	6.25		
E-D	0 / 0	-18.5	-18.5	0.13 (4)	10.00		

TOTAL WEIGHT = 21 X 17 = 355 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6 PSF
	DL = 8.0 PSF
BOT CH.	LL = 0.0 PSF
	DL = 7.4 PSF
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF NBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.20")
CALCULATED VERT. DEFL.(LL) = $L/989$ (0.00")
ALLOWABLE DEFL.(TL) = $L/360$ (0.20")
CALCULATED VERT. DEFL.(TL) = $L/989$ (0.03")

CSI: TC=0.54/1.00 (B-C:1), BC=0.13/1.00 (D-E:4),
WB=0.00/1.00 (N/A:0), SSI=0.24/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PL)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 769

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.19 (E) (INPUT = 0.90)
JSI METAL = 0.13 (B) (INPUT = 1.00)




Structural component only
DWG# T-2007059

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408150	J2	1	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 6.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:43 2020 Page 1
ID:17VF?aG0E03cRUj6X1[Srkz]WYK-dhR1FrOU8kMYU2P78gwP2_KzqQl30rSBX3DBzNCng



Scale = 1/2" = 1'-0"

LUMBER

N.L.G.A. RULES

CHORDS	SIZE	LUMBER	DESCR.
F - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
F - D	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
SPF DRY, SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	4.0	4.0	1.00	2.00
E	BMVW+p	MT20	2.0	4.0		
F	BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
JT	VERT	DOWN	HORIZ	UPLIFT
F	341	0	0	0
C	178	0	0	0
D	36	0	0	0

SEE MITEK STANDARD DETAIL B87791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

JT	1ST LCASE	MAX. MIN. COMPONENT REACTIONS	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
F	239	170/0	0/0	0/0	0/0	0/0	89/0	0/0
C	122	99/0	0/0	0/0	0/0	0/0	23/0	0/0
D	29	0/0	0/0	0/0	0/0	0/0	29/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (5)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (PLF)
FR-TO									
F-B		-305/0	0.0	0.0	0.03 (1)	7.81	B-E	0/0	0.00 (1)
A-B		0/41	-91.8	-91.8	0.14 (5)	10.00			
B-C		0/0	-91.8	-91.8	0.23 (1)	10.00			
F-E		0/0	-18.5	-18.5	0.08 (4)	10.00			
E-D		0/0	-18.5	-18.5	0.08 (4)	10.00			

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

TOTAL WEIGHT = 15 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL	= 25.6 PSF
DL	= 8.0 PSF
BOT CH. LL	= 0.0 PSF
DL	= 7.4 PSF
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-05, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (0.19")
CALCULATED VERT. DEFL. (LL) = $L/999$ (0.00")
ALLOWABLE DEFL. (TL) = $L/360$ (0.19")
CALCULATED VERT. DEFL. (TL) = $L/999$ (0.01")

CSI: TC=0.23/1.00 (B-C:1), BC=0.08/1.00 (D-E:4), WB=0.00/1.00 (B-E:1), SSI=0.11/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)	(PLI)
MAX	MIN	MAX	MIN
MT20	618	354	1857
	788	1387	1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.24 (B) (INPUT = 0.30)
JSI METAL= 0.06 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007060

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408150	J3	6	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington					

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:02:44 2020 Page 1
ID:37vF?AG0E03cRUj6X1jSkzWYK-5u?PSBPfSsDAedbsB9xGWUueIBSWG_hrGcmdzNCnf



LUMBER

N. L. G. A. RULES

CHORDS SIZE

A - C 2x4 DRY

B - D 2x4 DRY

LUMBER

No.2

No.2

DESCR.

SPF

SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B	TMB1-1	MT20	3.0	4.0	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	HORZ	DOWN	HORZ
C	174	0	174	0
B	384	0	384	0
D	68	0	68	0

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

JT	1ST CASE	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
C	120	93 / 0	0 / 0	0 / 0	0 / 0	27 / 0	0 / 0
B	255	180 / 0	0 / 0	0 / 0	0 / 0	75 / 0	0 / 0
D	50	19 / 0	0 / 0	0 / 0	0 / 0	32 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) B, D

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.

MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED	FORCE	VERT. LOAD	LC1	MAX	CS1 (LC)	UNBRAC	LENGTH	FR-TO	WEBS	MAX. FACTORED	FORCE	MAX	CS1 (LC)
A-B	0 / 18	-91.8	-91.8	0.11 (1)	10.00	E-F	-194 / 7	0.00 (1)							
B-F	-14 / 0	-91.8	-91.8	0.05 (4)	6.25										
F-C	0 / 2	-91.8	-91.8	0.22 (1)	10.00										
B-E	0 / 0	-18.5	-18.5	0.17 (1)	10.00										
E-D	0 / 0	-18.5	-18.5	0.17 (1)	10.00										

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	6.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.19")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.02")
ALLOWABLE DEFL.(TL) = $L/360$ (0.19")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.05")

CSI: TC=0.22/1.00 (C-F:1), BC=0.17/1.00 (D-E:1), WB=0.00/1.00 (E-F:1), SS=0.16/1.00 (B-E:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP (DRY)	SHEAR	SECTION
	(PSI)	(PLI)	(PLI)
MAX MIN	MAX MIN	MAX MIN	MAX MIN
MT20	618	354	1657

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.24 (B) (INPUT = 0.90)
JSI METAL = 0.07 (B) (INPUT = 1.00)




Structural component only
DWG# T-2007061

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408152	J40	4	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:29 2020 Page 1
ID:17vF?aG0E03cRUj6X1jSkz/WYK-bIU9J?q2Gb4UDp3CRUXV/VnrDY50PbE/2ZZb6zNGOa

Scale = 1/2" = 1'-0"



LUMBER

N.L.G.A. RULES

CHORDS	SIZE	DRY	LUMBER
E - A	2x4	DRY	No.2
A - B	2x4	DRY	No.2
E - C	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
DRY: SEASONED LUMBER.

DESCR.

SPF

SPF

SPF

SPF

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
A	TMVW-t	MT20	4.0	4.0	2.00	1.25
D	BMV-w	MT20	2.0	4.0		
E	BMV1-p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ
JT	209	0	209	0
E	174	0	174	0
B	35	0	35	0

A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED AT JOINT E. MINIMUM BEARING LENGTH AT JOINT E = 1'-8".

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) B, C

UNFACTORED REACTIONS

JT	1ST CASE	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
E	148	97/0	0/0	0/0	0/0	51/0	0/0
B	120	97/0	0/0	0/0	0/0	23/0	0/0
C	28	0/0	0/0	0/0	0/0	28/0	0/0

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX	CS1 (LC)	UNBRAC LENGTH	FR-TO	WEBS	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CS1 (LC)
E-A		-174/0	0.0	0.0	0.02 (1)	7.81	A-D		0/0	0.00 (1)	
A-B		0/0	-91.8	-91.8	0.22 (1)	10.00					
E-D		0/0	-18.5	-18.5	0.07 (4)	10.00					
D-C		0/0	-18.5	-18.5	0.08 (4)	10.00					

TOTAL WEIGHT = 4 X 13 = 52 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6 PSF
DL = 6.0 PSF	
BOT CH.	LL = 0.0 PSF
DL = 7.4 PSF	
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- GSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = $L/360$ (0.19")
CALCULATED VERT. DEFL. (LL) = $L/999$ (0.00")
ALLOWABLE DEFL. (TL) = $L/360$ (0.19")
CALCULATED VERT. DEFL. (TL) = $L/999$ (0.01")

CS1: TC=0.22/1.00 (A-B:1), BC=0.08/1.00 (C-D:4), WB=0.00/1.00 (A-D:1), SS=0.12/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT

NAIL VALUES


PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PL)
MAX MIN	MAX MIN	MAX MIN
MT20	818 354	1887 788

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP = 0.11 (A) (INPUT = 0.99)


JSI METAL = 0.03 (A) (INPUT = 1.00)



Structural component only
DWG# T-2007105

Version 8.310 S Oct 29 2019 MitTek Industries, Inc. Sat Apr 25 11:29:31 2020 Page 1
ID: i7vF?aG0E03cRUj6X1jSkzjWYK-Y2cwkhRJoCKCTbzSJsX?a8a7q0FFUJ5WDM29g zNCOY

Scale = 1:15.7



TOTAL WEIGHT = $4 \times 10 = 38$ lb

DRY: SEASONED LUMBER

DESCR
SPF
SPF
SPF

BEARINGS

	FACTORED		MAXIMUM FACTORED			INPUT	REQD
	GROSS	REACTION	GROSS	REACTION	UPLIFT	BRG	BRG
JT	VERT	HORZ	DOWN	HORZ		IN-SX	IN-SX
C	319	0	319	0	0	5-6	5-8
E	99	0	99	0	0	1-8	1-8
D	23	0	26	0	0	1-8	1-8

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

1ST CASE		MAX/MIN. COMPONENT REACTIONS					
COMBINED		SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
JT	223	161 / 0	0 / 0	0 / 0	0 / 0	62 / 0	0 / 0
E	68	55 / 0	0 / 0	0 / 0	0 / 0	13 / 0	0 / 0
C	18	0 / 0	0 / 0	0 / 0	0 / 0	18 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED

LOADING

TOTAL LOAD CASES: (5)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CSI (LC)
FR-TO		FROM TO			FR-TO		
E-B	-289 / 0	0.0	0.0	0.02 (4)	7.81		
A-B	0 / 28	-91.8	-91.8	0.13 (5)	10.00		
B-C	-15 / 0	-91.8	-91.8	0.13 (1)	6.25		
E-D	0 / 0	-18.5	-18.5	0.03 (4)	10.00		

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	6.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR
SMALL BUILDING REQUIREMENTS OF PART 9,
NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF CBC 2018 , OBC 2012 , ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

-OVERHANG NOT TO BE ALTERED OR CUT OFF.

(56 % DF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL)= L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/999 (0.00")

CSI: TC=0.13/1.00 (B-C:1), BC=0.03/1.00 (D-E:4),
WB=0.00/1.00 (n/a:0), SSI=0.11/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS= 1.10.

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP(DRY)		SHEAR		SECTION	
	(PSI)		(PLI)		(PLI)	
	MAX	MIN	MAX	MIN	MAX	MIN
MT20	618	354	1667	788	1987	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg


SI GRIP= 0.12 (E) (INPUT = 0.90)
SI METAL= 0.08 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007106

JOB NAME 408150	TRUSS NAME C1	QUANTITY 1	PLY 1	JOB DESC. GREEN PARK HOMES	DRWG NO.
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310 S Oct 29 2019 MITek Industries, Inc. Sat Apr 25 11:02:37 2020 Page 1
 ID:7vF?aG0E03cRUj8X1jSrkzWYK-oX4m_oJvul_CqZaFmuZV9nkJvPNuJLXy4F410XzNCnm
 Scale = 1:15.0



LUMBER
N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
F - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
F - D	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
 DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	4.0	4.0	1.00	2.00
E	BMV+w	MT20	2.0	4.0		
F	BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
F	297	0	297	0	5-8	5-8
C	42	0	42	0	1-8	1-8
D	36	0	40	0	1-8	1-8

SEE MITEK STANDARD DETAIL 897791 H FOR CONNECTION TO JOINT(S) C, D
 PROVIDE ANCHORAGE AT BEARING JOINT C FOR 150 LBS FACTORED UPLIFT

UNFACTORED REACTIONS							
JT	1ST LCASE	MAX/MIN COMPONENT REACTIONS					
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
F	208	145 / 0	0 / 0	0 / 0	0 / 0	63 / 0	0 / 0
C	29	23 / -26	0 / 0	0 / 0	0 / 0	5 / 0	0 / 0
D	29	0 / 0	0 / 0	0 / 0	0 / 0	29 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) F, C

BRACING
 TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
 MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
 TOTAL LOAD CASES: (5)

MEMB.	CHORDS		WEBS	
	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD LC1 (PLF)	MAX. UNBRACED LENGTH FR-TO	MAX. FACTORED FORCE (LBS)
F-B	-261 / 0	0.0	0.0 (1)	7.81
A-B	0 / 41	-91.8	-91.8 (5)	10.00
B-C	-29 / 0	-91.8	-91.8 (5)	6.25
F-E	0 / 0	-18.5	-18.5 (4)	10.00
E-G	0 / 0	-18.5	-18.5 (4)	10.00
G-D	0 / 0	-18.5	-18.5 (4)	10.00

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
G	2-0-12	1	1	---	BACK	VERT	TOTAL	---	C1

CONNECTION REQUIREMENTS

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

DESIGN CRITERIA

SPECIFIED LOADS:
 TOP CH. LL = 25.6 PSF
 DL = 6.0 PSF
 BOT CH. LL = 0.0 PSF
 DL = 7.4 PSF
 TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:
 - PART 9 OF NBC 2010, NBC 2012, ABC 2019
 - PART 9 OF CBC 2012 (2019 AMENDMENT)
 - CSA 086-09, CSA 085-14
 - TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS
 - OVERHANG NOT TO BE ALTERED OR CUT OFF.

(65% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.19")
 CALCULATED VERT. DEFL.(LL) = $L/989$ (0.00")
 ALLOWABLE DEFL.(TL) = $L/360$ (0.19")
 CALCULATED VERT. DEFL.(TL) = $L/989$ (0.01")

CSF: TC=0.14/1.00 (A-B-5), BC=0.08/1.00 (D-E-4), WB=0.00/1.00 (B-E-1), SS=0.09/1.00 (A-B-5)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.


NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PL)	(PL)	(PL)
MT20	818	354	1667 788 1987 1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.20 (B) (INPUT = 0.93)
 JSI METAL= 0.05 (B) (INPUT = 1.00)



Structural component only
 DWG# T-2007055



Scale = 1:19.0

LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	No.2
E - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
E - D	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2

DRY: SEASONED LUMBER.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
E	278	278	0	0
C	42	42	0	0
D	18	20	0	0

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 25.6 PSF
 DL = 6.0 PSF
 BOT CH. LL = 0.0 PSF
 DL = 7.4 PSF
 TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. O.C.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
 - PART 9 OF BCBC 2018, CBC 2012, ABC 2019
 - PART 9 OF CBC 2012 (2019 AMENDMENT)
 - CSA 086-09, CSA 086-14
 - TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

- OVERHANG NOT TO BE ALTERED OR CUT OFF.
 (55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(TL) = L/360 (0.19")
 CALCULATED VERT. DEFL.(TL) = L/999 (0.00")

CSI: TC=0.13/1.00 (A-B:1), BC=0.02/1.00 (D-E:4),
 WB=0.03/1.00 (B-D:1), SSI=0.08/1.00 (B-C:1)

COL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP (DRY)	SHEAR (PSI)	SECTION (PL)
MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1867 788

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.20 (B) (INPUT = 0.90)
 JSI METAL= 0.05 (B) (INPUT = 1.00)

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMVW+p	MT20	4.0	4.0	1.00	2.00
D	BMV1-I	MT20	4.0	4.0	2.00	1.25
E	BMV1+p	MT20	3.0	4.0		

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

PROVIDE ANCHORAGE AT BEARING JOINT C FOR 150 LBS. FACTORED UPLIFT

UNFACTORED REACTIONS

JT	1ST LCASE	MAX. MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
E	194	145 / 0	0 / 0	0 / 0	48 / 0	0 / 0
C	29	23 / -26	0 / 0	0 / 0	5 / 0	0 / 0
D	14	0 / 0	0 / 0	0 / 0	14 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E, C

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
 MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE LATERALLY RESTRAINED.

LOADING


TOTAL LOAD CASES: (5)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. LCI (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)
FR-TO		FROM TO		FR-TO			
E-B	-261 / 0	0.0	0.0 0.03 (1)	7.81	B-D	0 / 0	0.00 (1)
A-B	0 / 43	-91.8	-91.8 0.13 (1)	10.00			
B-C	-29 / 0	-91.8	-91.8 0.12 (1)	6.25			
E-D	0 / 0	-18.5	-18.5 0.02 (4)	10.00			

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN



Structural component only
 DWG# T-2007056



LUMBER

N. L. G. A. RULES			
CHORDS	SIZE		LUMBER
E - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
E - D	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0		
E	BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	RECORD BRG
	VERT	HORZ	DOWN	HORZ		
E	284	0	284	0	5-8	5-8
C	63	0	63	0	1-8	1-8
D	44	0	52	0	1-8	1-8

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS							
JT	1ST LCASE	MAX/MIN COMPONENT REACTIONS					
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
E	200	137/0	0/0	0/0	0/0	62/0	0/0
C	46	21/0	0/0	0/0	0/0	25/0	0/0
D	35	0/-3	0/0	0/0	0/0	37/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E, C

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
TOTAL LOAD CASES: (7)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED HORZ. LOAD (LC)	MAX. UNBRACED LENGTH (FT)	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED HORZ. LOAD (LC)
E-B	-227/0	0.0	0.0	0.11 (4)	7.81		
A-B	0/28	-91.8	-91.8	0.12 (1)	10.00		
B-C	-9/9	-91.8	-91.8	0.08 (4)	10.00		
E-F	0/0	-18.5	-18.5	0.14 (4)	10.00		
F-G	0/0	-18.5	-18.5	0.14 (4)	10.00		
G-D	0/0	-18.5	-18.5	0.14 (4)	10.00		

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
F	1-11-4	7	1	12	BACK	VERT	TOTAL	--	C1
G	3-11-4	1	1	--	BACK	VERT	TOTAL	--	C1

CONNECTION REQUIREMENTS

- 1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NSCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF NBCC 2010, NSCC 2015
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 088-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS
- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.20")
CALCULATED VERT. DEFL.(LL) = L/999 (0.01")
ALLOWABLE DEFL.(TL) = L/360 (0.20")
CALCULATED VERT. DEFL.(TL) = L/999 (0.04")

CSI: TC=0.12/1.00 (A-B-1), BC=0.14/1.00 (D-E-4), WB=0.06/1.00 (N/A-0), SS=0.09/1.00 (A-B-1)

DOL LUMBER=0.98 NAIL=0.98 L.S BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY


TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLJ) (PLJ)
MAX MIN MAX MIN MAX MIN
MT20 818 354 1667 788 1987 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.10 (E) (INPUT = 0.90)
JSI METAL= 0.08 (B) (INPUT = 1.00)




Structural component only
DWG# T-2007099

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	TRUSS DESC.	DRWG NO.
408152	C42	4	1	GREEN PARK HOMES		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:24 2020 Page 1
ID:7vF7aG0E03cRUj6X1jSrkzIWKYK-FhGGHmVR2R87Xx6PlvMognw5CsuL8MVcmrHwuzNCOI

Scale = 1/16"



TOTAL WEIGHT = 4 X 10 = 38 lb

LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
E - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2
E - D	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B	TMV+p	MT20	3.0	4.0	
E	BMV1+p	MT20	3.0	4.0	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG IN-SX	RECORD BRG IN-SX
	VERT	HORZ	DOWN	HORZ		
E	361	0	361	0	5-8	5-8
C	130	0	130	0	1-8	1-8
D	16	0	17	0	1-8	1-8

SEE MITEK STANDARD DETAIL 897791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

JT	1ST CASE COMBINED	MAX./MIN. COMPONENT REACTIONS				
		SNOW	LIVE	PERM.LIVE	WIND	DEAD
E	250	190 / 0	0 / 0	0 / 0	0 / 0	60 / 0
C	90	73 / 0	0 / 0	0 / 0	0 / 0	17 / 0
D	12	0 / 0	0 / 0	0 / 0	0 / 0	12 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRAIDED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (5)

MEMB.	CHORDS				WEBS			
	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX	UNBRACED LENGTH FR-TO	MEMB. MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX	UNBRACED LENGTH FR-TO
E-B	-342 / 0	3.0	0.0	0.01 (4)	7.81			
A-B	0 / 28	-91.8	-91.8	0.13 (5)	10.00			
B-C	-19 / 0	-91.8	-91.8	0.22 (1)	6.25			
E-D	0 / 0	-18.5	-18.5	0.02 (4)	10.00			

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	25.6	PSF
	DL	=	6.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.4	PSF
TOTAL LOAD		=	39.0	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010, NBC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF CBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/599 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/599 (0.00")

CSI: TC=0.22/1.00 (B-C:1), BC=0.02/1.00 (D-E:4), WB=0.00/1.00 (n/a:0), SS=0.15/1.00 (B-C:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PL)	(PL)
MAX	MIN	MAX
MT20	618	354
	1687	788
	1997	1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.14 (E) (INPUT = 0.90)
JSI METAL= 0.09 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007100


Structural component only
DWG# T-2007101

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	GREEN PARK HOMES	DRWG NO.
408152	C44	2	1	TRUSS DESC.		

Tamarack Roof Truss, Burlington

Version 8.310 S Oct 29 2019 Mitek Industries, Inc. Sat Apr 25 11:29:26 2020 Page 1
ID:7vF?aG0E03cRUj6X1jSrkzIWK-B4o1hzoAzgivMqSUXlxt5tHt?X4p2sn34KO_nzNCOd

Scale = 1:12.4



LUMBER	N. L. & A. RULES	SIZE	DRY	LUMBER
CHORDS	E - B	2x4	DRY	No.2
A - C	2x4	DRY	No.2	
E - D	2x4	DRY	No.2	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT TYPE	PLATES	W	LEN	Y	X
B TMV+p	MT20	3.0	4.0		
E BMV1+p	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

DESCR.	SPF	SPF	SPF	SPF
JT	FACTORED	MAXIMUM FACTORED	INPUT	RECORD
E	GROSS REACTION	GROSS REACTION	BRG	BRG
C	VERT	DOWN	UP	IN-SX
D	HORIZ	HORIZ	UP	IN-SX
E	264	0	0	5-8
C	66	0	0	1-8
D	23	0	0	1-8

SEE MITEK STANDARD DETAIL B97791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
E	185	130/0	0/0	0/0	0/0	55/0	0/0
C	46	37/0	0/0	0/0	0/0	9/0	0/0
D	18	0/0	0/0	0/0	0/0	18/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E, C

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (5)

CHORDS	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. LC1 MAX. (LC)	MAX. UNBRACED LENGTH	WEBS	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. (LC)
FR-TO						FR-TO			
E-B	-234/0	0.0	0.0	0.02 (4)	7.81				
A-B	0/28	-91.8	-91.8	0.13 (5)	10.00				
B-C	-10/0	-91.8	-91.8	0.06 (1)	10.00				
E-F	0/0	-18.5	-18.5	0.03 (4)	10.00				
F-D	0/0	-18.5	-18.5	0.03 (4)	10.00				

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX.	MAX+	FACE	DIR.	TYPE	HEEL	CONN.
F	2-0-12	1	1	---	FRONT	VERT	TOTAL	--	C1

CONNECTION REQUIREMENTS

1) C1: A SUITABLE HANGER/MECHANICAL CONNECTION IS REQUIRED.

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

TOTAL WEIGHT = 2 X 8 = 17 lb

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 25.6 PSF
	DL = 6.0 PSF
BOT CH.	LL = 0.0 PSF
	DL = 7.4 PSF
TOTAL LOAD	= 39.0 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:

- PART 9 OF BCBC 2018, CBC 2012, ABC 2019
- PART 9 OF CBC 2012 (2019 AMENDMENT)
- CSA 086-09, CSA 086-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS

OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/999 (0.00")

CSI: TC=0.13/1.00 (A-B:5), BC=0.03/1.00 (D-E:4),
WB=0.00/1.00 (n/a:0), SS=0.10/1.00 (A-B:5)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE GRIP(DRY)	SHEAR	SECTION
(PSI)	(PL)	(PL)
MAX MIN	MAX MIN	MAX MIN
MT20	819	354
	1557	788
	1987	1656

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.


JSI GRIP = 0.10 (E) (INPUT = 0.90)
JSI METAL = 0.08 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007102

JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
408152	C45	2	1	GREEN PARK HOMES	
Tamarack Roof Truss, Burlington				TRUSS DESC.	

Version 8.310.5 Oct 29 2019 MTEK Industries, Inc. Sat Apr 25 11:29:27 2020 Page 1
ID:17vF?aG0E03cRUj6X1jSkzIWYK-IHMPuJookzqm_gH40S3PIPT_PIZYV6xIk4xXDzNCC0



Scale = 1:13.4

TOTAL WEIGHT = 2 X 7 = 15 lb

LUMBER	N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
E - B	2x4	DRY	No.2			SPF
A - C	2x4	DRY	No.2			SPF
E - D	2x4	DRY	No.2			SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)	JT	TYPE	PLATES	W	LEN	Y	X
B	TMV-p	MT20	3.0	4.0			
E	BMV1-p	MT20	3.0	4.0			

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	REQD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	DOWN	HORIZ	UPLIFT
E	254	0	0	5-8
C	66	0	0	1-8
D	16	0	0	1-8

SEE MTEK STANDARD DETAIL 697791H FOR CONNECTION TO JOINT(S) C, D

UNFACTORED REACTIONS	1ST CASE	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL
JT	COMBINED						
E	177	130/0	0/0	0/0	0/0	47/0	0/0
C	46	37/0	0/0	0/0	0/0	9/0	0/0
D	13	0/0	0/0	0/0	0/0	13/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) E, C

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT. OR RIGID CEILING DIRECTLY APPLIED.
ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
TOTAL LOAD CASES: (5)

CHORDS	MAX. FACTORED	FACTORED	VERT. LOAD	LC1	MAX	MAX.	MEMB.	MAX. FACTORED
MEMB.	FORCE	VERT.	PLF	CSI (LC)	UNBRAC	LENGTH	FR-TO	FORCE
	(LBS)							(LBS)
FR-TO								
E-B	-234/0	0.0	0.0	0.01 (4)	7.81			
A-B	0/29	-91.8	-91.8	0.12 (1)	10.00			
B-C	-10/0	-91.8	-91.8	0.06 (1)	10.00			
E-D	0/0	-18.5	-18.5	0.02 (4)	10.00			

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 25.6 PSF
DL = 6.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.4 PSF
TOTAL LOAD = 39.0 PSF

SPACING = 24.0 IN./C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010, NBCC 2015

THIS DESIGN COMPLIES WITH:
- PART 9 OF BCBC 2018, OBC 2012, ABC 2019
- PART 9 OF OBC 2012 (2019 AMENDMENT)
- CSA 088-09, CSA 088-14
- TPIC 2011, TPIC 2014

DESIGN ASSUMPTIONS
- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55% OF 31.3 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 25.6 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/999 (0.00")

CSI: TC=0.12/1.00 (A-B:1), SC=0.02/1.00 (D-E:4), WB=0.00/1.00 (n/a:0), SSI=0.09/1.00 (A-B:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 1.00

AUTOSOLVE RIGHT HEEL ONLY

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 788 1987 1556

PLATE PLACEMENT TOL = 0.250 inches

PLATE ROTATION TOL = 5.0 Deg.

JSI GRIP = 0.10 (E) (INPUT = 0.90)
JSI METAL = 0.06 (B) (INPUT = 1.00)



Structural component only
DWG# T-2007103

LUL/LUS/LJS/HUS/HHUS/HGUS

Standard and Double-Shear Joist Hangers



This product is preferable to similar connectors because of
a) easier installation, b) higher capacities, c) lower installed
cost, or a combination of these features.

Most hangers in this series have double-shear nailing -- an innovation that distributes the load through two points on each joist nail for greater strength. This allows for fewer nails, faster installation, and the use of all common nails for the same connection. (Do not bend or remove tabs)

Double-shear hangers range from the light capacity LUS hangers to the highest capacity HGUS hangers. For medium load truss applications, the HUS offers a lower cost alternative and easier installation than the HGUS hangers, while providing greater load capacity and bearing than the LUS.

Material: See table on pp. 258-259.


Finish: Galvanized. Some products available in stainless steel or ZMAX® coating; see Corrosion Information, pp. 20-24.

Installation:


- Use all specified fasteners; see General Notes.
- Nails must be driven at an angle through the joist or truss into the header to achieve the tabulated resistances (except LUL).
- Where 16d commons are specified, 10d commons may be used at 0.83 of the tabulated factored resistance.
- Not designed for welded or nailer applications.
- With single ply 2x carrying members, use 10d x 1½" nails into the header and 10d commons into the joist, and reduce the resistance to 0.64 of the table value where 16d nails are specified and 0.77 where 10d nails are specified.

Options:


- LUS, LJS, LUL and HUS hangers cannot be modified.
- Other sizes available; consult your Simpson Strong-Tie representative.
- See Hanger Options information on p. 126.




LUS28




LU26L




HUS210
(HUS26, HUS28,
and HHUS similar)



HGUS28-2



HHUS210-2



Double-Shear
Nailing
Top View





Double-Shear
Nailing
Side View;
Do not
bend tab



Dome Double-Shear
Nailing Side View
(available on
some models)
U.S. Patent 5,603,580

Typical HUS26
Installation
with Reduced
Heel Height
(Truss Designer
to provide
fastener quantity
for connecting
multiple members
together)



LJS26DS

LUL/LUS/LJS/HUS/HHUS/HGUS

HHUS/HGUS

See Hanger Options information on pp. 125–127.



HHUS — Sloped and/or Skewed Seat

- HHUS hangers can be skewed to a maximum of 45° and/or sloped to a maximum of 45°
- For skew only, maximum factored down resistance is 0.85 of the table value
- For sloped only or sloped and skewed hangers, the maximum factored down resistance is 0.72 of the table value
- Uplift resistances for sloped/skewed conditions are 0.62 of the table value
- The joist must be bevel-cut to allow for double-shear nailing

HGUS — Skewed Seat

- HGUS hangers can be skewed only to a maximum of 45°. Factored resistances are:

HGUS Seat Width	Joist	Down Resistance	Uplift
$W < 2"$	Bevel or square cut	0.62 of table value	0.46 of table value
$2" < W < 6"$	Bevel cut	0.67 of table value	0.41 of table value
$2" < W < 6"$	Square cut	0.46 of table value	0.41 of table value
$W > 6"$	Bevel cut	0.75 of table value	0.41 of table value



Top View HHUS Hanger
Skewed Right
(joist must be bevel cut)
All joist nails installed on the
outside angle (non-acute side).

Standard and Double-Shear Joist Hangers (cont.)

These products are available with additional corrosion protection. For more information, see p. 24.

These products are approved for installation with the Strong-Drive® SD Connector screw. See pp. 32–34 for more information.

Plated Truss Connectors

Model No.	Ga.	Dimensions (in.)				Fasteners		Factored Resistance			
		W	H	B	d _g ³	Header	Joist	D.Fir-L		S-P-F	
								Uplift	Normal	Uplift	Normal
								(K _D = 1.15) lb.	(K _D = 1.00) lb.	(K _D = 1.15) lb.	(K _D = 1.00) lb.
Single 2x Sizes											
LUS24	18	1 1/8	3 1/4	1 1/4	2 1/4	(4) 10d	(2) 10d	710 3.16	1625 7.23	645 2.87	1155 5.14
LU24L	22	1 1/8	3	1 1/4	2 1/8	(4) 10d	(2) 10d x 1 1/2"	360 1.60	1020 4.54	320 1.42	725 3.22
LU26L	22	1 1/8	5	1 1/4	4%	(6) 10d	(4) 10d x 1 1/2"	720 3.20	1605 7.14	645 2.87	1140 5.07
LUS26	18	1 1/8	4%	1 1/4	3%	(4) 10d	(4) 10d	1420 6.32	2170 9.65	1290 5.74	1630 7.25
HUS26	16	1%	5%	3	3 3/8	(14) 16d	(6) 16d	2705 11.80	4940 21.97	2065 9.20	3875 17.24
LJS26DS	18	1 1/8	5	3 1/2	4%	(16) 16d	(6) 16d	2055 9.14	4265 18.97	1460 6.49	4115 18.31
HGUS26	12	1%	5%	5	4%	(20) 16d	(8) 16d	2685 11.96	6625 29.51	2685 11.96	5700 25.35
LU28L	20	1 1/8	6%	1 1/4	5%	(8) 10d	(6) 10d x 1 1/2"	1140 5.07	2185 9.72	1020 4.54	1550 6.89
LUS28	18	1 1/8	6%	1 1/4	3%	(6) 10d	(4) 10d	1420 6.32	2520 11.21	1290 5.74	1790 7.96
HUS28	16	1%	7 1/8	3	6 1/8	(22) 16d	(8) 16d	3605 16.04	5365 23.88	2675 11.90	4345 19.33
HGUS28	12	1%	7%	5	6%	(36) 16d	(12) 16d	3310 14.74	7675 34.19	3310 14.74	8900 30.73
LU210L	20	1 1/8	8	1%	7%	(10) 10d	(6) 10d x 1 1/2"	1140 5.07	2495 11.10	1020 4.54	1770 7.87
LUS210	18	1 1/8	7 1/8	1%	3%	(8) 10d	(4) 10d	1420 6.32	2785 12.39	1290 5.74	2210 9.83

1. Factored uplift resistances have been increased 15% for wind or earthquake loading; no further increase is allowed.
2. Designer must ensure that hanger is compatible with truss when reduced heel height is used.
3. d_g is the distance from the bearing seat to the top joist nail.
4. Resistances shown require a minimum 2-ply girder truss. For fastening to single-ply truss request technical bulletin T-C-N10TRUSSON and/or see installation notes.
5. Nails: 16d = 0.162" dia. x 3 1/2" long. See pp. 27–28 for other nail sizes and information.


Face-Mount Hangers

These products are available with additional corrosion protection. For more information, see p. 24.

These products are approved for installation with the Strong-Drive® SD Connector screw. See pp. 32-34 for more information.

Model No.	Ga.	Dimensions (in.)				Fasteners		Factored Resistance			
		W	H	B	d _o ¹	Header	Joist	D-Fir-L		S-P-F	
								Uplift	Normal	Uplift	Normal
								(K _D = 1.15)	(K _D = 1.00)	(K _D = 1.15)	(K _D = 1.00)
								lb.	lb.	lb.	lb.
								kN	kN	kN	kN
Double 2x Sizes											
LUS24-2	18	3 1/8	3 1/8	2	1 1/2	(4) 16d	(2) 16d	835	2020	590	1435
SS LUS26-2	18	3 1/8	4 1/8	2	4	(4) 16d	(4) 16d	3.71	8.99	2.62	6.38
								1720	2595	1545	1920
HHUS26-2	14	3 1/8	5 1/8	3	3 1/8	(14) 16d	(6) 16d	7.65	11.54	6.87	8.54
								2850	7335	2065	5205
HGUS26-2	12	3 1/8	5 1/8	4	4 1/8	(20) 16d	(8) 16d	12.68	32.63	9.20	23.15
								4385	8950	3110	6355
SS LUS28-2	18	3 1/8	7	2	4	(6) 16d	(4) 16d	19.51	39.81	13.83	28.27
								1720	3325	1545	2575
HHUS28-2	14	3 1/8	7 1/8	3	6 1/8	(22) 16d	(8) 16d	7.65	14.79	6.87	11.45
								3765	8940	2675	6345
HGUS28-2	12	3 1/8	7 1/8	4	6 1/8	(36) 16d	(12) 16d	16.75	39.77	11.90	28.22
								6070	12980	4310	9215
SS LUS210-2	18	3 1/8	9	2	6	(8) 16d	(6) 16d	27.00	57.74	19.17	40.99
								2580	4500	2320	3195
HHUS210-2	14	3 1/8	9 1/8	3	8	(30) 16d	(10) 16d	11.48	20.02	10.32	14.21
								4670	9660	4235	7000
HGUS210-2	12	3 1/8	9 1/8	4	8 1/8	(46) 16d	(16) 16d	20.77	42.97	18.84	31.14
								6840	14015	4855	10270
								30.43	62.34	21.60	45.69
Triple 2x Sizes											
HGUS26-3	12	4 1/8	5 1/8	4	4 1/8	(20) 16d	(8) 16d	4385	8950	3110	6355
								19.51	39.81	13.83	28.27
HGUS28-3	12	4 1/8	7 1/8	4	6 1/8	(36) 16d	(12) 16d	6070	12980	4310	9215
								27.00	57.74	19.17	40.99
HHUS210-3	14	4 1/8	9	3	7 1/8	(30) 16d	(10) 16d	4670	9670	4235	6965
								20.77	43.02	18.84	30.54
HGUS210-3	12	4 1/8	9 1/8	4	8 1/8	(46) 16d	(16) 16d	6840	14645	4855	10400
								30.43	65.14	21.60	46.26
Quadruple 2x Sizes											
HGUS26-4	12	6 1/8	5 1/8	4	4 1/8	(20) 16d	(8) 16d	4385	8950	3110	6355
								19.51	39.81	13.83	28.27
HGUS28-4	12	6 1/8	7 1/8	4	6 1/8	(36) 16d	(12) 16d	6070	12980	4310	9215
								27.00	57.74	19.17	40.99
HHUS210-4	14	6 1/8	8 1/8	3	7 1/8	(30) 16d	(10) 16d	4670	10155	4235	7210
								20.77	46.17	18.84	32.07
HGUS210-4	12	6 1/8	9 1/8	4	8 1/8	(46) 16d	(16) 16d	6840	14645	4855	10400
								30.43	65.14	21.60	46.26
HGUS212-4	12	6 1/8	10 1/8	4	10 1/8	(56) 16d	(20) 16d	7840	14995	5425	10645
								33.98	66.70	24.13	47.35
HGUS214-4	12	6 1/8	12 1/8	4	11 1/8	(66) 16d	(22) 16d	10130	16400	7195	11645
								45.06	72.95	32.00	51.80
4x Sizes											
LUS46	18	3 1/8	4 1/8	2	3 1/8	(4) 16d	(4) 16d	1720	2595	1545	1920
								7.65	11.54	6.87	8.54
HHUS46	14	3 1/8	5 1/8	3	3 1/8	(14) 16d	(6) 16d	2540	7335	2065	5205
								11.30	32.63	9.20	23.15
HGUS46	12	3 1/8	5 1/8	4	4 1/8	(20) 16d	(8) 16d	4385	8950	3110	6355
								19.51	39.81	13.83	28.27
LUS48	18	3 1/8	6 1/8	2	3 1/8	(6) 16d	(4) 16d	1720	3325	1545	2575
								7.65	14.79	6.87	11.45
HHUS48	14	3 1/8	7 1/8	3	6 1/8	(22) 16d	(8) 16d	3765	8940	2675	6345
								16.75	39.77	11.90	28.22
HGUS48	12	3 1/8	7 1/8	4	6 1/8	(36) 16d	(12) 16d	6070	12980	4310	9215
								27.00	57.74	19.17	40.99
LUS410	18	3 1/8	8 1/8	2	5 1/8	(8) 16d	(6) 16d	2580	4500	2320	3195
								11.48	20.02	10.32	14.21
HGUS410	12	3 1/8	9	4	8 1/8	(46) 16d	(16) 16d	6840	14015	4855	10270
								30.43	62.34	21.60	45.69
HGUS412	12	3 1/8	10 1/8	4	10 1/8	(56) 16d	(20) 16d	7840	14995	5425	10645
								33.98	66.70	24.13	47.35
HGUS414	12	3 1/8	12 1/8	4	11 1/8	(66) 16d	(22) 16d	10130	16400	7195	11645
								45.06	72.95	32.00	51.80

See footnotes on p. 258.



TC – Truss Connectors

SIMPSON
Strong-Tie

The TC truss connector is an ideal connector for scissor trusses and can allow horizontal movement up to 1 1/4". The TC also attaches plated trusses to top plates or sill plates to resist uplift forces. Typically used on one or both ends of truss as determined by the building designer.

Material: 16 gauge

Finish: G90 galvanized


Design: Factored resistances are in accordance with CSA 086-14

Installation:

- Use all specified fasteners.
- Nails: 10d = 0.148" dia. x 3" long common wire, 10d x 1 1/2" = 0.148" dia. x 1 1/2" long.
- Drive 10d nails into the truss at the inside end of the slotted holes (inside end is towards the centre of the truss) and clinch on the back side. Do not seat these nails into the truss—allow room under the nail head for movement of the truss with respect to the wall.


Optional TC Installation:

- Bend one flange up 90°. Drive specified nails into the top and face of the top plates or install Titen® screws into the top and face of masonry wall. See optional load tables and installation details.




TC24


U.S. Patent 4,932,173




TC26
(TC28 Similar)



Typical TC24 Installation



Optional TC26 Installation for Grouted Concrete Block using a Wood Nailer (8", 10", 12" Wall Installation Similar)



Optional TC26 Installation for Grouted Concrete Block using Titen Screws

Model No.	Fasteners		Factored Resistance	
	Truss	Wall Plates	D.Fir-L Uplift (K _u =1.15)	S-P-F Uplift (K _u =1.15)
			lb.	lb.
TC24	(4) 10d	(4) 10d	605	430
TC26	(5) 10d	(5) 10d	1015	720
TC28	(5) 10d	(5) 10d	1015	720

Optional TC Installation Table

Model No.	Fasteners		Factored Resistance	
	Truss	Wall Plates	D.Fir-L Uplift (K _u =1.15)	S-P-F Uplift (K _u =1.15)
			lb.	lb.
TC26	(5) 10d	(5) 10d x 1 1/2"	810	660
	(5) 10d	(5) 10d	930	660

1. Factored resistances have been increased 15% for earthquake or wind loading; no further increase allowed; reduce where other loads govern.
2. Grout strength is 15 MPa minimum.
3. Optional TC26 installation with 10d nails requires minimum 3" top plate thickness.
4. TC26 fastened to grouted concrete block with (8) - 3/4" x 2 1/4" Titen screws has a factored uplift resistance of 275 lb.



DESIGN
SIMPSON
STRONG-TIE

© 2017 Simpson Strong-Tie Company Inc. TSP081017-017, exp. 06/18

(800) 999-5099
strongtie.com

H/TSP

SIMPSON
Strong-Tie

Seismic and Hurricane Ties (cont.)

These products are available with additional corrosion protection. For more information, see p. 24.

These products are approved for installation with the Strong-Drive® SD Connector screw. See pp. 32-34 for more information.

Model No.	Ga.	Fasteners			Factored Resistance ($K_D = 1.15$)					
					D.Fir-L			S-P-F		
		To Rafters/ Truss	To Plates	To Studs	Uplift	Lateral		Uplift	Lateral	
						F ₁	F ₂		F ₁	F ₂
					lb.	lb.	lb.	lb.	lb.	lb.
					kN	kN	kN	kN	kN	kN
H1	18	(6) 8d x 1 1/2"	(4) 8d	—	740	685	300	680	485	215
					3.29	3.05	1.33	3.02	2.16	0.96
SS H2A	18	(5) 8d x 1 1/2"	(2) 8d x 1 1/2"	(5) 8d x 1 1/2"	830	220	75	590	155	55
					3.69	0.98	0.33	2.62	0.69	0.24
SS H2.5A	18	(5) 8d	(5) 8d	—	805	180	160	755	160	160
					3.58	0.71	0.71	3.36	0.71	0.71
H2.5T	18	(5) 8d	(5) 8d	—	835	175	210	740	160	210
					3.71	0.78	0.93	3.29	0.71	0.93
SS H3	18	(4) 8d	(4) 8d	—	740	180	265	615	125	190
					3.29	0.80	1.18	2.74	0.56	0.85
H6	16	—	(8) 8d	(8) 8d	1585	1085	—	1125	770	—
					7.05	4.83	—	5.00	3.43	—
H7Z	18	(4) 8d	(2) 8d	(8) 8d	1390	670	—	990	475	—
					6.18	2.98	—	4.40	2.11	—
SS H8 ³	18	(6) 10d x 1 1/2"	(5) 10d x 1 1/2"	—	1120	—	—	1025	—	—
					4.98	—	—	4.56	—	—
SS H10A ³	18	(9) 10d x 1 1/2"	(9) 10d x 1 1/2"	—	1735	795	410	1505	565	290
					7.72	3.54	1.82	6.69	2.51	1.29
H10AR	18	(9) 10d x 1 1/2"	(9) 10d x 1 1/2"	—	1485	690	430	1220	570	305
					6.61	3.07	1.91	5.43	2.54	1.36
H10A-2	18	(9) 10d x 1 1/2"	(9) 10d x 1 1/2"	—	1835	1275	430	1645	880	305
					8.16	5.67	1.91	7.32	3.91	1.36
H10S ^{7,8}	18	(6) 8d x 1 1/2"	(8) 8d x 1 1/2"	(8) 8d	1465	795	315	1040	565	225
					6.52	3.54	1.40	4.63	2.51	1.00
H11Z	18	(6) 16d x 2 1/2"	(6) 16d x 2 1/2"	—	1095	920	545	780	655	390
					4.87	4.09	2.42	3.47	2.91	1.73
H14	18	[1] (12) 8d x 1 1/2"	(13) 8d	—	2390	855	320	1805	610	230
		[2] (12) 8d x 1 1/2"	(15) 8d	—	10.63	3.80	1.42	8.03	2.71	1.02
					2390	855	320	1805	610	230
TSP	16	(9) 10d x 1 1/2"	(6) 10d x 1 1/2"	—	1295	440	—	920	310	—
		(9) 10d x 1 1/2"	(6) 10d	—	5.76	1.96	—	4.09	1.38	—
					1560	440	—	1105	310	—
					6.94	1.96	—	4.92	1.38	—

- Factored resistances have been increased 15% for short term loading; no further increase is allowed.
- Factored resistances are for one anchor. A minimum rafter thickness of 2 1/2" must be used when framing anchors are installed on the same side of the plate (exception: H2.5A).
- H8 factored uplift resistances for stud-to-bottom plate installations are 695 lb. (2.65 kN) for D.Fir-L and 390 lb. (1.74 kN) for S-P-F.
- When cross-grain bending or cross-grain tension cannot be avoided, mechanical reinforcement to resist such forces should be considered.
- Hurricane ties are shown installed on the outside of the wall for clarity. Installation on the inside of the wall is acceptable. For a continuous load path, connections at the top and bottom of the wall must be on the same side of the wall (see technical bulletin T-HTIECONPATH).
- Factored resistances in the F₁ direction are not intended to replace diaphragm boundary members or prevent cross grain bending of the truss or rafter members. Additional shear transfer elements shall be considered where there may be effects of cross grain bending or tension.

- H10S can have the stud offset a maximum of 1" from the rafter (centre to centre) for a reduced uplift of 1435 lb. (6.38 kN) D.Fir-L and 1015 lb. (4.51 kN) S-P-F.
- H10S nails to plates are optional for uplift but required for lateral loads.
- H10A may be field-bent up to a slope of 8/12. Multiply the tabulated uplift value x 0.75. Full tabulated lateral resistances apply.
- The factored resistances of stainless-steel connectors match carbon-steel connectors when installed with Simpson Strong-Tie® stainless-steel, SCNR ring-shank nails. For more information, refer to engineering letter L-F-SSNAILS at strongtie.com.
- D.Fir-L/S-P-F factored uplift resistances for the H2.5A fastened to a 2x4 truss bottom chord and double top plates using (6) 8d x 1 1/2" nails into the top plates and (3) 8d x 1 1/2" nails into the lowest three flange holes into the truss bottom chord is 495 lb. (2.20 kN).
- Nails: 16d x 2 1/2" = 0.162" dia. x 2 1/2" long, 10d = 0.148" dia. x 3" long, 10d x 1 1/2" = 0.148" dia. x 1 1/2" long, 8d = 0.131" dia. x 2 1/2" long, 8d x 1 1/2" = 0.131" dia. x 1 1/2" long. See pp. 27-28 for other nail sizes and information.



BEARING ANCHORAGE BY TOE-NAILS FOR LATERAL CAPACITY

B97791H1

NAIL TYPE	LENGTH (IN)	DIAMETER (IN)	NAIL LATERAL CAPACITY (LB)	
			S-P-F	D. FIR
COMMON WIRE	3.00	0.144	132	147
	3.25	0.144	132	147
	3.50	0.160	159	177
COMMON SPIRAL	3.00	0.122	97	108
	3.25	0.122	97	108
	3.50	0.152	145	162

NOTES:

1. Rafter and ceiling members may be anchored to top and bottom chords of girder truss by toe-nailing rafter and ceiling members to girder chords provided the reaction does not exceed the lateral capacities in the table. Hangers (specified by others) are required for reactions higher than the maximum toe-nail capacity. Reactions are based on factored loads.
2. Toe nail capacities shown in the table are for one toe-nail. For additional toe-nails multiply values in table by the number of toe-nails used. Toe-nail capacities take into account toe-nailing factor J_A in CSA O86-14, section 12.9.4.1.
3. For 9- 3/4 gauge 3.25" common wire gun nails (diameter = 0.120") use 3" common spiral nail values.
4. Maximum number of toe-nails allowed depends on the lumber size & species to be toe-nailed to supporting member and nail diameter, as shown in tables below.
5. Nail values in table are based on the following relative lumber densities: $G = 0.42$ (SPF), $G = 0.49$ (D. Fir).
6. Toe-nails shall be driven at approximately 1/3 the nail length from the edge of the joist/truss chord and driven at an angle of 30° to the grain of the member (See next page for nailing on bearing plate).
7. For loads due to wind the nail lateral capacity in this table may be multiplied by 1.15 (K_D factor).
8. Lumber must be dry ($< 19\%$ moisture content) at the time of nail installation.
9. Nail values in this table comply with CSA O86-14, section 12.9.4
10. This design is not valid after March 31, 2021.




TOE-NAIL INSTALLATION

Nail type	Common wire	Common spiral	Common wire	Common spiral
Nail dia. (in)	0.160	0.152	0.144	0.122
	(3.5" nail)		(3" and 3.25" nail)	
LUMBER SIZE	MAXIMUM NUMBER OF TOE-NAILS			
2X4 SPF	2	2	3	3
2X4 D. Fir	2	2	2	2
2X6 SPF	4	4	4	5
2X6 D. Fir	3	3	3	4

MiTek® MiTek Canada Inc
100 Industrial Rd.
Bradford, Ontario L3Z 3G7

December 2, 2019



BEARING ANCHORAGE BY TOE-NAILS FOR WIND LOADING

B97791H2



NAIL TYPE	LENGTH (IN)	DIAMETER (IN)	NAIL WITHDRAWAL CAPACITY (LB)	
			S-P-F	D. FIR
COMMON WIRE	3.00	0.144	30	42
	3.25	0.144	32	45
	3.50	0.160	38	52
COMMON SPIRAL	3.00	0.122	26	36
	3.25	0.122	28	40
	3.50	0.152	36	50

Note: If using truss with D. Fir lumber and S-P-F bearing plate, use values in table for S-P-F.



NOTES:

1. Truss chord, rafter, or ceiling members may be anchored to bearing plate by toe-nails, provided that the actual factored uplift force due to **wind** or **earthquake** load does not exceed the withdrawal capacities in the table. Hangers (specified by others) are required for uplift forces that are higher than the maximum toe-nail withdrawal capacity.
2. Toe nail capacities shown in the table are for **one** toe-nail. For additional toe-nails multiply values in table by the number of toe-nails used. Toe-nail capacities take into account toe-nailing factor J_A in CSA O86-14, section 12.9.5.2.
3. For 9- 3/4 gauge 3.25" common wire gun nails (diameter = 0.120") use 3" common spiral nail values.
4. Maximum number of toe-nails allowed depends on the lumber size & species to be toe-nailed to supporting member and nail diameter, as shown in table above.
5. Nail values in table are based on the following relative lumber densities: G = 0.42(SPF), G = 0.49(D. Fir).
6. Toe-nails shall be driven at approximately 1/3 the nail length from the edge of the joist/truss chord and driven at an angle of 30° to the grain of the member (See drawing on detail B37579H1).
7. Lumber must be dry (< 19% moisture content) at the time of nail installation.
8. Nail values in this table comply with CSA O86-14, section 12.9.5
9. This design is not valid after March 31, 2021.

Toe-nailing on 2x6 Bearing Plate



Toe-nailing on 2x4 Bearing Plate



PEO
Certificate No. 10869485




MiTek® MiTek Canada Inc
100 Industrial Rd.
Bradford, Ontario L3Z 3G7


December 2, 2019

Symbols

PLATE LOCATION AND ORIENTATION



Center plate on joint, unless x, y offsets are indicated. Dimensions are in ft-in-sixteenths or mm. Apply plates to both sides of truss and fully embed teeth.



For 4 x 2 orientation, locate plates 0-1/8" from outside edge of truss.



This symbol indicates the required direction of slots in connector plates.

*Plate location details available in MiTek software or upon request.

PLATE SIZE

4 x 4

The first dimension is the plate width measured perpendicular to slots. Second dimension is the length parallel to slots.

LATERAL BRACING LOCATION



Indicated by symbol shown and/or by text in the bracing section of the output. Use T, I or Eliminator bracing if indicated.

BEARING




Indicates location where bearings (supports) occur. Icons vary but reaction section indicates joint number where bearings occur.


Industry Standards:

TPIC: Truss Design Procedures and Specifications for Light Metal Plate Connected Wood Trusses
DSB-89: Design Standard for Bracing.
BCSI: Building Component Safety Information, Guide to Good Practice for Handling, Installing & Bracing of Metal Plate Connected Wood Trusses.

Numbering System



dimensions shown in ft-in-sixteenths or mm (Drawings not to scale)



JOINTS ARE GENERALLY NUMBERED/LETTERED CLOCKWISE AROUND THE TRUSS STARTING AT THE JOINT FARTHEST TO THE LEFT.

CHORDS AND WEBS ARE IDENTIFIED BY END JOINT NUMBERS/LETTERS.

PRODUCT CODE APPROVALS

CCMC Reports:

11996-L, 10319-L, 13270-L, 12691-R

© 2007 MiTek® All Rights Reserved

MiTek
POWER TO PERFORM.™

MiTek Engineering Reference Sheet: MII-7473C rev. 10-08

General Safety Notes

Failure to Follow Could Cause Property Damage or Personal Injury


1. Additional stability bracing for truss system, e.g. diagonal or X-bracing, is always required. See BCSI.
2. Truss bracing must be designed by an engineer. For wide truss spacing, individual lateral braces themselves may require bracing, or alternative T, I, or Eliminator bracing should be considered.
3. Never exceed the design loading shown and never stack materials on inadequately braced trusses.
4. Provide copies of this truss design to the building designer, erection supervisor, property owner and all other interested parties.
5. Cut members to bear tightly against each other.
6. Place plates on each face of truss at each joint and embed fully. Knots and wane at joint locations are regulated by TPIC.
7. Design assumes trusses will be suitably protected from the environment in accord with TPIC.
8. Unless otherwise noted, moisture content of lumber shall not exceed 19% at time of fabrication.
9. Unless expressly noted, this design is not applicable for use with fire retardant, preservative treated, or green lumber.
10. Camber is a non-structural consideration and is the responsibility of truss fabricator. General practice is to camber for dead load deflection.
11. Plate type, size, orientation and location dimensions indicated are minimum plating requirements.
12. Lumber used shall be of the species and size, and in all respects, equal to or better than that specified.
13. Top chords must be sheathed or purlins provided at spacing indicated on design.
14. Bottom chords require lateral bracing at 10 ft. spacing, or less, if no ceiling is installed, unless otherwise noted.
15. Connections not shown are the responsibility of others.
16. Do not cut or alter truss member or plate without prior approval of an engineer.
17. Install and load vertically unless indicated otherwise.
18. Use of green or treated lumber may pose unacceptable environmental, health or performance risks. Consult with project engineer before use.
19. Review all portions of this design (front, back, words and pictures) before use. Reviewing pictures alone is not sufficient.
20. Design assumes manufacture in accordance with TPIC Quality Criteria.

Overview:

Where piggybacks are connected ovetop of base trusses, 2x4 purlins must be first added to the flat portion of the base truss at a spacing no more than 24" o/c. These purlins not only provide support for the piggyback trusses above, but are required to laterally support the top chord of the base truss which will not have the sheathing directly connected to the flat portion of the base truss. This ensures the top chord, most often in compression, will not buckle laterally.

Further, the purlins in the plane of the flat portion require diagonal bracing to prevent lateral displacement of the purlins themselves where under certain conditions, the trusses may in fact all buckle in the same direction if this additional bracing is not added in the plane of the purlins.

Detail:



NOTE: THE SLOPED PORTION OF THE TOP CHORD OF THE BASE TRUSS AND PIGGYBACK TRUSS IN THIS SKETCH IS ASSUMED TO BE SHEATHED IN ACCORDANCE WITH THE OBC.

SKETCH FROM BCSI-CANADA 2013

Disclaimer:

OWTFA Tech Notes are intended to provide guidance to the design community both within the membership as well as to third party designers who might benefit from the information. The details have been developed by the OWTFA technical committee and although there may be professional engineers involved in development, the information contained in the tech-note are not intended to be used without having a professional engineer review the information for a specific application. The OWTFA takes no responsibility with respect to the information provided but has developed this tech-note to offer guidance where it is not currently readily available.



Alves Engineering Services Inc.

5208 Easton road
Burlington, Ontario L7L 6N6
(289) 259 5455

RESPONSABILITIES

- 1-Alves Engineering Services Inc. is responsible for the design of trusses as individual components
- 2-It is the responsibility of others to ascertain that the design loads utilized on this drawing meet or exceed the actual dead load imposed by the structure and the live load imposed by the local building code or the authorities having jurisdictions.
- 3- All dimensions are to be verified by owner, contractor, architect or other authority before manufacture.
- 4- Alves Engineering Services Inc. bears no responsibility for the erection of the trusses. Persons erecting trusses are cautioned to seek professional advice regarding temporary and permanent bracing system. Bracing shown on Alves Engineering Services Inc. drawings is specified for the truss as a single component and forms an integral part of the truss design, but is not meant to represent the only required bracing for that truss when trusses are installed in a series of trusses forming a roof truss system.
- 5- It is the manufactures responsibility to ensure that the trusses are manufactured in conformance with Alves Engineering Services Inc. specifications outlined below.

SPECIFICATIONS

- 1-Truss components sealed by Alves Engineering Services Inc. conform to the relevant sections of the current Building Code of Ontario and Canada (part 4 or part 9) or the current Canadian code for Farm Buildings in accordance with the application specified on the sealed truss component drawing. All truss component design procedures must conform to the current design standard issued by the truss plate institute of Canada (TPIC). All lumber and nailing stresses to conform to the current CSA wood design standard identified on the current Building Code and TPIC.
- 2- Lumber is to be the sizes and grade specified on the truss drawing.
- 3- Moist content of lumber is not to exceed 19% in service unless otherwise specified.
- 4- Plates shall be applied to both faces of the each truss joint and shall be positioned as shown on the truss drawings
- 5- Lumber used on manufacture of trusses is not to be treated with chemicals unless otherwise specified on the truss drawings.
- 6- The top chord is assumed to be continuously laterally braced by the roof sheathing or purlins at intervals specified on the truss drawing but not exceeding 24" c/c for (part 9) and not exceeding 48" for (part 4 or farm design)
- 7- When rigid ceiling is not attached directly to the bottom chord, lateral bracing is required and it should not exceed more than 3m or 10' intervals.
- 8-Refer to Mitek sheet MII7473C REV.10-08 attached for information on symbols, numbering system and General Safety notes.

T-1800213

Feb 09, 2018