

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 7
TYPE: MOUNTAINASH 6
GFA: 3401

DATE: Aug-20
LOS: 87170

WINTER NATURAL AIR CHANGE RATE 0.356
SUMMER NATURAL AIR CHANGE RATE 0.127

HEAT LOSS AT °F. 71
HEAT GAIN AT °F. 13

CSA-F280-12
SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	FLEX	WIC-3	ENS-3		
	34		9	9	8	34	33	26	9	11	8	6		
FACTORS														
GRS.WALL AREA	LOSS	GAIN	306	281	72	306	297	234	0	99	72	64		
GLAZING	LOSS	GAIN												
NORTH	19.8	15.1	0	0	0	0	0	0	0	0	0	0		
EAST	19.8	39.0	0	0	0	45	890	1758	64	1265	32	633	1249	0
SOUTH	19.8	23.5	0	0	0	0	0	0	11	217	258	0	0	7
WEST	19.8	39.0	32	633	1249	21	415	819	0	0	0	0	0	138
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	164
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	274	1136	206	226	937	179	72	298	54	251	1082	196
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	265	340	167	204	243	120	130	155	76	272	324	160
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	30	77	38	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	123	147	72	209	249	123
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	123	291	83	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2108		1872	453	2973	2834	438	831	1011	465		
SUB TOTAL HT GAIN			1622	1321	131	2235	3641	532	125	447	1342	260		
LEVEL FACTOR / MULTIPLIER	0.20	0.27		0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	
AIR CHANGE HEAT LOSS	561			498	121	792	754	361	117	221	289	121		
AIR CHANGE HEAT GAIN		111		90	9	153	208	36	55	31	92	18		
DUCT LOSS	0			0	0	377	359	0	85	0	128	0		
DUCT GAIN			0	0	0	299	385	0	50	0	180	0		
HEAT GAIN PEOPLE	240	2	480	0	0	1	240	1	0	0	0	0		
HEAT GAIN APPLIANCES/LIGHTS			365	365	365	365	365	365	365	365	365	365		
TOTAL HT LOSS BTU/H			2670	2370	574	4142	3947	1718	610	1053	1409	576		
TOTAL HT GAIN x 1.3 BTU/H			3351	2310	686	4279	5811	1625	713	1096	2873	835		

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department

FEB 05 2021

REC'D BY: DATE
REF'D TO: DATE

ROOM USE	EXP. WALL	CLG. HT.	L/D	FAM	K/B	L/H	LND	F-WIC	FOY	MUD				
	50		10	35	44	10	7	12	16	24				
FACTORS														
GRS.WALL AREA	LOSS	GAIN	500	350	440	100	63	120	160	254				
GLAZING	LOSS	GAIN												
NORTH	19.8	15.1	0	0	0	0	0	0	14	277	212	0	0	0
EAST	19.8	39.0	0	0	0	0	0	0	15	297	888	0	0	0
SOUTH	19.8	23.5	36	712	845	0	0	0	20	395	780	0	0	0
WEST	19.8	39.0	0	0	0	46	909	1796	33	682	1288	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	20	489	85	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	464	1924	349	304	1260	228	363	1605	273	82	340	62
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	29	35	17	0	0	0	126	150	74
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2636	2170	3135	696	621	732	1987	1481				
SUB TOTAL HT GAIN			1194	2023	2169	334	222	554	1227	268				
LEVEL FACTOR / MULTIPLIER	0.30	0.45		0.30	0.45	0.30	0.45	0.30	0.45	0.30	0.45	0.30	0.45	
AIR CHANGE HEAT LOSS	1220			1004	1451	322	139	338	910	685				
AIR CHANGE HEAT GAIN		82		138	147	23	15	45	84	18				
DUCT LOSS	0			0	0	0	0	0	0	0				
DUCT GAIN			0	0	0	0	0	0	0	0				
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0				
HEAT GAIN APPLIANCES/LIGHTS			365	365	365	365	365	365	365	365				
TOTAL HT LOSS BTU/H			3856	3174	4587	1018	609	1071	2877	2166				
TOTAL HT GAIN x 1.3 BTU/H			2133	3285	3474	939	783	922	1704	847				

TOTAL HEAT GAIN BTU/H: 42772

TONS: 1.56

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 57116

TOTAL COMBINED HEAT LOSS BTU/H: 58630

Michael O'Rourke

SITE NAME: RUSSEL GARDENS PHASE 3
 BUILDER: GREENPARK HOMES

 LOT 7
 TYPE: MOUNTAINASH 6

DATE: Aug-20

GFA: 3401 LO# 87170

 HEATING CFM 1504
 TOTAL HEAT LOSS 57,115
 AIR FLOW RATE CFM 26.33
 COOLING CFM 1504
 TOTAL HEAT GAIN 42,497
 AIR FLOW RATE CFM 35.39

 furnace pressure 0.6
 furnace filter 0.05
 a/c coil pressure 0.2
 available pressure for s/a & r/a 0.35

 #GOODMAN
 GMEC960804CNA 80
 FAN SPEED LOW 868
 MEDLOW 978
 MEDIUM 1112
 MEDIUM HIGH 1504
 HIGH 1615
 AFUE = 96 %
 INPUT (BTU/H) = 80,000
 OUTPUT (BTU/H) = 76,800
 DESIGN CFM = 1504
 CFM @ .6" E.S.P.
 TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	17	10	5
R/A	0	0	6	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

 plenum pressure s/a 0.18
 max s/a dif press. loss 0.02
 min adjusted pressure s/a 0.16
 r/a pressure 0.17
 r/a grille press. Loss 0.02
 adjusted pressure r/a 0.15

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	FLEX	WIC-3	MBR	ENS-3	L/D	FAM	K/B	K/B	L/H	LND	F-WIC	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.33	1.19	0.57	2.07	1.32	1.72	0.31	1.05	1.41	1.33	0.58	1.93	1.59	2.29	2.29	1.02	0.66	1.07	2.88	2.17	3.73	3.73	3.73	3.73
CFM PER RUN HEAT	35	31	15	55	35	45	8	28	37	35	15	51	42	60	60	27	17	28	76	57	98	98	98	98
RM GAIN MBH	1.68	1.15	0.66	2.14	1.84	1.52	0.36	1.10	2.57	1.68	0.84	1.07	1.64	1.74	1.74	0.94	0.78	0.92	1.70	0.85	1.11	1.11	1.11	1.11
CFM PER RUN COOLING	59	41	23	76	65	54	13	39	91	59	30	38	58	61	61	33	28	33	60	30	39	39	39	39
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	37	35	22	65	67	49	44	34	56	26	45	35	26	31	24	19	49	53	46	23	38	40	33	33
EQUIVALENT LENGTH	120	150	160	150	200	190	170	150	160	140	180	120	110	140	130	100	180	140	130	120	150	160	120	180
TOTAL EFFECTIVE LENGTH	157	185	182	215	267	239	214	184	216	166	225	155	136	171	154	119	229	193	176	143	188	200	153	213
ADJUSTED PRESSURE	0.11	0.09	0.09	0.08	0.06	0.07	0.08	0.09	0.08	0.1	0.08	0.11	0.13	0.1	0.11	0.14	0.08	0.09	0.1	0.12	0.09	0.08	0.11	0.08
ROUND DUCT SIZE	5	4	4	6	6	5	4	4	6	5	4	4	4	5	5	4	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	257	356	172	280	178	330	92	321	189	257	172	585	482	441	441	310	195	321	558	419	500	500	500	500
COOLING VELOCITY (ft/min)	433	470	264	388	331	396	149	447	464	433	344	436	665	448	448	379	321	379	441	220	199	199	199	199
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	D	F	F	C	A	C	B	C	B	D	C	B	F	D	F	C	A	A	F	F	D	C	A	A

RUN #	25	26	27	28	29	30	31	32
ROOM NAME	BED-2	BED-3	ENS	S-ENS	FAM	L/D	BAS	BED-3
RM LOSS MBH	2.07	1.32	1.19	0.31	1.59	1.93	3.73	1.32
CFM PER RUN HEAT	55	35	31	8	42	51	98	35
RM GAIN MBH	2.14	1.84	1.15	0.36	1.64	1.07	1.11	1.84
CFM PER RUN COOLING	76	65	41	13	58	38	39	65
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17
ACTUAL DUCT LGH.	60	74	30	40	14	49	46	70
EQUIVALENT LENGTH	180	200	120	180	150	170	160	200
TOTAL EFFECTIVE LENGTH	240	274	150	220	164	219	206	270
ADJUSTED PRESSURE	0.07	0.06	0.11	0.08	0.1	0.08	0.08	0.06
ROUND DUCT SIZE	6	6	4	4	5	6	6	6
HEATING VELOCITY (ft/min)	280	178	356	92	308	374	500	178
COOLING VELOCITY (ft/min)	388	331	470	149	426	279	199	331
OUTLET GRILL SIZE	4X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10
TRUNK	B	A	F	B	F	A	A	A

 CITY OF HAMILTON
 BUILDING DIVISION
 Planning & Construction Department

FEB 05 2021

 REC'D BY DATE
 REC'D TO DATE

SUPPLY AIR TRUNK SIZE								RETURN AIR TRUNK SIZE							
TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK
CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM
TRUNK A	456	0.06	11.2	14	x	8	586	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	615	0.06	12.6	18	x	8	615	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	873	0.06	14.3	24	x	8	655	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	288	0.08	8.8	10	x	8	518	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	1161	0.06	15.9	30	x	8	697	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	343	0.09	9.1	10	x	8	617	TRUNK L	0	0.00	0	0	x	8	0
RETURN AIR #								BR							
1	2	3	4	5	6	7	8	9	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
AIR VOLUME	75	75	135	115	75	75	185	400	135	0	0	0	0	0	234
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	68	68	57	74	67	69	21	23	38	1	1	1	1	1	17
EQUIVALENT LENGTH	245	235	215	235	220	215	155	160	285	0	0	0	0	0	145
TOTAL EFFECTIVE LH	313	303	272	309	287	284	176	183	323	1	1	1	1	1	162
ADJUSTED PRESSURE	0.05	0.05	0.05	0.05	0.05	0.05	0.08	0.08	0.05	14.80	14.80	14.80	14.80	14.80	0.09
ROUND DUCT SIZE	6	6	7.5	7	6	6	7.5	9.9	7.5	0	0	0	0	0	7.9
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	0	0	0	0	0	8
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	14	14	30	14	0	0	0	0	0	24

TYPE: MOUNTAINASH 6
 SITE NAME: RUSSEL GARDENS PHASE 3

 LO # 87170
 LOT 7

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒	Forced Air
☐	Non Forced Air
☐	Electric Space Heat

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	6 @ 10.6 cfm	63.6 cfm
Other Rooms	9 @ 10.6 cfm	95.4 cfm
Table 9.32.3.A.	TOTAL	233.2 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.6	cfm
5 Bedroom	95.4	cfm
TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	233.2	cfm
Less Principal Ventil. Capacity	79.6	cfm
Required Supplemental Capacity	153.7	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANE 65H	Location: BSMT
79.5 cfm	3.0 sones
☒	HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	X 71 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
S-ENS	FV-05-11VK1	50	☒	0.3
ENS-3	FV-05-11VK1	50	☒	0.3
F-WIC	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANE 65H		
155 cfm high	64 cfm low	
75 % Sensible Efficiency	☒	HVI Approved
@ 32 deg F (0 deg C)		


LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit
BUILDER: GREENPARK HOMES	CITY OF HAMILTON BUILDING DIVISION
Name:	Planning & Development Department
Address:	FEB 05 2021
City:	
Telephone #:	REC'D BY DATE
	REF'D TO Fax #: DATE

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	August-20

 I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
 INDIVIDUAL BCIN: 19569 *Michael O'Rourke* MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 87170	Model: MOUNTAINASH 6	Builder: GREENPARK HOMES	Date: 8/11/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1486</td> <td>8</td> <td>11888</td> </tr> <tr> <td>First</td> <td>1486</td> <td>10</td> <td>14860</td> </tr> <tr> <td>Second</td> <td>1915</td> <td>9</td> <td>17235</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>43,983.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1245.5 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1486	8	11888	First	1486	10	14860	Second	1915	9	17235	Third	0	9	0	Fourth	0	9	0	Total:			43,983.0 ft³	Total:			1245.5 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.356</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.127</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>T_{in} °C</th> <th>T_{out} °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTD_h</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-17</td> <td style="text-align: center;">39</td> <td style="text-align: center;">71</td> </tr> <tr> <td>Summer DTD_c</td> <td style="text-align: center;">24</td> <td style="text-align: center;">31</td> <td style="text-align: center;">7</td> <td style="text-align: center;">13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.356	SUMMER NATURAL AIR CHANGE RATE	0.127	Design Temperature Difference						T _{in} °C	T _{out} °C	ΔT °C	ΔT °F	Winter DTD _h	22	-17	39	71	Summer DTD _c	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1486	8	11888																																																									
First	1486	10	14860																																																									
Second	1915	9	17235																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			43,983.0 ft³																																																									
Total:			1245.5 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.356																																																											
SUMMER NATURAL AIR CHANGE RATE	0.127																																																											
Design Temperature Difference																																																												
	T _{in} °C	T _{out} °C	ΔT °C	ΔT °F																																																								
Winter DTD _h	22	-17	39	71																																																								
Summer DTD _c	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.356 x 345.96 x 39 °C x 1.2 = 5795 W = 19772 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.127 x 345.96 x 7 °C x 1.2 = 376 W = 1283 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{valrb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vailrb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HL_{airve} Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HL_{airbv} / HL_{level})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center; vertical-align: middle;">19,772</td> <td style="text-align: center;">8,755</td> <td style="text-align: center;">1.129</td> </tr> <tr> <td>2</td> <td>0.3</td> <td style="text-align: center;">12,815</td> <td style="text-align: center;">0.463</td> </tr> <tr> <td>3</td> <td>0.2</td> <td style="text-align: center;">14,854</td> <td style="text-align: center;">0.266</td> </tr> <tr> <td>4</td> <td>0</td> <td style="text-align: center;">0</td> <td style="text-align: center;">0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td style="text-align: center;">0</td> <td style="text-align: center;">0.000</td> </tr> </tbody> </table> *HL_{airbv} = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HL_{airve} = 0					Level	Level Factor (LF)	HL _{airve} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})	1	0.5	19,772	8,755	1.129	2	0.3	12,815	0.463	3	0.2	14,854	0.266	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HL _{airve} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})																																																								
1	0.5	19,772	8,755	1.129																																																								
2	0.3		12,815	0.463																																																								
3	0.2		14,854	0.266																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								



HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: MOUNTAINASH 6	LOT 7	BUILDER: GREENPARK HOMES
SFQT: 3401	LO# 87170	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	43983.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.0 ft
LENGTH: 55.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	126.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	56.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component**

Ceiling with Attic Space Minimum RSI (R)-Value	
Ceiling Without Attic Space Minimum RSI (R)-Value	
Exposed Floor Minimum RSI (R)-Value	
Walls Above Grade Minimum RSI (R)-Value	
Basement Walls Minimum RSI (R)-Value	
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	
Windows and Sliding Glass Doors Maximum U-Value	
Skylights Maximum U-Value	
Space Heating Equipment Minimum AFUE	
HRV Minimum Efficiency	
Domestic Hot Water Heater Minimum EF	

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department

FEB 05 2021

REC'D BY _____ DATE _____

REF'D TO _____ DATE _____

Compliance Package**A1**


Nominal	Min. Eff.
60	59.22
31	27.65
31	29.80
22	17.03
20 ci	21.12
-	-
10	10
10	11.13
0.28	-
0.49	-
0.96	-
75%	-
0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE

Michael O'Rourke

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	6.1	 Insulation Configuration
Floor Width (m):	11.0	
Exposed Perimeter (m):	38.4	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.32	
Window Area (m ²):	0.9	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	742	


TYPE: MOUNTAINASH 6
LO# 87170

LOT 7

CITY OF HAMILTON BUILDING DIVISION Planning & Development Department	
FEB 05 2021	
REC'D BY _____	DATE _____
REF'D TO _____	DATE _____

Residential Slab on Grade Thermal Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	3.0	 Insulation Configuration
Width (m):	11.0	
Exposed Perimeter (m):	17.1	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		234

TYPE: MOUNTAINASH 6
LO# 87170

LOT 7

CITY OF HAMILTON BUILDING DIVISION Planning & Development Department	
FEB 05 2021	
REC'D BY _____	DATE _____
REF'D TO _____	DATE _____



HVAC Designs Ltd.
375 Finley Ave, Suite 202
Ajax ON, L1S 2E2
905-619-2300


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.23			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1245.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1660.2 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.356			
Cooling Air Leakage Rate (ACH/H):	0.127			

TYPE: MOUNTAINASH 6
LO# 87170

LOT 7



I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.3 OF THE BUILDING CODE

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department

FEB 05 2021

REC'D BY _____ DATE _____
REF'D TO _____ DATE _____

CITY OF HAMILTON
Building Division

Permit No. 21-102430

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by
Ken Smith Feb 24, 2021
FOR CHIEF BUILDING OFFICIAL DATE

WOB

LOT 7

CSA-F280-12

PACKAGE A1

HVAC LEGEND						3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER
							REVISIONS
No.	Description	Date					

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO

LOT 7
MOUNTAINASH 6 3401 sqft

HVACDESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper.
Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.


Sheet Title
FIRST FLOOR
HEATING
LAYOUT

Date
APRIL/2020

Scale
3/16" = 1'-0"

BCIN# 19669

LO# 87170



I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, License # 19669
HVAC DESIGNS LTD.

CITY OF HAMILTON
BUILDING DEPARTMENT
Planning & Development Services Unit
FEB 05 2021
REC'D BY _____ DATE _____
REF'D TO _____ DATE _____

CITY OF HAMILTON
Building Division
Permit No. 21-102430
THESE DRAWINGS AND LOGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
These drawings and/or specifications have been reviewed by
Ken Smith Feb 24, 2021
FOR CHIEF BUILDING OFFICIAL DATE

WOB
LOT 7
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.6300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date APRIL/2020	
LOT 7 MOUNTAINASH 6 3401 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 87170	