

SITE NAME: RUSSEL GARDENS PHASE 3				LOT 181				DATE: Dec-20				WINTER NATURAL AIR CHANGE RATE 0.314				HEAT LOSS AT °F. 71				CSA-F280-12							
BUILDER: GREENPARK HOMES				TYPE: MOUNTAINASH 5				GFA: 3288				LO# 88537				SUMMER NATURAL AIR CHANGE RATE 0.113				HEAT GAIN ΔT °F. 13				SB-12 PACKAGE A1			
ROOM USE		MBR		ENS		WIC		BED-2		BED-3		BED-4		ENS-2		FLEX		WIC-3		S-ENS		CITY OF HAMILTON BUILDING DEPARTMENT RECEIVED 2021 JUL 21		RECEIVED 2021 JUL 21			
EXP. WALL		33		30		7		27		37		12		6		11		5		6							
CLG. HT.		9		9		9		9		9		9		9		9		9		9							
FACTORS		297		270		63		243		333		108		54		99		45		64							
GRS.WALL AREA		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN							
GLAZING		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN							
NORTH		19.8	16.0	0	0	0	14	277	224	0	0	0	0	0	0	0	7	138	112	16	316	256	0	0	0		
EAST		19.8	41.6	0	0	0	0	0	0	0	36	712	1496	41	810	1704	0	0	0	0	9	178	374	0	0	0	
SOUTH		19.8	24.9	0	0	0	0	0	0	0	0	0	0	0	0	0	16	316	398	0	0	0	0	0	0		
WEST		19.8	41.6	32	633	1330	14	277	582	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SKYLT.		34.6	191.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
DOORS		23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
NET EXPOSED WALL		4.1	0.8	265	1099	199	242	1003	182	63	261	47	207	858	156	292	1211	219	92	381	69	47	195	35	47	195	
NET EXPOSED BSMT WALL ABOVE GR		3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
EXPOSED CLG		1.2	0.6	287	342	169	221	263	130	140	167	82	236	281	139	183	218	108	180	215	106	66	79	39	220	262	
NO ATTIC EXPOSED CLG		2.6	1.3	0	0	0	0	0	0	0	0	0	16	41	20	45	115	57	0	0	0	0	0	0	0		
EXPOSED FLOOR		2.4	0.4	0	0	0	0	0	0	0	0	0	241	571	104	0	0	0	0	0	68	161	29	69	163		
BASEMENT/CRAWL HEAT LOSS				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SLAB ON GRADE HEAT LOSS				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SUBTOTAL HT LOSS				2073		1820		428		2463		2354		912		573		573		1086		470		442			
SUB TOTAL HT GAIN					1697		1117		130		1914		2087		573		215		477		442		252				
LEVEL FACTOR / MULTIPLIER		0.20	0.26			0.20	0.26			0.20	0.26			0.20	0.26			0.20	0.26			0.20	0.26				
AIR CHANGE HEAT LOSS				544		478		112		647		518		240		159		285		123		110					
AIR CHANGE HEAT GAIN					130		86		10		147		160		44		17		37		34		19				
DUCT LOSS				0		0		0		311		0		0		72		137		59		0					
DUCT GAIN				0		0		0		290		0		0		23		112		48		0					
HEAT GAIN PEOPLE		240		2		480		0		0		1		240		1		240		0		0		0			
HEAT GAIN APPLIANCES/LIGHTS						603		0		0		603		603		603		603		603		0		0			
TOTAL HT LOSS BTU/H				2618		2298		541		3421		2972		1152		796		1508		652		529		353			
TOTAL HT GAIN x 1.3 BTU/H				3784		1564		181		4153		4018		1899		331		1597		680		353					

ROOM USE			FAM		L/D		K/B		L/H		LND		W/R		FOY		MUD								BAS		
EXP. WALL			36		30		37		19		12		18		18		30								184		
CLG. HT.			11		11		11		11		9		11		11		12								8		
GRS.WALL AREA	FACTORS		396		330		407		208		108		198		198		360								1012		
GLAZING	LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN								LOSS GAIN		
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	7	138	112				5	99	80	
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0	0	23	455	956	8	158	332	0	0	0			0	0	0	
SOUTH	19.8	24.9	0	0	0	40	791	996	8	0	0	13	257	324	7	138	174	0	0	0	0	0	0	10	198	249	
WEST	19.8	41.6	40	791	1662	0	0	0	60	1185	2493	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	40	938	170	0	0	0			20	489	85	
NET EXPOSED WALL	4.1	0.8	356	1476	268	290	1202	218	347	1439	261	186	813	147	101	419	76	175	725	113	353	1463	265		0	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	450	1538	279	
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	0	0	0	180	215	106	0	0	0	0	0	0	0	0	0	
NO ATTIC EXPOSED CLG	2.6	1.3	10	26	13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS																										5842	
SLAB ON GRADE HEAT LOSS																											
SUBTOTAL HT LOSS				2292			1993			2625			1070			772		1180			1602					8145	
SUB TOTAL HT GAIN					1942				1214		2754			471		356		1087		615		377				693	
LEVEL FACTOR / MULTIPLIER		0.30	0.42			0.30	0.42			0.30	0.42		0.20	0.26		0.30	0.42		0.30	0.42				0.50	1.08		
AIR CHANGE HEAT LOSS				967			841				1108			451			203		498		725					8778	
AIR CHANGE HEAT GAIN					149			93			212			36			27		84		47					53	
DUCT LOSS				0			0			0				0			0		0		0				0		
DUCT GAIN				0			0			0				0			0		0		0				0		
HEAT GAIN PEOPLE	240		0		0		0		0		0		0	0		0	0		0		0			0		0	
HEAT GAIN APPLIANCES/LIGHTS					803		603			603			603			603		0		0		0			0	0	
TOTAL HT LOSS BTU/H				3260			2834			3732			1521			974		1678		2443		2278				16924	
TOTAL HT GAIN x 1.3 BTU/H				3503			2484			4639			1444			1283		1522		861		528				970	

TOTAL HEAT GAIN BTU/H: 36068

TONS: 3.01

LOSS DUE TO VENTILATION LOAD BTU/H: 1516

STRUCTURAL HEAT LOSS: 52131

TOTAL COMBINED HEAT LOSS BTU/H: 53647

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMESLOT 181
TYPE: MOUNTAINASH 5

DATE: Dec-20

GFA: 3288 LO# 88537

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 52,131 TOTAL HEAT GAIN 35,794
AIR FLOW RATE CFM 21.7 AIR FLOW RATE CFM 31.6furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MED LOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600DESIGN CFM = 1131
CFM @ .5" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	15	8	4
R/A	0	0	6	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5'Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	ENS-2	FLEX	WIC-3	MBR	S-ENS	FAM	L/D	K/B	K/B	L/H	LND	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.31	1.15	0.54	1.71	1.49	1.15	0.80	1.51	0.65	1.31	0.53	3.26	2.83	1.87	1.87	1.52	0.97	1.68	2.44	2.28	4.23	4.23	4.23	4.23
CFM PER RUN HEAT	28	25	12	37	32	25	17	33	14	28	11	71	61	40	40	33	21	36	53	49	92	92	92	92
RM GAIN MBH	1.89	0.78	0.18	2.08	2.01	1.90	0.33	1.60	0.68	1.89	0.35	3.50	2.48	2.32	2.32	1.44	1.28	1.52	0.86	0.53	0.24	0.24	0.24	0.24
CFM PER RUN COOLING	60	25	6	66	63	60	10	50	21	60	11	111	78	73	73	46	41	48	27	17	8	8	8	8
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.15	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	37	56	39	59	56	34	34	51	45	38	39	22	10	40	31	27	20	33	41	44	38	19	5	31
EQUIVALENT LENGTH	190	160	150	130	170	200	220	160	110	130	150	140	130	150	160	140	180	110	90	140	140	120	140	130
TOTAL EFFECTIVE LENGTH	227	216	189	189	226	234	254	211	155	169	189	162	140	190	191	167	200	143	131	184	178	139	145	161
ADJUSTED PRESSURE	0.08	0.08	0.09	0.09	0.08	0.07	0.07	0.08	0.11	0.1	0.09	0.09	0.12	0.09	0.09	0.1	0.09	0.12	0.13	0.09	0.09	0.12	0.11	0.1
ROUND DUCT SIZE	5	4	4	5	5	6	4	6	4	5	4	6	6	5	5	5	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	206	287	138	272	235	127	195	168	161	206	126	362	311	294	294	242	241	413	389	360	469	469	469	469
COOLING VELOCITY (ft/min)	441	287	69	485	463	306	115	255	241	441	126	566	398	536	536	338	470	551	198	125	41	41	41	41
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	4X10	3X10	4X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	B	A	B	D	C	C	C	A	D	B	D	B	D	A	A	C	B	C	C	A	A	B	D	C

RUN #	25	26	27
ROOM NAME	BED-2	BED-3	ENS
RM LOSS MBH	1.71	1.49	1.15
CFM PER RUN HEAT	37	32	25
RM GAIN MBH	2.08	2.01	0.78
CFM PER RUN COOLING	66	63	25
ADJUSTED PRESSURE	0.17	0.17	0.17
ACTUAL DUCT LGH.	52	48	52
EQUIVALENT LENGTH	120	170	130
TOTAL EFFECTIVE LENGTH	172	218	182
ADJUSTED PRESSURE	0.1	0.08	0.09
ROUND DUCT SIZE	5	5	4
HEATING VELOCITY (ft/min)	272	235	287
COOLING VELOCITY (ft/min)	485	463	287
OUTLET GRILL SIZE	3X10	3X10	3X10
TRUNK	D	C	A

SUPPLY AIR TRUNK SIZE															RETURN AIR TRUNK SIZE									
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)	
TRUNK A	304	0.08	9	10	X	8	547	TRUNK G	0	0.00	0	0	X	8	0	TRUNK Q	0	0.05	0	0	X	8	0	
TRUNK B	556	0.08	11.3	14	X	8	715	TRUNK H	0	0.00	0	0	X	8	0	TRUNK P	0	0.05	0	0	X	8	0	
TRUNK C	320	0.07	9.5	10	X	8	576	TRUNK I	0	0.00	0	0	X	8	0	TRUNK R	0	0.05	0	0	X	8	0	
TRUNK D	572	0.07	11.8	16	X	8	644	TRUNK J	0	0.00	0	0	X	8	0	TRUNK S	0	0.05	0	0	X	8	0	
TRUNK E	0	0.00	0	0	X	8	0	TRUNK K	0	0.00	0	0	X	8	0	TRUNK T	0	0.05	0	0	X	8	0	
TRUNK F	0	0.00	0	0	X	8	0	TRUNK L	0	0.00	0	0	X	8	0	TRUNK U	0	0.05	0	0	X	8	0	
															TRUNK V	0	0.05	0	0	X	8	0		
															TRUNK W	0	0.05	0	0	X	8	0		
RETURN AIR #	1	2	3	4	5	6	7	8	0	0	0	0	0	0	BR	TRUNK X	1036	0.05	16	30	X	8	622	
AIR VOLUME	95	85	95	95	85	75	350	85	0	0	0	0	0	0	166	TRUNK Y	690	0.05	13.7	22	X	8	565	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	TRUNK Z	435	0.05	11.6	16	X	8	489	
ACTUAL DUCT LGH.	41	52	53	58	53	59	45	41	1	1	1	1	1	1	15	DROP	1131	0.05	16.5	24	X	10	679	
EQUIVALENT LENGTH	185	195	165	165	215	265	165	190	0	0	0	0	0	0	150									
TOTAL EFFECTIVE LH	226	247	218	223	268	324	210	231	1	1	1	1	1	1	165									
ADJUSTED PRESSURE	0.07	0.06	0.07	0.07	0.06	0.05	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	0.09									
ROUND DUCT SIZE	6	6	6	6	6	6	9.8	6	0	0	0	0	0	0	6.9									
INLET GRILL SIZE	8	8	8	8	8	8	8	8	0	0	0	0	0	0	8									
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
INLET GRILL SIZE	14	14	14	14	14	14	30	14	0	0	0	0	0	0	14									

TYPE: MOUNTAINASH 5
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 88537
LOT 181

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY
COMBUSTION APPLIANCES 9.32.3.1(1)
a) ☒ Direct vent (sealed combustion) only
b) ☐ Positive venting Induced draft (except fireplaces)
c) ☐ Natural draft, B-vent or induced draft gas fireplace
d) ☐ Solid Fuel (including fireplaces)
e) ☐ No Combustion Appliances

HEATING SYSTEM
☒ Forced Air ☐ Non Forced Air
☐ Electric Space Heat

HOUSE TYPE 9.32.1(2)
☒ I Type a) or b) appliance only, no solid fuel
☐ II Type I except with solid fuel (including fireplaces)
☐ III Any Type c) appliance
☐ IV Type I, or II with electric space heat
☐ Other: Type I, II or IV no forced air

SYSTEM DESIGN OPTIONS O.N.H.W.P.
☐ 1 Exhaust only/Forced Air System
☐ 2 HRV with Ducting/Forced Air System
☒ 3 HRV Simplified/connected to forced air system
☐ 4 HRV with Ducting/non forced air system
☐ Part 6 Design

TOTAL VENTILATION CAPACITY 9.32.3.3(1)

Basement + Master Bedroom	2	@ 21.2 cfm	42.4	cfm
Other Bedrooms	3	@ 10.6 cfm	31.8	cfm
Kitchen & Bathrooms	5	@ 10.6 cfm	53	cfm
Other Rooms	8	@ 10.6 cfm	84.8	cfm
Table 9.32.3.A.		TOTAL	212.0	cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4.(1)

1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.5.

Total Ventilation Capacity	212	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	132.5	cfm

PRINCIPAL EXHAUST FAN CAPACITY
Model: VANEE 65H Location: BSMT
79.5 cfm 3.0 sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION

CFM	ΔT °F	FACTOR	% LOSS
79.6 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS PANASONIC

Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	✓	0.3
ENS-2	FV-05-11VK1	50	✓	0.3
S-ENS	FV-05-11VK1	50	✓	0.3
W/R	FV-05-11VK1	50	✓	0.3

HEAT RECOVERY VENTILATOR 9.32.3.11.
Model: VANEE 65H
155 cfm high 64 cfm low
75 % Sensible Efficiency @ 32 deg F (0 deg C) ☒ HVI Approved

LOCATION OF INSTALLATION
Lot: Concession
Township: Plan:
Address:
Roll # Building Permit #

BUILDER: GREENPARK HOMES
Name:
Address:
City:
Telephone #: Fax #:

INSTALLING CONTRACTOR
Name:
Address:
City:
Telephone #: Fax #:

DESIGNER CERTIFICATION
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.
Name: HVAC Designs Ltd.
Signature: *Michael O'Rourke*
HRAI # 001820
Date: December-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 88537	Model: MOUNTAINASH 5	Builder: GREENPARK HOMES	Date: 07/12/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1452</td> <td>8</td> <td>11616</td> </tr> <tr> <td>First</td> <td>1452</td> <td>11</td> <td>15972</td> </tr> <tr> <td>Second</td> <td>1846</td> <td>9</td> <td>16614</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>44,202.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1251.7 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1452	8	11616	First	1452	11	15972	Second	1846	9	16614	Third	0	9	0	Fourth	0	9	0	Total:			44,202.0 ft³	Total:			1251.7 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.314</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.113</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-17</td> <td style="text-align: center;">39</td> <td style="text-align: center;">71</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">24</td> <td style="text-align: center;">31</td> <td style="text-align: center;">7</td> <td style="text-align: center;">13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.314	SUMMER NATURAL AIR CHANGE RATE	0.113	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1452	8	11616																																																									
First	1452	11	15972																																																									
Second	1846	9	16614																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			44,202.0 ft³																																																									
Total:			1251.7 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.314																																																											
SUMMER NATURAL AIR CHANGE RATE	0.113																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-17	39	71																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.314 x 347.68 x 39 °C x 1.2 = 5146 W = 17557 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.113 x 347.68 x 7 °C x 1.2 = 334 W = 1140 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	17,557	8,145	1.078																																																								
2	0.3		12,479	0.422																																																								
3	0.2		13,370	0.263																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL:	MOUNTAINASH 5	LOT 181	BUILDER:	GREENPARK HOMES
SFQT:	3288	LO#	88537	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	44202.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.5 ft
LENGTH: 55.0 ft	WIDTH: 37.0 ft	EXPOSED PERIMETER:	184.0 ft


2012 OBC - COMPLIANCE PACKAGE		Compliance Package A1	
Component		Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value		60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value		31	27.65
Exposed Floor Minimum RSI (R)-Value		31	29.80
Walls Above Grade Minimum RSI (R)-Value		22	17.03
Basement Walls Minimum RSI (R)-Value		20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value		-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value		10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value		10	11.13
Windows and Sliding Glass Doors Maximum U-Value		0.28	-
Skylights Maximum U-Value		0.49	-
Space Heating Equipment Minimum AFUE		0.96	-
HRV Minimum Efficiency		75%	-
Domestic Hot Water Heater Minimum EF		0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE

Michael O'Rourke

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.8	
Floor Width (m):	11.3	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.68	
Window Area (m ²):	1.4	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1712	

TYPE: MOUNTAINASH 5
LO# 88537

LOT 181


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.86			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1251.7			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1668.5 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.314			
Cooling Air Leakage Rate (ACH/H):	0.113			

TYPE: MOUNTAINASH 5
LO# 88537

LOT 181



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.


Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

LOT 181
CSA-F280-12
PACKAGE A1

HVAC LEGEND								REVISIONS	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.	
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.	
								No.	Description

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 53647 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title BASEMENT HEATING LAYOUT
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			MAKE GOODMAN	3RD FLOOR				
		MODEL GMEC960603BNA	2ND FLOOR		15	6	4	
		INPUT 60 MBTU/H	1ST FLOOR		8	2	3	
		OUTPUT 57.6 MBTU/H	BASEMENT		4	1	0	
LOT 181 MOUNTAINASH 5 3288 sqft		COOLING 3.0 TONS	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A					Date DEC/2020
		FAN SPEED 1131 cfm @ 0.6" w.g.						Scale 3/16" = 1'-0"
							BCIN# 19669	
				LO# 88537				




LOT 181
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEW
AND TAKE RESPONSIBILITY FOR THE
DESIGN WORK AND AM QUALIFIED
UNDER DIVISION C.3.2.5 OF THE
BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND							3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No. Description Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND
USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE
USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE
ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	FIRST FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date DEC/2020	Scale 3/16" = 1'-0"
LOT 181 MOUNTAINASH 5 3288 sqft.		Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	BCIN# 19669	
			LO#	88537



SECOND FLOOR PLAN '1'

LOT 181
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEW
AND TAKE RESPONSIBILITY FOR THE
DESIGN WORK AND AM QUALIFIED
UNDER DIVISION C.32.3 OF THE
BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND							3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**

**LOT 181
MOUNTAINASH 5 3288 sqft**

HVAC DESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**SECOND FLOOR
HEATING
LAYOUT**

Date
DEC/2020

Scale
3/16" = 1'-0"

BCIN# 19669

LO# **88537**