

SITE NAME: RUSSEL GARDENS PHASE 3

LOT 229

DATE: Nov-20

WINTER NATURAL AIR CHANGE RATE 0.343

HEAT LOSS AT °F. 71

CSA-F280-12

BUILDER: GREENPARK HOMES

TYPE: MOUNTAINASH 3

GFA: 3049

LOF 88162


SUMMER NATURAL AIR CHANGE RATE 0.123

HEAT GAIN AT °F. 13

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	WIC-3	BED-3	BED-4	FLEX	ENS-1	BED-2	S-ENS
			42	11	7	27	32	18	16	25	6
			9	9	9	9	9	9	9	9	9
GRS.WALL AREA	LOSS	GAIN	373	99	63	243	288	162	144	225	54
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	19.8	14.7	0	0	0	0	0	0	7	138	103
EAST	19.8	37.8	0	0	0	0	0	0	0	0	0
SOUTH	19.8	22.8	0	0	16	316	364	0	0	0	0
WEST	19.8	37.8	32	633	1208	0	0	0	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	346	1434	260	83	344	62	45	187	34
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	512	910	301	132	157	78	46	55	27
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	42	100	18	252	597	108
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2677		818	697	2626	2522	1246	912	1369
SUB TOTAL HT GAIN				1769	504	758	2084	2357	634	290	853
LEVEL FACTOR / MULTIPLIER	0.20	0.27		0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27
AIR CHANGE HEAT LOSS			711		217	185	597	670	331	242	363
AIR CHANGE HEAT GAIN				134	38	58	158	179	48	22	65
DUCT LOSS			0		0	88	332	319	0	115	0
DUCT GAIN			0		0	82	299	329	0	31	0
HEAT GAIN PEOPLE	240		2	480	0	0	1	240	0	1	240
HEAT GAIN APPLIANCES/LIGHTS				511	0	0	511	511	0	511	511
TOTAL HT LOSS BTU/H			3388		1035	970	3656	3511	1577	1270	1732
TOTAL HT GAIN x 1.3 BTU/H			3763		705	1167	4280	4701	1651	446	2169

ROOM USE	EXP. WALL	CLG. HT.	L/D	FM	K/B	L/H	LND	W/R	FOY	WOD	BAS
			30	33	35	27	31	7	18	46	178
			11	11	11	12	11	11	11	8	8
GRS.WALL AREA	LOSS	GAIN	318	350	371	313	329	74	191	368	1160
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	LOSS	GAIN
NORTH	19.8	14.7	0	0	0	0	0	0	0	0	0
EAST	19.8	37.8	0	0	0	0	0	0	0	0	0
SOUTH	19.8	22.8	36	712	820	0	0	0	0	0	0
WEST	19.8	37.8	0	0	0	34	672	1284	67	1324	2530
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	12	281	51	0	0	0
NET EXPOSED WALL	4.1	0.8	282	1169	212	316	1309	237	285	1182	214
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1881		1981	2926	1923	1873	1189	1657	505
SUB TOTAL HT GAIN				1032	1621	2954	1716	429	350	167	546
LEVEL FACTOR / MULTIPLIER	0.30	0.39		0.30	0.39	0.30	0.39	0.30	0.39	0.30	0.39
AIR CHANGE HEAT LOSS			741		781	1163	758	738	469	553	8819
AIR CHANGE HEAT GAIN				78	115	224	130	33	27	38	54
DUCT LOSS			0		0	0	0	0	0	0	0
DUCT GAIN			0		0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240		0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS				511	511	511	511	511	0	0	511
TOTAL HT LOSS BTU/H			2622		2762	4078	2681	2611	1658	2310	15745
TOTAL HT GAIN x 1.3 BTU/H			2107		2792	4796	3064	1264	489	707	1445



TOTAL HEAT GAIN BTU/H: 36272

TONS: 3.02

LOSS DUE TO VENTILATION LOAD BTU/H: 1915

STRUCTURAL HEAT LOSS: 53059

TOTAL COMBINED HEAT LOSS BTU/H: 54574

Michael O'Rourke

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 229
TYPE: MOUNTAINASH 3

DATE: Nov-20

GFA: 3049

LC# 88162

HEATING CFM	1131	COOLING CFM	1131
TOTAL HEAT LOSS	53,059	TOTAL HEAT GAIN	35,997
AIR FLOW RATE CFM	21.32	AIR FLOW RATE CFM	31.42

furnace pressure	0.1
furnace filter	0.0
a/c coil pressure	0.1
available pressure for s/a & r/a	0.3

#GOODMAN
GMEC960603BNA 60
FAN SPEED

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	8	4
R/A	0	0	6	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

plenum pressure s/a	0.18
max s/a dif press. loss	0.02
min adjusted pressure s/a	0.16

r/a pressure	0.17
r/a grille press. Loss	0.02
adjusted pressure r/a	0.15

LOW	
MEDLOW	
MEDIUM	928
MEDIUM HIGH	1017
HIGH	1131

DESIGN CFM = 1131
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	BED-2	ENS	WIC-3	BED-3	BED-4	FLEX	ENS-1	BED-3	BED-4	MBR	S-ENS	L/D	FM	K/B	K/B	L/H	LND	W/R	FOY	MBR	BAS	BAS	BAS	BAS
RM LOSS MBH	1.73	1.03	0.97	1.83	1.76	1.58	1.27	1.83	1.76	1.69	0.53	2.62	2.76	2.04	2.04	2.68	2.61	1.66	2.31	1.69	4.17	4.17	4.17	4.17
CFM PER RUN HEAT	37	22	21	39	37	34	27	39	37	36	11	56	59	43	43	57	56	35	49	36	89	89	89	89
RM GAIN MBH	2.17	0.71	1.17	2.14	2.35	1.55	0.45	2.14	2.35	1.88	0.33	2.11	2.79	2.40	2.40	3.06	1.26	0.49	0.71	1.88	0.42	0.42	0.42	0.42
CFM PER RUN COOLING	68	22	37	67	74	49	14	67	74	59	10	66	88	75	75	96	40	15	22	59	13	13	13	13
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	57	19	43	51	48	32	61	56	47	46	30	17	47	23	33	37	47	16	35	22	44	19	4	22
EQUIVALENT LENGTH	140	150	110	120	150	180	130	130	160	160	190	120	120	140	100	150	110	150	100	140	140	110	130	130
TOTAL EFFECTIVE LENGTH	197	169	153	171	198	212	191	186	207	206	220	137	167	163	133	187	157	166	135	162	184	129	134	152
ADJUSTED PRESSURE	0.09	0.1	0.11	0.1	0.09	0.08	0.09	0.09	0.08	0.08	0.08	0.13	0.1	0.11	0.13	0.09	0.11	0.1	0.13	0.11	0.09	0.13	0.12	0.11
ROUND DUCT SIZE	5	4	4	5	5	5	4	5	5	5	4	5	6	6	6	6	5	4	4	5	6	6	6	6
HEATING VELOCITY (f/min)	272	252	241	286	272	250	310	286	272	264	126	411	301	219	219	291	411	402	562	264	454	454	454	454
COOLING VELOCITY (f/min)	499	252	424	492	543	360	161	492	543	433	115	485	449	382	382	489	294	172	252	433	66	66	66	66
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	D	D	C	B	A	D	C	A	C	D	A	B	B	C	A	C	C	B	A	B	D	C

RUN #
ROOM NAME
RM LOSS MBH.
CFM PER RUN HEAT
RM GAIN MBH.
CFM PER RUN COOLING
ADJUSTED PRESSURE
ACTUAL DUCT LGH.
EQUIVALENT LENGTH
TOTAL EFFECTIVE LENGTH
ADJUSTED PRESSURE
ROUND DUCT SIZE
HEATING VELOCITY (ft/min)
COOLING VELOCITY (ft/min)
OUTLET GRILL SIZE
TRUNK

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)			
TRUNK A	304	0.08	9	10	X	547	TRUNK G	0	0.00	0	0	X	8	0	TRUNK O	0	0.05	0	0	X	8	0	
TRUNK B	571	0.08	11.4	16	X	642	TRUNK H	0	0.00	0	0	X	8	0	TRUNK P	0	0.05	0	0	X	8	0	
TRUNK C	315	0.08	9.1	10	X	567	TRUNK I	0	0.00	0	0	X	8	0	TRUNK Q	0	0.05	0	0	X	8	0	
TRUNK D	559	0.08	11.3	14	X	719	TRUNK J	0	0.00	0	0	X	8	0	TRUNK R	0	0.05	0	0	X	8	0	
TRUNK E	0	0.00	0	0	X	8	0	TRUNK K	0	0.00	0	0	X	8	0	TRUNK S	0	0.05	0	0	X	8	0
TRUNK F	0	0.00	0	0	X	8	0	TRUNK L	0	0.00	0	0	X	8	0	TRUNK T	0	0.05	0	0	X	8	0

RETURN AIR #	1	2	3	4	5	6	7	8										BR	TRUNK W	0	0.05	0	0	x	8	0
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		TRUNK X	846	0.05	14.8	26	x	8	586
AIR VOLUME	75	130	70	70	70	380	75	100	0	0	0	0	0	0	0	0	161		TRUNK Y	585	0.05	12.9	20	x	8	527
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15			TRUNK Z	205	0.05	8.7	10	x	8	369
ACTUAL DUCT LGH.	56	58	52	56	51	31	33	60	1	1	1	1	1	1	1	15		DROP	1131	0.05	16.5	24	x	10	679	
EQUIVALENT LENGTH	215	235	195	165	255	195	220	240	0	0	0	0	0	0	0	175										
TOTAL EFFECTIVE LH	271	293	247	221	306	226	253	300	1	1	1	1	1	1	1	190										
ADJUSTED PRESSURE	0.05	0.05	0.06	0.07	0.05	0.07	0.06	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.08										
ROUND DUCT SIZE	6	7.3	5.6	5.4	5.8	10.1	5.7	6.7	0	0	0	0	0	0	0	7.1										
INLET GRILL SIZE	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	8										
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X										
INLET GRILL SIZE	14	14	14	14	14	30	14	14	0	0	0	0	0	0	0	14										

TYPE: MOUNTAINASH 3
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 88162
LOT 229

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒	Forced Air
☐	Non Forced Air
☐	Electric Space Heat

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	4 x 7.7 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	8 @ 10.6 cfm	84.8 cfm
Table 9.32.3.A.	TOTAL	212.0 cfm
		222.6

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		222.6 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	222.6	212 cfm
Less Principal Ventil. Capacity	95.4	79.5 cfm
Required Supplemental Capacity	127.2	102.5 cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE 65H
Location:	BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	ΔT °F	FACTOR	% LOSS
79.5 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
ENS-1	FV-05-11VK1	50	☒	0.3
S-ENS	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE 65H	
155 cfm high	64 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:		GREENPARK HOMES
Name:		
Address:		
City:		
Telephone #:	Fax #:	

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	November-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 88162	Model: MOUNTAINASH 3	Builder: GREENPARK HOMES	Date: 09/11/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1378</td> <td>8</td> <td>11024</td> </tr> <tr> <td>First</td> <td>1378</td> <td>11</td> <td>14606.8</td> </tr> <tr> <td>Second</td> <td>1671</td> <td>9</td> <td>15039</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>40,669.8 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1151.6 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1378	8	11024	First	1378	11	14606.8	Second	1671	9	15039	Third	0	9	0	Fourth	0	9	0	Total:			40,669.8 ft³	Total:			1151.6 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width:20%; text-align: center;">0.343</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.123</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.343	SUMMER NATURAL AIR CHANGE RATE	0.123	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1378	8	11024																																																									
First	1378	11	14606.8																																																									
Second	1671	9	15039																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			40,669.8 ft³																																																									
Total:			1151.6 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.343																																																											
SUMMER NATURAL AIR CHANGE RATE	0.123																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-17	39	71																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.343 x 319.90 x 39 °C x 1.2 = 5169 W = 17637 Btu/h			$HG_{sai b} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.123 x 319.90 x 7 °C x 1.2 = 336 W = 1145 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HL_{level})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">17,637</td> <td>7,849</td> <td>1.124</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>13,431</td> <td>0.394</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>13,286</td> <td>0.266</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{level})	1	0.5	17,637	7,849	1.124	2	0.3	13,431	0.394	3	0.2	13,286	0.266	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{level})																																																								
1	0.5	17,637	7,849	1.124																																																								
2	0.3		13,431	0.394																																																								
3	0.2		13,286	0.266																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: MOUNTAINASH 3	LOT 229	BUILDER: GREENPARK HOMES
SFQT: 3049	LO# 88162	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	40669.8	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 53.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	178.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package****A1****Nominal Min. Eff.**


Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 cl	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.2	 Insulation Configuration
Floor Width (m):	11.0	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.4	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1547

TYPE: MOUNTAINASH 3
LO# 88162

LOT 229


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.80			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1151.6			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1535.2 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.343			
Cooling Air Leakage Rate (ACH/H):	0.123			

TYPE: MOUNTAINASH 3
LO# 88162

LOT 229



BASEMENT PLAN ELEV. 3


LOT 229
CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C. 32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 54574 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title BASEMENT HEATING LAYOUT	
		MAKE GOODMAN	MODEL GMEC960603BNA	3RD FLOOR				
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO	Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	INPUT 60 MBTU/H	OUTPUT 57.6 MBTU/H	2ND FLOOR	12	6	3	Date NOV/2020
		COOLING 3.0 TONS	FAN SPEED 1131 cfm @ 0.5" w.c.	1ST FLOOR	8	2	2	Scale 3/16" = 1'-0"
		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5" UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			BCIN# 19669			LO# 88162
LOT 229 MOUNTAINASH 3 3049 sqft								



GROUND FLOOR PLAN
ELEV. 3


LOT 229
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAS REVIEWED AND TAKEN RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No. Description Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO LOT 229 MOUNTAINASH 3 3049 sqft	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdsgns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
		Date	NOV/2020
		Scale	3/16" = 1'-0"
		BCIN# 19669	
		LO#	88162



SECOND FLOOR PLAN
ELEV. 3

LOT 229
CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION 6, 32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.® AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date NOV/2020	
LOT 229 MOUNTAINASH 3 3049 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 88162	