

SITE NAME: RESSEL GARDENS PHASE 3

LOT 248

DATE: Oct-20

WINTER NATURAL AIR CHANGE RATE 0.347

HEAT LOSS AT °F. 71

CSA-F280-12

BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 6

GFA: 2836

LO# 87977

SUMMER NATURAL AIR CHANGE RATE 0.124

HEAT GAIN AT °F. 13

SB-12 PACKAGE A1

ROOM USE			MBR		ENS		WIC-3		BED-2		BED-3		BED-4		ENS-2						ENS-3					
EXP. WALL			31		32		12		10		33		28		8						22					
CLG. HT.			9		9		9		9		9		9		9						9					
FACTORS																										
GRS.WALL AREA			279		288		108		90		297		252		72						198					
GLAZING			LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN						LOSS GAIN					
NORTH	19.8	16.0	0	0	0	7	138	112	0	0	0	16	316	256	0	0	0	7	138	112	0	0	0	0		
EAST	19.8	41.6	0	0	0	0	0	0	12	237	499	0	0	0	42	830	1745	0	0	0	0	0	0	18	356	748
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	16	316	398	0	0	0	0	0	0
WEST	19.8	41.6	32	633	1330	19	376	789	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	247	1024	186	262	1086	197	96	398	72	74	307	56	255	1057	192	236	978	177	65	269	49	180	746	135
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	254	303	149	255	304	150	54	64	32	200	233	118	242	289	142	207	247	122	160	191	94	120	143	71
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0	30	77	38	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	200	474	86	230	646	99	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS																										
SLAB ON GRADE HEAT LOSS																										
SUBTOTAL HT LOSS				1959			1904			700			1335			2797			1541			699			1245	
SUB TOTAL HT GAIN					1666			1248			603			616			2216			687			255			954
LEVEL FACTOR / MULTIPLIER			0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27	
AIR CHANGE HEAT LOSS				528			513			189			360			754			416			161			336	
AIR CHANGE HEAT GAIN					134			100			48			41			178			56			20			77
DUCT LOSS				0			0			0			170			365			0			0			0	
DUCT GAIN					0			0			0			158			342			0			0			0
HEAT GAIN PEOPLE	240		2		480	0		0	0		1			240	1		240	1		240	0		0	0		0
HEAT GAIN APPLIANCES/LIGHTS					788			0			0			788			788			788			0			0
TOTAL HT LOSS BTU/H				2488			2417			888			1866			3907			1957			760			1581	
TOTAL HT GAIN x 1.3 BTU/H					3986			1753			846			2265			4892			2315			358			1339

ROOM USE	EXP. WALL	CLG. HT.	D/L/H	FAM	K/B	LAUND	W/R	FOY	MUD	WOD	BAS
			53	37	35	9	6	18	28	62	176
			11	11	11	9	11	11	12	9	9
FACTORS											
GRS.WALL AREA	LOSS	GAIN	583	407	385	81	66	198	336	558	1242
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	19.8	16.0	0	0	0	0	0	0	7	138	112
EAST	19.8	41.6	24	474	997	0	0	0	0	0	0
SOUTH	19.8	24.9	20	395	498	0	0	0	0	0	0
WEST	19.8	41.6	0	0	0	24	474	997	70	1334	2909
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	539	2234	405	383	1568	288	315	1306	237
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			3104		2062		2690		563		383
SUB TOTAL HT GAIN				1900		1285		3145		563	
LEVEL FACTOR / MULTIPLIER	0.30	0.43			0.30	0.43		0.30	0.43		0.30
AIR CHANGE HEAT LOSS			1343		892		1164		152		166
AIR CHANGE HEAT GAIN				153		103		253		23	
DUCT LOSS			0		0		0		0		0
DUCT GAIN			0		0		0		0		0
HEAT GAIN PEOPLE	240		0		0		0		0		0
HEAT GAIN APPLIANCES/LIGHTS					788		788		788		788
TOTAL HT LOSS BTU/H			4448		2955		3854		715		1429
TOTAL HT GAIN x 1.3 BTU/H				3693		2829		5441		1429	

TOTAL HEAT GAIN BTU/H:

35856

TONS: 2.99

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 51084

TOTAL COMBINED HEAT LOSS BTU/H: 52599

SITE NAME: RESSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMESLOT 248
TYPE: VALLEYCREEK 6

DATE: Oct-20

GFA: 2836

LO# 87977

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 51,084 TOTAL HEAT GAIN 35,581
AIR FLOW RATE CFM 22.14 AIR FLOW RATE CFM 31.79furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35#GOODMAN
GMEC960603BNA 60
FAN SPEED LOWAFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	8	4
R/A	0	0	5	2	1

plenum pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.02 r/a grille press. loss 0.02
min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131
DESIGN CFM = 1131
CFM @ .5" E.S.P.
TEMPERATURE RISE 47 °FAll S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5'Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC-3	BED-2	BED-3	BED-4	ENS-2	ENS	BED-3	MBR	ENS-3	D/L/H	FAM	K/B	K/B	D/L/H	LAUND	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.24	1.21	0.89	1.86	1.95	1.96	0.76	1.21	1.95	1.24	1.58	2.22	2.95	1.93	1.93	2.22	0.71	0.55	2.42	2.71	4.39	4.39	4.39	4.39
CFM PER RUN HEAT	28	27	20	41	43	43	17	27	43	28	35	49	65	43	43	49	16	12	54	60	97	97	97	97
RM GAIN MBH	1.99	0.88	0.85	2.26	2.45	2.32	0.36	0.88	2.45	1.99	1.34	1.85	2.83	2.72	2.72	1.85	1.43	0.31	0.75	0.60	0.69	0.69	0.69	0.69
CFM PER RUN COOLING	63	28	27	72	78	74	11	28	78	63	43	59	90	86	86	59	45	10	24	19	22	22	22	22
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	53	35	57	51	61	59	43	43	38	37	68	39	38	24	13	52	21	27	39	36	33	12	33	47
EQUIVALENT LENGTH	190	190	180	150	140	190	140	120	130	170	160	160	120	160	100	120	110	140	100	120	130	90	140	130
TOTAL EFFECTIVE LENGTH	243	225	237	201	201	249	183	163	168	207	228	199	158	184	113	172	131	167	139	156	163	102	173	177
ADJUSTED PRESSURE	0.07	0.08	0.07	0.09	0.09	0.07	0.09	0.11	0.1	0.08	0.08	0.09	0.1	0.09	0.14	0.1	0.13	0.1	0.12	0.11	0.1	0.16	0.09	0.09
ROUND DUCT SIZE	6	4	4	6	6	6	4	4	5	6	5	5	6	6	6	5	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	143	310	229	209	219	219	195	310	316	143	257	360	331	219	219	360	184	138	396	441	495	495	495	495
COOLING VELOCITY (ft/min)	321	321	310	367	398	377	126	321	573	321	316	433	459	438	438	433	516	115	176	140	112	112	112	112
OUTLET GRILL SIZE	4X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	B	C	A	B	B	A	C	C	B	C	A	A	C	C	D	A	D	B	A	C	C	D	B	A

RUN #	ROOM NAME	RM LOSS MBH	CFM PER RUN HEAT	RM GAIN MBH	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.24	28	1.99	63	0.17	53	190	243	0.07	6	143	321	4X10	B
2	ENS	1.21	27	0.88	28	0.17	35	190	225	0.08	4	310	321	3X10	C
3	WIC-3	0.89	20	0.85	27	0.17	57	180	237	0.07	4	229	310	3X10	A
4	BED-2	1.86	41	2.26	72	0.17	51	150	201	0.09	6	209	367	4X10	B
5	BED-3	1.95	43	2.45	78	0.17	61	140	201	0.09	6	219	398	4X10	B
6	BED-4	1.96	43	2.32	74	0.17	59	190	249	0.07	6	219	377	4X10	A
7	ENS-2	0.76	17	0.36	11	0.17	43	140	183	0.11	4	195	126	3X10	C
8	ENS	1.21	27	0.88	28	0.17	43	120	163	0.1	5	310	321	3X10	C
9	BED-3	1.95	43	2.45	78	0.17	38	130	168	0.1	5	316	573	3X10	B
10	MBR	1.24	28	1.99	63	0.17	37	170	207	0.08	6	143	321	4X10	C
11	ENS-3	1.58	35	1.34	43	0.17	68	160	228	0.08	5	257	316	3X10	A
12	D/L/H	2.22	49	1.85	59	0.17	39	120	199	0.09	5	360	433	3X10	A
13	FAM	2.95	65	2.83	90	0.16	24	160	158	0.1	6	331	459	4X10	C
14	K/B	1.93	43	2.72	86	0.16	13	100	184	0.09	6	219	438	4X10	C
15	K/B	1.93	43	2.72	86	0.16	52	100	113	0.14	6	219	438	4X10	D
16	D/L/H	2.22	49	1.85	59	0.17	21	120	172	0.1	5	360	433	3X10	A
17	LAUND	0.71	16	1.43	45	0.17	27	110	131	0.13	4	184	115	3X10	D
18	W/R	0.55	12	0.31	10	0.17	39	140	167	0.1	5	138	176	3X10	B
19	FOY	2.42	54	0.75	24	0.17	36	100	139	0.12	5	396	140	3X10	A
20	MUD	2.71	60	0.60	19	0.17	33	120	156	0.11	6	441	112	3X10	C
21	BAS	4.39	97	0.69	22	0.16	33	130	163	0.1	6	495	112	4X10	C
22	BAS	4.39	97	0.69	22	0.16	33	130	163	0.1	6	495	112	4X10	D
23	BAS	4.39	97	0.69	22	0.16	33	130	163	0.1	6	495	112	4X10	B
24	BAS	4.39	97	0.69	22	0.16	33	130	163	0.1	6	495	112	4X10	A

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE																				
	TRUNK	STATIC	ROUND	RECT	VELOCITY						TRUNK	STATIC	ROUND	RECT	VELOCITY						TRUNK	STATIC	ROUND	RECT	VELOCITY					
	CFM	PRESS.	DUCT	DUCT			(ft/min)				CFM	PRESS.	DUCT	DUCT			(ft/min)				CFM	PRESS.	DUCT	DUCT			(ft/min)			
	TRUNK A	347	0.07	9.8	12	x	8	521			TRUNK G	0	0.00	0	0	x	8	0			TRUNK O	0	0.05	0	0	x	8	0		
	TRUNK B	611	0.07	12.1	18	x	8	611			TRUNK H	0	0.00	0	0	x	8	0			TRUNK P	0	0.05	0	0	x	8	0		
	TRUNK C	364	0.08	9.6	10	x	8	655			TRUNK I	0	0.00	0	0	x	8	0			TRUNK Q	0	0.05	0	0	x	8	0		
	TRUNK D	1131	0.07	15.2	26	x	8	783			TRUNK J	0	0.00	0	0	x	8	0			TRUNK R	0	0.05	0	0	x	8	0		
	TRUNK E	0	0.00	0	0	x	8	0			TRUNK K	0	0.00	0	0	x	8	0			TRUNK S	0	0.05	0	0	x	8	0		
	TRUNK F	0	0.00	0	0	x	8	0			TRUNK L	0	0.00	0	0	x	8	0			TRUNK T	0	0.05	0	0	x	8	0		

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	155	75	135	75	75	300	135	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	42	52	53	90	57	37	48	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	195	225	245	235	225	235	250	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	237	277	298	325	282	272	298	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.06	0.05	0.05	0.05	0.05	0.05	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7.5	6	7.5	6	6	10.1	7.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: VALLEYCREEK 6
SITE NAME: RESSEL GARDENS PHASE 3

LO # 87977
LOT 248

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	6 @ 10.6 cfm	63.6 cfm
Table 9.32.3.A.	TOTAL	190.8 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	190.8	cfm
Less Principal Ventl. Capacity	79.5	cfm
Required Supplemental Capacity	111.3	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	ΔT °F	FACTOR	% LOSS
79.5 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC	
Location	Model	cfm	HVI Sones
ENS	FV-05-11VK1	50	☒ 0.3
ENS-2	FV-05-11VK1	50	☒ 0.3
ENS-3	FV-05-11VK1	50	☒ 0.3
W/R	FV-05-11VK1	50	☒ 0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
155 cfm high	64 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	October-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 87977		Model: VALLEYCREEK 6		Builder: GREENPARK HOMES																																																								
				Date: 28/10/2020																																																								
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1215</td> <td>9</td> <td>10935</td> </tr> <tr> <td>First</td> <td>1215</td> <td>11</td> <td>13365</td> </tr> <tr> <td>Second</td> <td>1621</td> <td>9</td> <td>14589</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>38,889.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1101.2 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1215	9	10935	First	1215	11	13365	Second	1621	9	14589	Third	0	9	0	Fourth	0	9	0	Total:			38,889.0 ft³	Total:			1101.2 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.347</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.124</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.347	SUMMER NATURAL AIR CHANGE RATE	0.124	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1215	9	10935																																																									
First	1215	11	13365																																																									
Second	1621	9	14589																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			38,889.0 ft³																																																									
Total:			1101.2 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.347																																																											
SUMMER NATURAL AIR CHANGE RATE	0.124																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-17	39	71																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.347 x 305.89 x 39 °C x 1.2 = 4995 W = 17043 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.124 x 305.89 x 7 °C x 1.2 = 324 W = 1106 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	17,043	9,058	0.941																																																								
2	0.3		11,815	0.433																																																								
3	0.2		12,644	0.270																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: VALLEYCREEK 6	LOT 248	BUILDER: GREENPARK HOMES
SFQT: 2836	LO# 87977	SITE: RESSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA


ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	38889.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 50.0 ft	WIDTH: 38.0 ft	EXPOSED PERIMETER:	176.0 ft

2012 OBC - COMPLIANCE PACKAGE		
Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	15.2	
Floor Width (m):	11.6	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	2.0	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1702	

TYPE: VALLEYCREEK 6
LO# 87977

LOT 248

Air Infiltration Residential Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.92			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1101.2			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1468.0 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.347			
Cooling Air Leakage Rate (ACH/H):	0.124			

TYPE: VALLEYCREEK 6
LO# 87977

LOT:248

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department
FEB 04 2021
REC'D BY _____ DATE _____
REF'D TO _____ DATE _____



GROUND FLOOR PLAN ELEV. 1

CITY OF HAMILTON
Building Division

Permit No. 21-105908

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and specifications have been reviewed by
W.B. 2/19/21
FOR CHIEF BUILDING OFFICIAL DATE

LOT 248
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER		Date

REVISIONS

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES
Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**


**LOT 248
VALLEYCREEK 6 2836 sqft**

HVAC DESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper.
Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**FIRST FLOOR
HEATING
LAYOUT**
Date **OCT/2020**
Scale **3/16" = 1'-0"**
BCIN# **19669**
LO# **87977**

FEB 04 2021

REC'D BY _____ DATE _____
REF'D TO _____ DATE _____



SECOND FLOOR PLAN ELEV. 1

CITY OF HAMILTON
Building Division

Permit No. 21-105908

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and specifications have been reviewed by
[Signature] 2/19/21
FOR CHIEF BUILDING OFFICIAL DATE

LOT 248
CSA-F280-12
PACKAGE A1

I, MICHAEL O'BROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.5 OF THE BUILDING CODE.
[Signature]
Michael O'Brouke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND							
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date OCT/2020	Scale 3/16" = 1'-0"
LOT 248 VALLEYCREEK 6 2836 sqft		Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	BCIN# 19669	
			LO#	87977