

SITE NAME: RUSSEL GARDENS PHASE 3

LOT 308

DATE: Dec-20

WINTER NATURAL AIR CHANGE RATE 0.319

HEAT LOSS AT "F. 71

CSA-F280-12

BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 3

GFA: 2653

LO# 88503

SUMMER NATURAL AIR CHANGE RATE 0.114

HEAT GAIN AT "F. 13

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	MBR	ENS	BED-2	BED-3	BED-4	S-ENS	ENS-2
EXP. WALL						37	22	10	32	15	6	10
CLG. HT.						9	9	9	9	9	9	9
GRS.WALL AREA						333	198	90	288	135	54	90
GLAZING						LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	19.8	16.0	0	0	0	0	0	15	297	240	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	7	138
SOUTH	19.8	24.9	0	0	0	9	178	0	0	0	0	0
WEST	19.8	41.6	34	672	1413	15	297	0	0	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	299	1240	225	174	721	75	311	86	244	1012
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	346	412	203	121	144	239	286	140	263	314
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	27	64	12	228	540
BASEMENT/CRAWL HEAT LOSS						0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS						0	0	0	0	0	0	0
SUBTOTAL HT LOSS						2324	1340	958	2735	1067	753	659
SUB TOTAL HT GAIN						1841	1049	448	2264	598	267	357
LEVEL FACTOR / MULTIPLIER			0.20	0.31		0.20	0.31	0.20	0.31	0.20	0.31	0.20
AIR CHANGE HEAT LOSS						728	420	259	856	334	236	206
AIR CHANGE HEAT GAIN						149	85	36	183	48	22	29
DUCT LOSS						0	0	126	359	0	99	0
DUCT GAIN						0	0	128	325	0	29	0
HEAT GAIN PEOPLE	240		2			480	0	1	240	1	240	0
HEAT GAIN APPLIANCES/LIGHTS						561	0		561		561	0
TOTAL HT LOSS BTU/H						3052	1760	1381	3951	1401	1088	866
TOTAL HT GAIN x 1.3 BTU/H						3939	1474	1837	4644	1881	413	501

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	DIN	FAM	BR/KT	LAUN	FOY	BAS
EXP. WALL						29	34	36	25	49	172
CLG. HT.						11	11	11	11	20	9
GRS.WALL AREA						319	374	396	275	980	1032
GLAZING						LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	31	613
SOUTH	19.8	24.9	26	514	647	0	0	0	0	19	376
WEST	19.8	41.6	0	0	0	44	870	1828	45	890	1870
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	15	352	64	
NET EXPOSED WALL	4.1	0.8	293	1215	220	330	1368	248	336	1393	253
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS						0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS						0	0	0	0	0	0
SUBTOTAL HT LOSS						1729	2238	2634	1636	5934	8157
SUB TOTAL HT GAIN						868	2076	2186	383	2697	727
LEVEL FACTOR / MULTIPLIER			0.30	0.33		0.30	0.33	0.30	0.33	0.30	0.33
AIR CHANGE HEAT LOSS						563	729	859	533	1934	7699
AIR CHANGE HEAT GAIN						70	168	177	31	218	59
DUCT LOSS						0	0	0	0	0	0
DUCT GAIN						0	0	0	0	0	0
HEAT GAIN PEOPLE	240		0			0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS						561	561	561	561	561	561
TOTAL HT LOSS BTU/H						2292	2967	3493	2169	7869	15856
TOTAL HT GAIN x 1.3 BTU/H						1948	3646	3801	1267	3730	1760

CITY OF HAMILTON
Building Division
Permit No. 107111
THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
These drawings and/or specifications have been reviewed by
FEB 23 2021
DATE
FOR CHIEF BUILDING OFFICIAL

TOTAL HEAT GAIN BTU/H: 31167

TONS: 2.60

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 48144

TOTAL COMBINED HEAT LOSS BTU/H: 49659

Michael O'Rourke

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 308
TYPE: VALLEYCREEK 3

DATE: Dec-20

GFA: 2653 LO# 88603

HEATING CFM 928 COOLING CFM 928
TOTAL HEAT LOSS 48,144 TOTAL HEAT GAIN 30,893
AIR FLOW RATE CFM 19.28 AIR FLOW RATE CFM 30.04

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	10	8	4
R/A	0	0	3	1	1

plenium pressure s/a 0.18
max s/a diff press. loss 0.01
min adjusted pressure s/a 0.17

r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15

MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

DESIGN CFM = 928
CFM @ .5" E.S.P.

TEMPERATURE RISE 57 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	4	5	6	7	8	9	10	11	12	13	14	15	16	17	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-2	BED-3	BED-4	S-ENS	S-ENS	BED-3	MBR	ENS-2	DIN	FAM	BF/KT	BF/KT	FAM	LAUN	FOY	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.53	1.76	1.38	1.98	1.40	0.54	0.54	1.98	1.53	0.87	2.29	1.48	1.75	1.75	1.48	2.17	3.93	3.93	3.96	3.96	3.96	3.96
CFM PER RUN HEAT	29	34	27	38	27	10	10	38	29	17	44	29	34	34	29	42	76	76	76	76	76	76
RM GAIN MBH	1.97	1.47	1.84	2.32	1.88	0.21	0.21	2.32	1.97	0.50	1.95	1.82	1.90	1.90	1.82	1.27	1.89	1.89	0.44	0.44	0.44	0.44
CFM PER RUN COOLING	59	44	55	70	57	6	6	70	59	15	59	55	57	57	55	38	57	57	13	13	13	13
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	32	42	42	40	44	37	31	45	38	32	19	30	21	24	28	10	43	36	24	25	22	37
EQUIVALENT LENGTH	120	190	170	170	160	140	140	120	140	170	160	140	150	130	120	150	180	100	90	100	140	120
TOTAL EFFECTIVE LENGTH	152	232	212	210	204	177	171	165	178	202	179	170	171	154	146	160	223	138	114	125	162	157
ADJUSTED PRESSURE	0.11	0.07	0.08	0.08	0.08	0.1	0.1	0.1	0.1	0.09	0.1	0.1	0.1	0.11	0.12	0.11	0.08	0.13	0.15	0.14	0.11	0.11
ROUND DUCT SIZE	5	5	6	5	6	4	4	5	5	4	6	5	5	5	5	4	5	5	5	5	5	5
HEATING VELOCITY (ft/min)	213	250	138	279	138	115	115	279	213	195	224	213	250	250	213	462	558	558	558	558	558	558
COOLING VELOCITY (ft/min)	433	323	280	514	291	69	69	514	433	172	301	404	419	419	404	436	419	419	95	95	95	95
OUTLET GRILL SIZE	3X10	3X10	4X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	A	B	D	C	C	D	D	D	A	B	D	A	B	A	A	D	C	C	B	B	C	C

RUN #	ROOM NAME	RM LOSS MBH	CFM PER RUN HEAT	RM GAIN MBH	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.53	29	1.97	59	0.17	32	120	152	0.11	5	213	433	3X10	A
2	ENS	1.76	34	1.47	44	0.17	42	190	232	0.07	5	250	323	3X10	B
4	BED-2	1.38	27	1.84	55	0.17	42	170	212	0.08	6	138	280	4X10	D
5	BED-3	1.98	38	2.32	70	0.17	40	170	210	0.08	5	279	514	3X10	C
6	BED-4	1.40	27	1.88	57	0.17	44	160	204	0.08	6	138	291	4X10	C
7	S-ENS	0.54	10	0.21	6	0.17	37	140	177	0.1	4	115	69	3X10	D
8	S-ENS	0.54	10	0.21	6	0.17	31	140	171	0.1	4	115	69	3X10	D
9	BED-3	1.98	38	2.32	70	0.17	45	120	165	0.1	5	279	514	3X10	D
10	MBR	1.53	29	1.97	59	0.17	38	140	178	0.1	5	213	433	3X10	A
11	ENS-2	0.87	17	0.50	15	0.17	32	170	202	0.09	4	195	172	3X10	B
12	DIN	2.29	44	1.95	59	0.17	19	160	179	0.1	6	224	301	4X10	D
13	FAM	1.48	29	1.82	55	0.17	30	140	170	0.1	5	213	404	3X10	A
14	BF/KT	1.75	34	1.90	57	0.17	21	150	171	0.1	5	250	419	3X10	B
15	BF/KT	1.75	34	1.90	57	0.17	24	130	154	0.11	5	250	419	3X10	A
16	FAM	1.48	29	1.82	55	0.17	28	120	146	0.12	5	213	404	3X10	A
17	LAUN	2.17	42	1.27	38	0.17	10	150	160	0.11	4	462	436	3X10	D
19	FOY	3.93	76	1.89	57	0.17	43	180	223	0.08	5	558	419	3X10	C
20	FOY	3.93	76	1.89	57	0.17	36	100	138	0.13	5	558	419	3X10	C
21	BAS	3.96	76	0.44	13	0.17	24	90	114	0.15	5	558	95	3X10	B
22	BAS	3.96	76	0.44	13	0.17	25	100	125	0.14	5	558	95	3X10	B
23	BAS	3.96	76	0.44	13	0.17	22	140	162	0.11	5	558	95	3X10	C
24	BAS	3.96	76	0.44	13	0.17	37	120	157	0.11	5	558	95	3X10	C

SUPPLY AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY	RETURN AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY
	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)		CFM	PRESS.	DUCT	DUCT	(ft/min)
TRUNK A	150	0.10	6.5	8	338	TRUNK G	0	0.00	0	0	TRUNK O	0	0.06	0	0	8
TRUNK B	387	0.07	10.2	14	498	TRUNK H	0	0.00	0	0	TRUNK P	0	0.06	0	0	8
TRUNK C	369	0.08	9.7	12	554	TRUNK I	0	0.00	0	0	TRUNK Q	0	0.06	0	0	8
TRUNK D	540	0.08	11.1	16	608	TRUNK J	0	0.00	0	0	TRUNK R	0	0.06	0	0	8
TRUNK E	0	0.00	0	0	0	TRUNK K	0	0.00	0	0	TRUNK S	0	0.06	0	0	8
TRUNK F	0	0.00	0	0	0	TRUNK L	0	0.00	0	0	TRUNK T	0	0.06	0	0	8
											TRUNK U	0	0.06	0	0	8
											TRUNK V	0	0.06	0	0	8
											TRUNK W	0	0.06	0	0	8
											TRUNK X	928	0.06	14.7	26	8
											TRUNK Y	0	0.06	0	0	8
											TRUNK Z	0	0.06	0	0	8
											DROP	928	0.06	14.7	24	10

TYPE: VALLEYCREEK 3
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 88603
LOT 308

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting Induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	4 @ 10.6 cfm	42.4 cfm
Table 9.32.3.A.	TOTAL	169.6 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	169.6	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	90.1	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	$\Delta T^{\circ}F$	FACTOR	% LOSS
79.5 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC
Location	Model	cfm
ENS	FV-05-11VK1	50
S-ENS	FV-05-11VK1	50
ENS-2	FV-05-11VK1	50

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
155 cfm high	84 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	December-20

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 19869

MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 88603	Model: VALLEYCREEK 3	Builder: GREENPARK HOMES	Date: 14/12/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1215</td> <td>9</td> <td>10935</td> </tr> <tr> <td>First</td> <td>1215</td> <td>11</td> <td>13365</td> </tr> <tr> <td>Second</td> <td>1543</td> <td>9</td> <td>13887</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>38,187.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1081.3 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1215	9	10935	First	1215	11	13365	Second	1543	9	13887	Third	0	9	0	Fourth	0	9	0	Total:			38,187.0 ft³	Total:			1081.3 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.319</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.114</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>T_{in} °C</th> <th>T_{out} °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTD_h</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTD_c</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.319	SUMMER NATURAL AIR CHANGE RATE	0.114	Design Temperature Difference						T _{in} °C	T _{out} °C	ΔT °C	ΔT °F	Winter DTD _h	22	-17	39	71	Summer DTD _c	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1215	9	10935																																																									
First	1215	11	13365																																																									
Second	1543	9	13887																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			38,187.0 ft³																																																									
Total:			1081.3 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.319																																																											
SUMMER NATURAL AIR CHANGE RATE	0.114																																																											
Design Temperature Difference																																																												
	T _{in} °C	T _{out} °C	ΔT °C	ΔT °F																																																								
Winter DTD _h	22	-17	39	71																																																								
Summer DTD _c	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.319 x 300.37 x 39 °C x 1.2 = 4513 W = 15397 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.114 x 300.37 x 7 °C x 1.2 = 293 W = 1000 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HL_{airb} Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HL_{airbv} / HL_{level})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">15,397</td> <td>8,157</td> <td>0.944</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>14,171</td> <td>0.326</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>9,835</td> <td>0.313</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HL_{airbv} = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HL_{airb} = 0					Level	Level Factor (LF)	HL _{airb} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})	1	0.5	15,397	8,157	0.944	2	0.3	14,171	0.326	3	0.2	9,835	0.313	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HL _{airb} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})																																																								
1	0.5	15,397	8,157	0.944																																																								
2	0.3		14,171	0.326																																																								
3	0.2		9,835	0.313																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: VALLEYCREEK 3	LOT 308	BUILDER: GREENPARK HOMES
SFQT: 2653	LO# 88603	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	38187.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 52.0 ft	WIDTH: 34.0 ft	EXPOSED PERIMETER:	172.0 ft

2012 OBC - COMPLIANCE PACKAGE Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	15.8	 Insulation Configuration
Floor Width (m):	10.4	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.4	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1660

TYPE: VALLEYCREEK 3
LO# 88603

LOT 308


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.01			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1081.3			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1441.5 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.319			
Cooling Air Leakage Rate (ACH/H):	0.114			

TYPE: VALLEYCREEK 3
LO# 88603

LOT 308



BASEMENT PLAN 3


LOT 308
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client	HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 49659 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS				Sheet Title	
GREENPARK HOMES		MAKE GOODMAN		3RD FLOOR				BASEMENT HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO		MODEL GMEC960603BNA		2ND FLOOR	10	3	3		
		INPUT 60 MBTU/H		1ST FLOOR	8	1	2		
		OUTPUT 57.6 MBTU/H		BASEMENT	4	1	0	Date DEC/2020	
LOT 308 VALLEYCREEK 3 2653 sqft		COOLING 2.5 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5" UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A				Scale 3/16" = 1'-0"	
		FAN SPEED 928 cfm @ 0.6" w.c.						BCIN# 19669	
					LO# 88603				



FIRST FLOOR PLAN 3


LOT 308
CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE ONTARIO BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date DEC/2020	
LOT 308 VALLEYCREEK 3 2653 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO#	88603



SECOND FLOOR PLAN 3

LOT 308
CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date DEC/2020	Scale 3/16" = 1'-0"
LOT 308 VALLEYCREEK 3 2653 sqft			BCIN# 19669	
			LO#	88603