

ROOM USE	FAM		L/D		K/B		L/H		LND		W/R		FOY		WUB		BAS			
EXP. WALL	34		24		37		18		8		26		42		26		160			
CLG. HT.	10		10		10		10		9		11		10		9		9			
FACTORS																				
GRS.WALL AREA	340		240		370		180		72		286		420		234		900			
GLAZING	LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN			
NORTH	19.8	15.1	8	168	121	0	0	0	0	0	0	7	138	106	0	0	0	5	99	76
EAST	19.8	39.0	0	0	0	0	0	0	0	0	0	0	0	0	6	119	234	7	138	273
SOUTH	19.8	23.5	0	0	0	33	652	775	0	0	0	12	237	282	7	138	164	0	0	0
WEST	19.8	39.0	40	791	1561	0	0	0	60	1186	2341	0	0	0	0	0	0	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	12	261	51	0	0	0	0	20	469	85	40	938	170
NET EXPOSED WALL	4.1	0.8	292	1211	219	207	858	156	298	1235	224	168	696	126	65	269	49	259	1074	195
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	128	143	71	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0		0		0		0		0		0		0		0		0	
SLAB ON GRADE HEAT LOSS			0		0		0		0		0		0		0		0		0	
SUBTOTAL HT LOSS			2169		1610		2763		934		551		1681		2507		224		1580	
SUB TOTAL HT GAIN					1901		930		2616		408		284		386		685		246	
LEVEL FACTOR / MULTIPLIER	0.30	0.43			0.30		0.43		0.30		0.43		0.20		0.24		0.30		0.43	
AIR CHANGE HEAT LOSS			932		652		1186		403		131		726		1125		8340		0.50	
AIR CHANGE HEAT GAIN			139		68		191		30		21		28		50		87		0	
DUCT LOSS			0		0		0		0		0		0		0		0		0	
DUCT GAIN			0		0		0		0		0		0		0		0		0	
HEAT GAIN PEOPLE	240	0	0		0		0		0		0		0		0		0		0	
HEAT GAIN APPLIANCES/LIGHTS			529		629		529		529		529		529		529		0		529	
TOTAL HT LOSS BTU/H			3091		2162		3869		1337		682		2407		3732		1580		15622	
TOTAL HT GAIN x 1.3 BTU/H			3340		1986		4338		1257		1084		538		966		320		2025	

TOTAL COMBINED HEAT LOSS BTU/H: 53660

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 321
TYPE: MOUNTAINASH 4

DATE: Oct-20

GFA: 3185 LO# 87984

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 52,144 TOTAL HEAT GAIN 36,221
AIR FLOW RATE CFM 21.69 AIR FLOW RATE CFM 31.22

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	13	7	4
R/A	0	0	5	2	1

plenum pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.02 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15

MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

DESIGN CFM = 1131
CFM @ .5" E.S.P.

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	FLEX	BED-2	BED-3	BED-4	ENS-3	FLEX	BED-3	MBR	S-ENS	FAM	L/D	K/B	K/B	L/H	LND	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.52	2.12	2.12	1.68	1.91	1.20	0.55	2.12	1.91	1.52	0.50	3.09	2.16	1.93	1.93	1.34	0.68	2.41	3.73	4.30	4.30	4.30	4.30
CFM PER RUN HEAT	33	46	46	36	41	26	12	46	41	33	11	67	47	42	42	29	15	52	81	93	93	93	93
RM GAIN MBH	1.86	1.45	2.84	1.87	2.56	1.79	0.36	2.84	2.56	1.86	0.20	3.34	1.99	2.17	2.17	1.26	1.08	0.54	0.96	0.59	0.59	0.59	0.59
CFM PER RUN COOLING	58	45	89	58	80	56	11	89	80	58	6	104	62	68	68	39	34	17	30	18	18	18	18
ADJUSTED PRESSURE	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	32	63	51	58	61	46	49	58	49	38	46	26	25	38	44	40	23	47	48	34	37	24	41
EQUIVALENT LENGTH	130	150	160	140	100	210	200	130	190	100	130	130	140	120	120	140	160	130	110	120	140	130	130
TOTAL EFFECTIVE LENGTH	162	213	211	196	161	256	249	188	239	138	176	156	165	158	164	180	183	177	158	154	177	154	171
ADJUSTED PRESSURE	0.11	0.08	0.08	0.09	0.11	0.07	0.07	0.09	0.07	0.12	0.1	0.1	0.1	0.11	0.1	0.1	0.09	0.1	0.1	0.11	0.09	0.11	0.09
ROUND DUCT SIZE	5	5	6	6	6	6	4	6	6	5	4	6	5	5	5	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	242	338	235	184	209	133	138	235	209	242	126	342	345	308	308	333	172	382	595	474	474	474	474
COOLING VELOCITY (ft/min)	426	330	454	296	408	286	126	454	408	426	69	530	455	499	499	447	390	125	220	92	92	92	92
OUTLET GRILL SIZE	3X10	3X10	4X10	4X10	4X10	4X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	C	A	D	A	E	D	D	D	D	C	E	C	E	B	B	D	C	A	D	B	C	E	D

RUN #	25
ROOM NAME	S-ENS
RM LOSS MBH	0.50
CFM PER RUN HEAT	11
RM GAIN MBH	0.20
CFM PER RUN COOLING	6
ADJUSTED PRESSURE	0.17
ACTUAL DUCT LGH	46
EQUIVALENT LENGTH	140
TOTAL EFFECTIVE LENGTH	186
ADJUSTED PRESSURE	0.09
ROUND DUCT SIZE	4
HEATING VELOCITY (ft/min)	126
COOLING VELOCITY (ft/min)	69
OUTLET GRILL SIZE	3X10
TRUNK	E

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)							
TRUNK A	134	0.08	6.6	8	x	302		TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0				
TRUNK B	177	0.10	6.9	8	x	398		TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0				
TRUNK C	552	0.08	11.2	14	x	710		TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0				
TRUNK D	374	0.07	10	12	x	561		TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0				
TRUNK E	577	0.07	11.8	16	x	649		TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	0		TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0				
															TRUNK U	0	0.05	0	0	x	8	0					
															TRUNK V	0	0.05	0	0	x	8	0					
															TRUNK W	0	0.05	0	0	x	8	0					
															TRUNK X	876	0.05	15	26	x	8	606					
															TRUNK Y	535	0.05	12.5	18	x	8	535					
															TRUNK Z	0	0.05	0	0	x	8	0					
															DROP	1131	0.05	16.5	24	x	10	679					

RETURN AIR #	1	2	3	4	5	6	7									BR
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AIR VOLUME	85	95	95	85	75	360	175	0	0	0	0	0	0	0	0	161
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	51	42	51	53	63	26	26	1	1	1	1	1	1	1	1	15
EQUIVALENT LENGTH	205	165	155	205	210	185	190	0	0	0	0	0	0	0	0	185
TOTAL EFFECTIVE LH	266	207	206	258	273	211	216	1	1	1	1	1	1	1	1	200
ADJUSTED PRESSURE	0.06	0.07	0.07	0.06	0.05	0.07	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.07
ROUND DUCT SIZE	6	6	6	6	6	9.9	7.5	0	0	0	0	0	0	0	0	7.3
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	14

TYPE: MOUNTAINASH 4
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 87984
LOT 321

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES 9.32.3.1(1)	
a) ☒	Direct vent (sealed combustion) only
b) ☐	Positive venting Induced draft (except fireplaces)
c) ☐	Natural draft, B-vent or induced draft gas fireplace
d) ☐	Solid Fuel (including fireplaces)
e) ☐	No Combustion Appliances

HEATING SYSTEM	
☒	Forced Air
☐	Non Forced Air
☐	Electric Space Heat

HOUSE TYPE 9.32.1(2)	
☒	I Type a) or b) appliance only, no solid fuel
☐	II Type I except with solid fuel (including fireplaces)
☐	III Any Type c) appliance
☐	IV Type I, or II with electric space heat
☐	Other: Type I, II or IV no forced air

SYSTEM DESIGN OPTIONS O.N.H.W.P.	
☐	1 Exhaust only/Forced Air System
☐	2 HRV with Ducting/Forced Air System
☒	3 HRV Simplified/connected to forced air system
☐	4 HRV with Ducting/non forced air system
☐	Part 6 Design

TOTAL VENTILATION CAPACITY 9.32.3.3(1)	
Basement + Master Bedroom	2 @ 21.2 cfm 42.4 cfm
Other Bedrooms	3 @ 10.6 cfm 31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm 53 cfm
Other Rooms	8 @ 10.6 cfm 84.8 cfm
Table 9.32.3.A.	TOTAL 212.0 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4(1)	
1 Bedroom	31.8 cfm
2 Bedroom	47.7 cfm
3 Bedroom	63.6 cfm
4 Bedroom	79.5 cfm
5 Bedroom	95.4 cfm
TOTAL	79.6 cfm

SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.6.	
Total Ventilation Capacity	212 cfm
Less Principal Ventil. Capacity	79.5 cfm
Required Supplemental Capacity	132.5 cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANE 65H	Location: BSMT
79.5 cfm	3.0 sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	X 71 F	X 1.08	X	0.25

SUPPLEMENTAL FANS PANASONIC		cfm	HVI	Sones
Location	Model			
ENS	FV-05-11VK1	50	☒	0.3
ENS-3	FV-05-11VK1	50	☒	0.3
S-ENS	FV-05-11VK1	50	☒	0.3
WR	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR 9.32.3.11.	
Model: VANE 65H	
155 cfm high	64 cfm low
75 % Sensible Efficiency	☒ HVI Approved
@ 32 deg F (0 deg C)	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	October-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 87984

Model: MOUNTAINASH 4

Builder: GREENPARK HOMES

Date: 28/10/2020

Volume Calculation
House Volume

Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)
Bsmt	1398	9	12582
First	1398	10	13980
Second	1787	9	16083
Third	0	9	0
Fourth	0	9	0
Total:			42,645.0 ft³
Total:			1207.6 m³

Air Change & Delta T Data

WINTER NATURAL AIR CHANGE RATE	0.310
SUMMER NATURAL AIR CHANGE RATE	0.111

Design Temperature Difference

	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.310 \times 335.44 \times 39^\circ\text{C} \times 1.2 = 4888 \text{ W}$$

$$= 16679 \text{ Btu/h}$$

6.2.6 Sensible Gain due to Air Leakage

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$0.111 \times 335.44 \times 7^\circ\text{C} \times 1.2 = 317 \text{ W}$$

$$= 1083 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation

$$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 71^\circ\text{F} \times 1.08 \times 0.25 = 1515 \text{ Btu/h}$$

6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{level})
1	0.5	16,679	8,863	0.941
2	0.3		11,595	0.432
3	0.2		14,029	0.238
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

CITY OF HAMILTON
Building Division

Permit No.

21-107102

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by

FEB 26 2021

FOR CHIEF BUILDING OFFICIAL

DATE

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: MOUNTAINASH 4	LOT 321	BUILDER: GREENPARK HOMES
SFQT: 3185	LO# 87984	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	42645.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 52.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	150.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	15.8	 Insulation Configuration
Floor Width (m):	11.0	
Exposed Perimeter (m):	45.7	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	2.0	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1428

TYPE: MOUNTAINASH 4
LO# 87984

LOT 321

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.8	
Width (m):	4.3	
Exposed Perimeter (m):	7.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):	66	

TYPE: MOUNTAINASH 4
LO# 87984

LOT 321


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Hamilton		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	6.71		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	1207.6		
Air Leakage/Ventilation			
Air Tightness Type:	Present (1961-) (3.57 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	1609.7 cm ²	
	3.57	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	37.5	37.5	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.310		
Cooling Air Leakage Rate (ACH/H):	0.111		

TYPE: MOUNTAINASH 4
LO# 87984

LOT 321




I, MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.3 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCP# 19669
HVAC DESIGNS LTD.

LOT 321
WUB
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacadesigns.ca Web: www.hvacadesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date OCT/2020	
LOT 321 MOUNTAINASH 4 3185 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO#	87984



SECOND FLOOR PLAN - ELEV. '2'

LOT 321
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL OROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
MICHAEL O'ROURKE, DESIGNER 19669
HVAC DESIGNS LTD.

HVAC LEGEND						3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER
REVISIONS							
No.	Description	Date					

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacadesigns.ca Web: www.hvacadesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO		Date OCT/2020		
LOT 321 MOUNTAINASH 4 3185 sqft		Scale 3/16" = 1'-0"		
		BCIN# 19669 LO# 87984		