

SITE NAME: RUSSEL GARDENS PHASE 3

LOT 257

DATE: Oct-20

WINTER NATURAL AIR CHANGE RATE 0.310

HEAT LOSS AT °F. 71

CSA-F280-12

BUILDER: GREENPARK HOMES

TYPE: MOUNTAINASH 6

GFA: 3360

LO# 87979

SUMMER NATURAL AIR CHANGE RATE 0.111

HEAT GAIN AT °F. 13

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	BED-5	WIC-3	ENS-3
			33	29	8	34	33	26	0	11	8	6
			9	9	9	9	9	9	9	9	9	9
FACTORS												
GRS.WALL AREA	LOSS	GAIN	297	261	72	306	297	234	0	99	72	54
GLAZING	LOSS	GAIN							LOSS	GAIN	LOSS	GAIN
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0	0
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0	0	0
WEST	19.8	41.6	32	633	1330	14	277	224	0	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	265	1099	199	240	995	180	72	298	54	261
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	286	340	167	204	243	120	130	155	76	264
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2071		1653	453	2398	2634		1357	438	547
SUB TOTAL HT GAIN				1696		1056	131	2361		3215	463	270
LEVEL FACTOR / MULTIPLIER	0.20	0.23				0.20	0.23		0.20	0.23		
AIR CHANGE HEAT LOSS			483		385	106	699	660		316	194	236
AIR CHANGE HEAT GAIN				112		70	9	166		212	36	8
DUCT LOSS			0		0	0	370	349		0	54	0
DUCT GAIN			0		0	0	318	409		0	56	0
HEAT GAIN PEOPLE	240		2	480	0	0	0	240	1	240	1	240
HEAT GAIN APPLIANCES/LIGHTS			427		427	427	427	427		427	427	427
TOTAL HT LOSS BTU/H			2654		2039	559	4066	3843		1673	594	1025
TOTAL HT GAIN x 1.3 BTU/H				3530		2019	736	4553		5854	1626	1197

ROOM USE	EXP. WALL	CLG. HT.	L/D	FAM	K/B	L/H	LND	FOY	MUD	WUB	BAS
			50	35	44	10	7	28	24	13	169
			10	10	10	10	9	11	11	11	8
FACTORS											
GRS.WALL AREA	LOSS	GAIN	500	350	440	100	63	308	264	845	845
GLAZING	LOSS	GAIN						LOSS	GAIN	LOSS	GAIN
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0
SOUTH	19.8	24.9	35	712	896	0	0	0	0	0	0
WEST	19.8	41.6	0	0	0	0	0	0	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	464	1924	349	304	1260	228	363	1505	273
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2635		2170	3135	696	521	2815	1481	268
SUB TOTAL HT GAIN				1245		2140	2272	349	228		
LEVEL FACTOR / MULTIPLIER	0.30	0.40				0.30	0.40		0.30	0.40	
AIR CHANGE HEAT LOSS			1042		858	1239	275	121	1113	133	18
AIR CHANGE HEAT GAIN				82		141	150	23	15		
DUCT LOSS			0		0	0	0	0	0	0	0
DUCT GAIN			0		0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240		0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			427		427	427	427	427	427	427	427
TOTAL HT LOSS BTU/H			3677		3027	4375	971	642	3927	2066	5695
TOTAL HT GAIN x 1.3 BTU/H				2281		3521	3704	1039	871		

TOTAL HEAT GAIN BTU/H:

41536

TONS: 3.46

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 54535

TOTAL COMBINED HEAT LOSS BTU/H: 56951

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 257
TYPE: MOUNTAINASH 6

DATE: Oct-20

GFA- 3360

LO# 87979

HEATING CFM	1504	COOLING CFM	1504
TOTAL HEAT LOSS	54,535	TOTAL HEAT GAIN	41,267
AIR FLOW RATE CFM	27.58	AIR FLOW RATE CFM	36.45

furnace pressure	0.6
furnace filter	0.0
a/c coil pressure	0.2
available pressure for s/a & r/a	0.3

#*GOODMAN	
GMEC960804CNA	80
FAN SPEED	
LOW	868
MEDLOW	978
MEDIUM	1112
MEDIUM HIGH	1504
HIGH	1815

AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = 76,800

DESIGN CFM = 1504
CFM @ 6" F.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	17	10	5
R/A	0	0	6	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout

All S/A runs 5"Ø unless noted otherwise on layout

Run #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	BED-5	WIC-3	MBR	ENS-3	L/D	FAM	K/B	K/B	L/H	LND	FOY	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.28	1.02	0.56	2.03	1.28	1.67	0.30	1.03	1.37	1.28	0.56	1.84	1.51	2.19	2.19	0.97	0.64	1.96	1.96	2.07	3.51	3.51	3.51	3.51
CFM PER RUN HEAT	35	28	15	56	35	46	8	28	38	35	15	51	42	60	60	27	18	54	54	57	97	97	97	97
RM GAIN MBH.	1.76	1.01	0.74	2.28	1.95	1.63	0.40	1.20	2.78	1.76	0.93	1.14	1.76	1.85	1.85	1.04	0.87	1.39	1.39	0.93	0.42	0.42	0.42	0.42
CFM PER RUN COOLING	64	37	27	83	71	59	15	44	101	64	34	42	64	68	68	38	32	51	51	34	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	36	48	22	65	67	49	44	34	56	26	45	35	26	31	24	19	49	47	46	23	37	22	33	33
EQUIVALENT LENGTH	100	170	160	150	200	190	170	150	160	170	180	120	110	140	130	100	180	140	130	120	100	120	120	180
TOTAL EFFECTIVE LENGTH	136	218	182	215	267	239	214	184	216	196	225	155	136	171	154	119	229	187	176	143	137	142	153	213
ADJUSTED PRESSURE	0.13	0.08	0.09	0.08	0.06	0.07	0.08	0.09	0.08	0.09	0.08	0.11	0.13	0.1	0.11	0.14	0.08	0.09	0.1	0.12	0.12	0.11	0.11	0.08
ROUND DUCT SIZE	5	4	4	6	6	5	4	6	6	5	4	4	5	5	5	4	4	5	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	257	321	172	286	178	338	92	143	194	257	172	585	308	441	441	310	207	396	396	419	495	495	495	495
COOLING VELOCITY (ft/min)	470	424	310	423	362	433	172	224	515	470	390	482	470	499	499	436	367	374	374	250	76	76	76	76
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	F	C	F	C	A	C	B	C	B	F	C	B	F	D	D	E	C	A	A	E	E	D	C	A

RUN #	25	26	27	28	29	30	31	32
ROOM NAME	BED-2	BED-3	ENS	S-ENS	FAM	L/D	BAS	BED-3
RM LOSS MBH.	2.03	1.28	1.02	0.90	1.51	1.84	3.51	1.28
CFM PER RUN HEAT	56	35	28	8	42	51	97	35
RM GAIN MBH.	2.28	1.95	1.01	0.40	1.76	1.14	0.42	1.95
CFM PER RUN COOLING	83	71	37	15	64	42	15	71
ADJUSTED PRESSURE	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.17
ACTUAL DUCT LGH.	60	74	44	40	14	49	46	70
EQUIVALENT LENGTH	180	200	180	180	150	170	180	200
TOTAL EFFECTIVE LENGTH	240	274	224	220	164	219	206	270
ADJUSTED PRESSURE	0.07	0.06	0.08	0.08	0.1	0.08	0.08	0.06
ROUND DUCT SIZE	6	6	4	4	5	5	6	6
HEATING VELOCITY (ft/min)	286	178	321	92	308	374	495	178
COOLING VELOCITY (ft/min)	423	362	424	172	470	308	76	362
OUTLET GRILL SIZE	4X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10
TRUNK	B	A	C	B	F	A	A	A

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)			TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)			
TRUNK A	458	0.06	11.2	14	x	8	589	TRUNK G	0	0.00	0	0	x	8	0	0			
TRUNK B	619	0.06	12.6	18	x	8	619	TRUNK H	0	0.00	0	0	x	8	0	0			
TRUNK C	935	0.06	14.7	26	x	8	647	TRUNK I	0	0.00	0	0	x	8	0	0			
TRUNK D	217	0.10	7.5	8	x	8	488	TRUNK J	0	0.00	0	0	x	8	0	0			
TRUNK E	1152	0.06	15.9	30	x	8	691	TRUNK K	0	0.00	0	0	x	8	0	0			
TRUNK F	350	0.09	9.2	10	x	8	630	TRUNK L	0	0.00	0	0	x	8	0	0			
RETURN AIR #	1	2	3	4	5	6	7	8	9	0	0	0	0	0	0	BR			
AIR VOLUME	75	75	135	115	75	75	185	400	135	0	0	0	0	0	0	234			
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15			
ACTUAL DUCT LGH.	71	68	57	74	67	69	21	23	38	1	1	1	1	1	1	17			
EQUIVALENT LENGTH	245	235	215	235	220	215	155	160	285	0	0	0	0	0	0	145			
TOTAL EFFECTIVE LH	316	303	272	309	287	284	176	183	323	1	1	1	1	1	1	162			
ADJUSTED PRESSURE	0.05	0.05	0.05	0.05	0.05	0.05	0.08	0.08	0.05	14.80	14.80	14.80	14.80	14.80	14.80	0.09			
ROUND DUCT SIZE	6	6	7.5	7	6	6	7.5	9.9	7.5	0	0	0	0	0	0	7.9			
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	0	0	0	0	0	0	8			
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X			
INLET GRILL SIZE	14	14	14	14	14	14	14	30	14	0	0	0	0	0	0	24			
										TRUNK O	0	0.05	0	0	x	8	0		
										TRUNK P	0	0.05	0	0	x	8	0		
										TRUNK Q	0	0.05	0	0	x	8	0		
										TRUNK R	0	0.05	0	0	x	8	0		
										TRUNK S	0	0.05	0	0	x	8	0		
										TRUNK T	0	0.05	0	0	x	8	0		
										TRUNK U	0	0.05	0	0	x	8	0		
										TRUNK V	585	0.05	12.9	20	x	8	527		
										TRUNK W	150	0.05	7.8	8	x	8	338		
										TRUNK X	919	0.05	15.3	28	x	8	591		
										TRUNK Y	685	0.05	13.7	22	x	8	580		
										TRUNK Z	535	0.05	12.5	18	x	8	535		
										DROP	1504	0.05	18.4	24	x	14	645		

TYPE: MOUNTAINASH 6
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 87979
LOT 257

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>3</u> @ 10.6 cfm	<u>31.8</u> cfm
Kitchen & Bathrooms	<u>5</u> @ 10.6 cfm	<u>53</u> cfm
Other Rooms	<u>9</u> @ 10.6 cfm	<u>95.4</u> cfm
Table 9.32.3.A. TOTAL		<u>222.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>78.5</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>222.6</u>	cfm
Less Principal Ventil. Capacity	<u>79.5</u>	cfm
Required Supplemental Capacity	<u>143.1</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
<u>79.5</u> cfm	<u>3.0</u> sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	AT °F	FACTOR	% LOSS	
<u>79.5</u> CFM	<u>X</u>	<u>71 F</u>	<u>X</u>	<u>1.08</u>
			<u>X</u>	<u>0.25</u>

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	<u>50</u>	☒	<u>0.3</u>
S-ENS	FV-05-11VK1	<u>50</u>	☒	<u>0.3</u>
ENS-3	FV-05-11VK1	<u>50</u>	☒	<u>0.3</u>

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
<u>155</u> cfm high	<u>64</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	October-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																																	
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																																	
LO#: 87979		Model: MOUNTAINASH 6		Builder: GREENPARK HOMES			Date: 28/10/2020																																																										
Volume Calculation					Air Change & Delta T Data																																																												
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1480</td> <td>8</td> <td>11840</td> </tr> <tr> <td>First</td> <td>1480</td> <td>10</td> <td>14800</td> </tr> <tr> <td>Second</td> <td>1880</td> <td>9</td> <td>16920</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>43,560.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1233.5 m³</td> </tr> </tbody> </table>					Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1480	8	11840	First	1480	10	14800	Second	1880	9	16920	Third	0	9	0	Fourth	0	9	0	Total:			43,560.0 ft³	Total:			1233.5 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.310</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.111</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>					WINTER NATURAL AIR CHANGE RATE	0.310	SUMMER NATURAL AIR CHANGE RATE	0.111	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																														
Bsmt	1480	8	11840																																																														
First	1480	10	14800																																																														
Second	1880	9	16920																																																														
Third	0	9	0																																																														
Fourth	0	9	0																																																														
Total:			43,560.0 ft³																																																														
Total:			1233.5 m³																																																														
WINTER NATURAL AIR CHANGE RATE	0.310																																																																
SUMMER NATURAL AIR CHANGE RATE	0.111																																																																
Design Temperature Difference																																																																	
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																													
Winter DTDh	22	-17	39	71																																																													
Summer DTDc	24	31	7	13																																																													
5.2.3.1 Heat Loss due to Air Leakage $HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.310 x 342.63 x 39 °C x 1.2 = 4993 W = 17037 Btu/h					6.2.6 Sensible Gain due to Air Leakage $HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ 0.111 x 342.63 x 7 °C x 1.2 = 324 W = 1106 Btu/h																																																												
5.2.3.2 Heat Loss due to Mechanical Ventilation $HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h					6.2.7 Sensible heat Gain due to Ventilation $HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																												
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																																	
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center; vertical-align: middle;">17,037</td> <td>9,047</td> <td>0.942</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>12,931</td> <td>0.395</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>14,622</td> <td>0.233</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table>										Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	17,037	9,047	0.942	2	0.3	12,931	0.395	3	0.2	14,622	0.233	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																													
1	0.5	17,037	9,047	0.942																																																													
2	0.3		12,931	0.395																																																													
3	0.2		14,622	0.233																																																													
4	0		0	0.000																																																													
5	0		0	0.000																																																													
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																																	

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL:	MOUNTAINASH 6	LOT 257	BUILDER:	GREENPARK HOMES
SFQT:	3360	LO#	87979	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	43560.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.50	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.0 ft
LENGTH: 55.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	169.0 ft

2012 OBC - COMPLIANCE PACKAGE		
Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.8	 Insulation Configuration
Floor Width (m):	11.0	
Exposed Perimeter (m):	51.5	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.52	
Window Area (m ²):	2.0	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1630	

TYPE: MOUNTAINASH 6
LO# 87979

LOT 257

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.8	
Width (m):	2.1	
Exposed Perimeter (m):	4.0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		26

TYPE: MOUNTAINASH 6
LO# 87979

LOT 257


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.71			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1233.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1644.3 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.310			
Cooling Air Leakage Rate (ACH/H):	0.111			

TYPE: MOUNTAINASH 6
LO# 87979

LOT 257



BASEMENT PLAN - ELEV. '3'

LOT 257
WUB
CSA-F280-12
PACKAGE A1


I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION 6, 12.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						REVISIONS		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE	3.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE	2.		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE	1.		
					REDUCER			

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 56051 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title BASEMENT HEATING LAYOUT		
		MAKE GOODMAN		3RD FLOOR					
		MODEL GMEC960804CNA		2ND FLOOR	17	6			4
		INPUT 80 MBTU/H		1ST FLOOR	10	3			2
		OUTPUT 76.8 MBTU/H		BASEMENT	5	1			0
		COOLING 3.5 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			Date OCT/2020		
		FAN SPEED 1504 cfm @ 0.5" w.c.					Scale 3/16" = 1'-0"		
							BCIN# 19669		
							LO# 87979		

| Project Name **RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO** | Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed. | | | | | | |
| **LOT 257 MOUNTAINASH 6 3360 sqft** | | | | | | | |



GROUND FLOOR PLAN - ELEV. '3'

INSULATE DUCTS ROUTING THRU GARAGE MIN 2.1 RSI

LOT 257
WUB
CSA-F280-12
PACKAGE A1


I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND							
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

No.	Description	Date
3.		
2.		
1.		
No.	Description	Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date OCT/2020	Scale 3/16" = 1'-0"
LOT 257 MOUNTAINASH 6 3360 sqft			BCIN# 19669	
			LO#	87979



SECOND FLOOR PLAN (5 BDRM)
- ELEV. '3'

LOT 257
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No. Description Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVAC DESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date OCT/2020
LOT 257			Scale 3/16" = 1'-0"
MOUNTAINASH 6 3360 sqft			BCIN# 19669
			LO# 87979