

SITE NAME: RUSSEL GARDENS PHASE 3				LOT 276				DATE: Nov-20				WINTER NATURAL AIR CHANGE RATE 0.305				HEAT LOSS AT °F. 71				CSA-F280-12							
BUILDER: GREENPARK HOMES				TYPE: MOUNTAINASH 5				GFA: 3288				LO# 88386				SUMMER NATURAL AIR CHANGE RATE 0.109				HEAT GAIN AT °F. 13				SB-12 PACKAGE A1			
ROOM USE		MBR		ENS		WIC		BED-2		BED-3		BED-4		ENS-2		FLEX		WIC-3		S-ENS							
EXP. WALL		33		30		7		27		37		12		6		11		5		6							
CLG. HT.		9		9		9		9		9		9		9		9		9		9							
FACTORS																											
GRS.WALL AREA		297		270		63		243		333		108		54		99		45		54							
GLAZING		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN							
NORTH		19.8	15.1	0	0	0	14	277	212	0	0	0	13	257	197	0	0	0	0	0	0	0	0				
EAST		19.8	39.0	0	0	0	0	0	0	0	0	48	948	1873	0	0	0	0	9	178	351	0	0				
SOUTH		19.8	23.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	7					
WEST		19.8	39.0	32	833	1249	14	277	546	0	0	0	0	0	0	0	0	0	0	0	0	138					
SKYL.T.		34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	164					
DOORS		23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
NET EXPOSED WALL		4.1	0.8	265	1089	199	242	1003	182	63	261	47	182	755	137	271	1123	204	92	381	69	47					
NET EXPOSED BSMT WALL ABOVE GR		3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	195					
EXPOSED CLG		1.2	0.6	287	342	169	221	263	130	140	167	82	236	281	139	183	218	108	188	215	106	66					
NO ATTIC EXPOSED CLG		2.6	1.3	0	0	0	0	0	0	16	41	20	45	115	57	0	0	0	0	0	0	79					
EXPOSED FLOOR		2.4	0.4	0	0	0	0	0	0	241	571	104	0	0	0	0	0	0	68	161	29	69					
BASEMENT/CRAWL HEAT LOSS				0		0		0		0		0		0		0		0		0		163					
SLAB ON GRADE HEAT LOSS				0		0		0		0		0		0		0		0		0		30					
SUBTOTAL HT LOSS				2073		1820		428		2854		2682		912		573		1086		470		419					
SUB TOTAL HT GAIN				1616		1070		130		2469		2787		551		209		464		419		242					
LEVEL FACTOR / MULTIPLIER		0.20	0.24		0.20	0.24		0.20	0.24	0.20	0.24		0.20	0.24		0.20	0.24		0.20	0.24		0.20					
AIR CHANGE HEAT LOSS			600			439		103		688		646		220		138		262		113		101					
AIR CHANGE HEAT GAIN				117		78		9		179		202		40		15		34		30		18					
DUCT LOSS			0			0		0		354		0		0		71		135		58		0					
DUCT GAIN						0		0		349		0		0		22		50		45		0					
HEAT GAIN PEOPLE		240	2		480	0	0	0	0	1	240	1	240	1	240	0	0	0	0	0	0	0					
HEAT GAIN APPLIANCES/LIGHTS					602		0		0	602		602		602		0		0		0		0					
TOTAL HT LOSS BTU/H				2573		2259		531		3895		3329		1132		782		1483		641		520					
TOTAL HT GAIN x 1.3 BTU/H				3660		1492		181		4991		4980		1862		321		711		643		337					

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	FAM	L/D	K/B	L/H	LND	W/R	FOY	MUD	WUB	BAS
				36	30	37	19	12	18	18	30	25	155
				10	10	10	10	9	11	11	11	9	9
GRS.WALL AREA	LOSS	GAIN		360	300	370	190	108	198	196	330	225	1008
GLAZING	LOSS	GAIN		LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	19.8	15.1	0	0	0	0	0	0	0	0	7	138	106
EAST	19.8	39.0	0	0	0	0	0	0	22	435	863	6	119
SOUTH	19.8	23.5	0	0	40	791	939	0	0	0	0	0	0
WEST	19.8	39.0	40	791	1561	0	0	60	1185	2341	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	320	1327	241	260	1078	195	310	1285	233	177	734
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	180	215	106	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS													
SLAB ON GRADE HEAT LOSS													
SUBTOTAL HT LOSS				2117	1889	2471	991	772	1165	1687	1477	217	1536
SUB TOTAL HT GAIN				1801	1135	2574	438	346	991	518	349	239	630
LEVEL FACTOR / MULTIPLIER	0.30	0.43		0.30	0.43	0.30	0.43	0.20	0.24	0.30	0.43	0.30	0.43
AIR CHANGE HEAT LOSS	916			808	1969	187	32	25	72	38	25	0	0
AIR CHANGE HEAT GAIN				131	82								
DUCT LOSS				0	0	0	0	0	0	0	0	0	0
DUCT GAIN				0	0	0	0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240	0		0	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS				602	602	602	602	602	0	0	0	0	0
TOTAL HT LOSS BTU/H				3033	2677	3540	1419	958	1668	2417	2116	1536	15360
TOTAL HT GAIN x 1.3 BTU/H				3294	2364	4372	1393	1265	1381	723	486	311	1684

TOTAL HEAT GAIN BTU/H: 36727

TONS: 3.05

LOSS DUE TO VENTILATION LOAD BTU/H: 1616

STRUCTURAL HEAT LOSS: 51860

TOTAL COMBINED HEAT LOSS BTU/H: 53375

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

SITE NAME: RUSSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 276
TYPE: MOUNTAINASH 5

DATE: Nov-20

GFA: 3288 LO# 88386

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 51,860 TOTAL HEAT GAIN 36,452
AIR FLOW RATE CFM 21.81 AIR FLOW RATE CFM 31.03

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MEDLOW 928
MEDIUM 1017
MEDIUM HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

DESIGN CFM = 1131
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	15	8	4
R/A	0	0	6	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	ENS-2	FLEX	WIC-3	MBR	S-ENS	FAM	L/D	K/B	K/B	L/H	LND	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.29	1.13	0.53	1.95	1.66	1.13	0.78	1.48	0.64	1.29	0.52	3.03	2.68	1.77	1.77	1.42	0.96	1.67	2.42	2.12	4.22	4.22	4.22	4.22
CFM PER RUN HEAT	28	25	12	42	36	25	17	32	14	28	11	66	58	39	39	31	21	36	53	46	92	92	92	92
RM GAIN MBH	1.83	0.75	0.18	2.50	2.49	1.86	0.32	0.71	0.64	1.83	0.34	3.29	2.36	2.19	2.19	1.39	1.26	1.38	0.72	0.49	0.50	0.50	0.50	0.50
CFM PER RUN COOLING	57	23	6	77	77	58	10	22	20	57	10	102	73	68	68	43	39	43	22	15	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	37	56	39	59	56	34	34	51	45	39	39	22	10	40	31	27	20	33	41	44	38	34	5	31
EQUIVALENT LENGTH	190	160	150	130	170	200	220	160	110	130	150	140	130	150	160	140	180	110	90	140	140	150	140	130
TOTAL EFFECTIVE LENGTH	227	216	189	189	226	234	254	211	155	169	189	162	140	190	191	167	200	143	131	184	178	184	145	161
ADJUSTED PRESSURE	0.08	0.08	0.09	0.09	0.08	0.07	0.07	0.08	0.11	0.1	0.09	0.1	0.12	0.09	0.09	0.1	0.09	0.12	0.13	0.09	0.09	0.09	0.11	0.1
ROUND DUCT SIZE	5	4	4	6	6	6	4	4	4	5	4	6	5	5	5	4	4	4	5	4	6	6	6	6
HEATING VELOCITY (ft/min)	206	287	138	214	184	127	195	367	161	206	126	337	426	286	286	356	241	413	369	528	469	469	469	469
COOLING VELOCITY (ft/min)	419	264	69	393	393	296	115	252	229	419	115	520	536	499	499	493	447	493	162	172	76	76	76	76
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	B	A	B	D	C	C	C	A	D	B	D	B	D	A	A	C	B	C	C	A	A	B	D	C

RUN #	25	26	27
ROOM NAME	BED-2	BED-3	ENS
RM LOSS MBH	1.95	1.66	1.13
CFM PER RUN HEAT	42	36	25
RM GAIN MBH	2.50	2.49	0.75
CFM PER RUN COOLING	77	77	23
ADJUSTED PRESSURE	0.17	0.17	0.17
ACTUAL DUCT LGH	52	48	52
EQUIVALENT LENGTH	120	170	130
TOTAL EFFECTIVE LENGTH	172	218	182
ADJUSTED PRESSURE	0.1	0.08	0.09
ROUND DUCT SIZE	6	6	4
HEATING VELOCITY (ft/min)	214	184	287
COOLING VELOCITY (ft/min)	393	393	264
OUTLET GRILL SIZE	4X10	4X10	3X10
TRUNK	D	C	A

SUPPLY AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY	RETURN AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY
	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)		CFM	PRESS.	DUCT	DUCT	(ft/min)
TRUNK A	298	0.08	8.9	10	536	TRUNK G	0	0.00	0	0	TRUNK O	0	0.05	0	0	8
TRUNK B	545	0.08	11.2	14	701	TRUNK H	0	0.00	0	0	TRUNK P	0	0.05	0	0	8
TRUNK C	326	0.07	9.5	10	587	TRUNK I	0	0.00	0	0	TRUNK Q	0	0.05	0	0	8
TRUNK D	585	0.07	11.9	16	658	TRUNK J	0	0.00	0	0	TRUNK R	0	0.05	0	0	8
TRUNK E	0	0.00	0	0	0	TRUNK K	0	0.00	0	0	TRUNK S	0	0.05	0	0	8
TRUNK F	0	0.00	0	0	0	TRUNK L	0	0.00	0	0	TRUNK T	0	0.05	0	0	8
											TRUNK U	0	0.05	0	0	8
											TRUNK V	0	0.05	0	0	8
											TRUNK W	0	0.05	0	0	8
											TRUNK X	1041	0.05	16	30	8
											TRUNK Y	695	0.05	13.8	22	8
											TRUNK Z	445	0.05	11.6	16	8
											DROP	1131	0.05	16.5	24	10

RETURN AIR #	1	2	3	4	5	6	7	8													BR
AIR VOLUME	90	85	90	90	85	75	360	85	0	0	0	0	0	0	0	0	0	171			
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15			
ACTUAL DUCT LGH	41	52	53	58	53	59	45	41	1	1	1	1	1	1	1	1	15				
EQUIVALENT LENGTH	185	195	165	165	215	265	165	190	0	0	0	0	0	0	0	0	150				
TOTAL EFFECTIVE LH	226	247	218	223	268	324	210	231	1	1	1	1	1	1	1	1	165				
ADJUSTED PRESSURE	0.07	0.06	0.07	0.07	0.06	0.05	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.09				
ROUND DUCT SIZE	5.9	6	5.9	5.9	6	6	9.9	6	0	0	0	0	0	0	0	0	7				
INLET GRILL SIZE	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	8				
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X				
INLET GRILL SIZE	14	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	14				

TYPE: MOUNTAINASH 5
SITE NAME: RUSSEL GARDENS PHASE 3

LO # 88386
LOT 276

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	7 @ 10.6 cfm	74.2 cfm
Table 9.32.3.A.	TOTAL	201.4 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL	79.5 cfm	

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.6.
Total Ventilation Capacity	201.4	cfm
Less Principal Ventill. Capacity	79.5	cfm
Required Supplemental Capacity	121.9	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE 65H
Location:	BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	X	71 F	X	1.08
				X
				0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	60	☒	0.3
ENS-2	FV-05-11VK1	60	☒	0.3
S-ENS	FV-05-11VK1	60	☒	0.3
W/R	FV-05-11VK1	60	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE 65H	
155 cfm high	64 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	November-20

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 *Michael O'Rourke* MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 88386

Model: MOUNTAINASH 5

Builder: GREENPARK HOMES

Date: 26/11/2020

Volume Calculation
House Volume

Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)
Bsmt	1451	9	13059
First	1451	10	14510
Second	1837	9	16533
Third	0	9	0
Fourth	0	9	0
Total:			44,102.0 ft³
Total:			1248.8 m³

Air Change & Delta T Data

WINTER NATURAL AIR CHANGE RATE	0.305
SUMMER NATURAL AIR CHANGE RATE	0.109

Design Temperature Difference

	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.305 \times 346.90 \times 39^\circ\text{C} \times 1.2 = 4976 \text{ W}$$

$$= 16979 \text{ Btu/h}$$

6.2.6 Sensible Gain due to Air Leakage

$$HG_{saib} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$= 0.109 \times 346.90 \times 7^\circ\text{C} \times 1.2 = 323 \text{ W}$$

$$= 1102 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation

$$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 71^\circ\text{F} \times 1.08 \times 0.25 = 1515 \text{ Btu/h}$$

6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{level})
1	0.5	16,979	8,396	1.011
2	0.3		11,777	0.433
3	0.2		14,089	0.241
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairv = 0

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: MOUNTAINASH 5	LOT 276	BUILDER: GREENPARK HOMES
SFQT: 3288	LO# 88386	SITE: RUSSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	44102.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.5 ft
LENGTH: 54.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	155.0 ft


2012 OBC - COMPLIANCE PACKAGE		Compliance Package A1	
Component		Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value		60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value		31	27.65
Exposed Floor Minimum RSI (R)-Value		31	29.80
Walls Above Grade Minimum RSI (R)-Value		22	17.03
Basement Walls Minimum RSI (R)-Value		20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value		-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value		10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value		10	11.13
Windows and Sliding Glass Doors Maximum U-Value		0.28	-
Skylights Maximum U-Value		0.49	-
Space Heating Equipment Minimum AFUE		0.96	-
HRV Minimum Efficiency		75%	-
Domestic Hot Water Heater Minimum EF		0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.5	
Floor Width (m):	11.0	
Exposed Perimeter (m):	47.2	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.98	
Window Area (m ²):	1.4	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1406	

TYPE: MOUNTAINASH 5
LO# 88386

LOT 276

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	
Width (m):	4.6	
Exposed Perimeter (m):	7.6	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		64

TYPE: MOUNTAINASH 5
LO# 88386

LOT 276


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.55			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1248.8			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1664.7 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.305			
Cooling Air Leakage Rate (ACH/H):	0.109			

TYPE: MOUNTAINASH 5
LO# 88386

LOT 276



BASEMENT FLOOR PLAN '1'
CITY OF HAMILTON
Building Division

Permit No. 21-107196
THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
These drawings and/or specifications have been reviewed by
gr 04/22/21
FOR CHIEF BUILDING OFFICIAL DATE

LOT 276
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL OROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael Orouke
Michael Orouke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						REVISIONS		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE	3.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE	2.		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE	1.		
					REDUCER	No.		


ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES
Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**

**LOT 276
MOUNTAINASH 5 3288 sqft**

HVACDESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

HEAT LOSS 53375 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title BASEMENT HEATING LAYOUT Date NOV/2020 Scale 3/16" = 1'-0" BCIN# 19669 LO# 88386
MAKE	GOODMAN	3RD FLOOR			
MODEL	GMEC960603BNA	2ND FLOOR	15	6	
INPUT	60 MBTU/H	1ST FLOOR	8	2	
OUTPUT	57.6 MBTU/H	BASEMENT	4	1	
COOLING	3.0 TONS	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5'Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			
FAN SPEED	1131 cfm @ 0.6" w.c.				



GROUND FLOOR PLAN '1'

LOT 276
WUB
CSA-F280-12
PACKAGE A1

HVAC LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x6" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

No.	Description	Date
3.		
2.		
1.		
No.		


REVISIONS

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES
Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**
**LOT 276
MOUNTAINASH 5 3288 sqft**

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**FIRST FLOOR
HEATING
LAYOUT**
Date
NOV/2020
Scale
3/16" = 1'-0"
BCIN# 19669
LO# 88386



SECOND FLOOR PLAN '1'

LOT 276
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL OROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						REVISIONS	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE	2.	
	SUPPLY AIR BOOT ABOVE		8" SUPPLY AIR STACK 2nd FLOOR		FRA-FLOOR RETURN AIR GRILLE	3.	
					REDUCER		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**

**LOT 276
MOUNTAINASH 5 3288 sqft**

HVAC DESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**SECOND FLOOR
HEATING
LAYOUT**

Date
NOV/2020

Scale
3/16" = 1'-0"

BCIN# 19669

LO# **88386**