

SITE NAME: RESSEL GARDENS PHASE 3

LOT 285

DATE: Dec-20

WINTER NATURAL AIR CHANGE RATE 0.310

HEAT LOSS AT °F. 71

CSA-F280-12

BUILDER: GREENPARK HOMES

TYPE: VALLEYCREAK 4

GFA: 2795

LC# 88621

SUMMER NATURAL AIR CHANGE RATE 0.111

HEAT GAIN AT °F. 13

SB-12 PACKAGE A1

ROOM USE	MBR	ENS	BED-2	BED-3	BED-4	S-BATH	ENS-4
EXP. WALL	41	30	11	28	39	6	7
CLG. HT.	9	9	9	9	9	9	9
FACTORS							
GRS.WALL AREA	369	270	99	282	351	54	63
GLAZING	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN
NORTH	19.8 16.0 0 0 0	9 178 144	16 316 256	0 0 0	0 0 0	7 138 112	0 0 0
EAST	19.8 41.6 0 0 0	0 0 0	0 0 0	45 890 1870	32 633 1330	0 0 0	16 316 665
SOUTH	19.8 24.9 16 316 398	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
WEST	19.8 41.6 36 712 1496	16 316 665	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
SKYLT.	34.6 101.5 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
DOORS	23.5 4.3 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
NET EXPOSED WALL	4.1 0.8 317 1314 238	245 1016 184	344 62 207 858 156	319 1322 240	47 195 35	47 195 35	47 195 35
NET EXPOSED BSMT WALL ABOVE GR	3.3 0.6 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
EXPOSED CLG	1.2 0.6 363 433 213	228 262 129	207 247 122 214 255 126	228 262 129	119 142 70	75 89 44	75 89 44
NO ATTIC EXPOSED CLG	2.6 1.3 0 0 0	0 0 0	0 0 0	40 102 50	0 0 0	0 0 0	0 0 0
EXPOSED FLOOR	2.4 0.4 0 0 0	0 0 0	0 0 0	0 0 0	85 204 37	75 178 32	75 178 32
BASEMENT/CRAWL HEAT LOSS	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS	0	0	0	0	0	0	0
SUBTOTAL HT LOSS	2775	1772	997	2510	2319	679	778
SUB TOTAL HT GAIN	2346	1122	440	2243	1749	254	776
LEVEL FACTOR / MULTIPLIER	0.20 0.24	0.20 0.24	0.20 0.24	0.20 0.24	0.20 0.24	0.20 0.24	0.20 0.24
AIR CHANGE HEAT LOSS	660	424	31	597	552	161	185
AIR CHANGE HEAT GAIN	166	19	31	158	123	18	55
DUCT LOSS	0	0	0	311	0	84	96
DUCT GAIN	0	0	0	331	0	27	83
HEAT GAIN PEOPLE	240	2	480	0	240	0	0
HEAT GAIN APPLIANCES/LIGHTS	665	0	665	1	665	0	0
TOTAL HT LOSS BTU/H	3435	2194	1123	3417	2871	924	1060
TOTAL HT GAIN x 1.3 BTU/H	4753	1552	1788	4728	3611	389	1189

ROOM USE	LV/DN	LJB	BF/KT	FAM	LAUN	WR	FOY	MUD	WUB	BAS
EXP. WALL	39	20	35	37	9	4	30	9	24	162
CLG. HT.	10	10	10	10	9	10	10	10	9	9
FACTORS										
GRS.WALL AREA	390	200	350	370	81	40	300	90	216	912
GLAZING	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN
NORTH	19.8 16.0 0 0 0	18 356 288	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	5 99 80
EAST	19.8 41.6 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
SOUTH	19.8 24.9 26 514 647	0 0 0	0 0 0	0 0 0	3 158 199	3 158 199	0 0 0	0 0 0	0 0 0	5 99 124
WEST	19.8 41.6 0 0 0	0 0 0	70 1384 2509	40 791 1652	0 0 0	0 0 0	0 0 0	0 0 0	5 99 208	0 0 0
SKYLT.	34.6 101.5 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
DOORS	23.5 4.3 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	47 1102 200	20 469 85	20 469 85	20 469 85
NET EXPOSED WALL	4.1 0.8 364 1509 274	182 755 137	280 1161 210	330 1368 248	73 303 55	32 133 24	253 1049 190	70 290 53	191 792 144	0 0 0
NET EXPOSED BSMT WALL ABOVE GR	3.3 0.6 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	456 1524 276
EXPOSED CLG	1.2 0.6 0 0 0	0 0 0	0 0 0	16 19 9	115 137 68	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
NO ATTIC EXPOSED CLG	2.6 1.3 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
EXPOSED FLOOR	2.4 0.4 0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0
BASEMENT/CRAWL HEAT LOSS	0	0	0	0	0	0	0	0	0	4953
SLAB ON GRADE HEAT LOSS	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS	2023	1110	2545	2178	598	291	2151	759	1561	7144
SUB TOTAL HT GAIN	921	424	3119	1920	322	223	390	138	436	566
LEVEL FACTOR / MULTIPLIER	0.30 0.40	0.30 0.40	0.30 0.40	0.30 0.40	0.20 0.24	0.30 0.40	0.30 0.40	0.30 0.40	0.30 0.40	0.50 0.84
AIR CHANGE HEAT LOSS	805	442	1013	867	142	116	856	302	7335	71
AIR CHANGE HEAT GAIN	65	30	220	135	23	16	28	10	0	0
DUCT LOSS	0	0	0	0	0	0	0	0	0	0
DUCT GAIN	0	0	0	0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS	665	665	665	665	665	665	665	665	665	665
TOTAL HT LOSS BTU/H	2828	1552	3557	3045	740	407	3007	1061	1561	14479
TOTAL HT GAIN x 1.3 BTU/H	2146	1455	6206	3536	1312	311	543	192	557	1692

TOTAL HEAT GAIN BTU/H: 35255

TONS: 2.94

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 47261

TOTAL COMBINED HEAT LOSS BTU/H: 45777

SITE NAME: RESSEL GARDENS PHASE 3
BUILDER: GREENPARK HOMES

LOT 285
TYPE: VALLEYCREEK 4

DATE: Dec-20

GFA: 2795

LO# 88621

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 47,261 TOTAL HEAT GAIN 34,980
AIR FLOW RATE CFM 23.93 AIR FLOW RATE CFM 32.33

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600
DESIGN CFM = 1131
CFM @ .5" E.S.P.

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	8	4
R/A	0	0	4	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

plenium pressure s/a 0.18 r/a pressure 0.17
max s/a diff press. loss 0.03 r/a grille press. loss 0.02
min adjusted pressure s/a 0.15 adjusted pressure r/a 0.15

TEMPERATURE RISE 47 °F

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-3	BED-2	BED-3	BED-4	S-BATH	S-BATH	BED-4	MBR	ENS-4	LVDN	LIB	BF/KT	BF/KT	FAM	LAUN	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.72	2.19	1.71	1.12	1.71	1.44	0.46	0.46	1.44	1.72	1.06	2.83	1.55	1.78	1.78	3.04	0.74	0.41	3.01	1.06	4.01	4.01	4.01	4.01
CFM PER RUN HEAT	41	52	41	27	41	34	11	11	34	41	25	68	37	43	43	73	18	10	72	25	96	96	96	96
RM GAIN MBH	2.38	1.56	2.36	1.79	2.36	1.81	0.19	0.19	1.81	2.38	1.19	2.15	1.46	2.60	2.60	3.54	1.31	0.31	0.54	0.19	0.56	0.56	0.56	0.56
CFM PER RUN COOLING	77	50	76	58	76	58	6	6	58	77	38	69	47	84	84	114	42	10	18	6	18	18	18	18
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.15	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	48	44	46	30	42	51	32	36	44	33	34	35	18	25	32	28	31	33	40	13	24	43	16	36
EQUIVALENT LENGTH	180	120	140	160	130	150	160	150	130	140	120	150	150	120	140	130	200	160	120	190	100	90	150	130
TOTAL EFFECTIVE LENGTH	228	164	186	190	172	201	192	186	174	173	154	185	168	145	172	158	231	193	160	203	124	133	166	166
ADJUSTED PRESSURE	0.08	0.1	0.09	0.09	0.1	0.09	0.09	0.09	0.1	0.11	0.09	0.1	0.11	0.09	0.1	0.09	0.1	0.07	0.09	0.11	0.08	0.13	0.12	0.1
ROUND DUCT SIZE	6	5	5	6	5	5	4	4	5	6	4	6	5	6	6	6	5	4	5	4	8	6	6	6
HEATING VELOCITY (ft/min)	209	382	301	138	301	250	126	126	250	209	287	347	272	219	219	372	132	115	529	287	489	489	489	489
COOLING VELOCITY (ft/min)	393	367	558	296	558	426	69	69	426	393	436	352	345	428	428	581	308	115	132	69	92	92	92	92
OUTLET GRILL SIZE	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	4X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	A	D	B	D	C	D	D	C	A	D	C	B	A	A	A	D	C	C	D	B	B	D	C

RUN #	ROOM NAME	RM LOSS MBH	CFM PER RUN HEAT	RM GAIN MBH	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.72	41	2.38	77	0.17	48	180	228	0.08	6	209	393	4X10	A
2	ENS	2.19	52	1.56	50	0.17	44	120	164	0.1	5	382	367	3X10	A
3	BED-3	1.71	41	2.36	76	0.17	46	140	186	0.09	5	301	558	3X10	D
4	BED-2	1.12	27	1.79	58	0.17	30	160	190	0.09	6	138	296	4X10	B
5	BED-3	1.71	41	2.36	76	0.17	42	130	172	0.1	5	301	558	3X10	D
6	BED-4	1.44	34	1.81	58	0.17	51	150	201	0.09	5	250	426	3X10	C
7	S-BATH	0.46	11	0.19	6	0.17	32	160	192	0.09	4	126	69	3X10	D
8	S-BATH	0.46	11	0.19	6	0.17	36	150	186	0.09	4	126	69	3X10	D
9	BED-4	1.44	34	1.81	58	0.17	44	130	174	0.1	5	250	426	3X10	C
10	MBR	1.72	41	2.38	77	0.17	33	140	173	0.11	6	209	393	4X10	A
11	ENS-4	1.06	25	2.15	38	0.17	34	120	154	0.09	4	287	436	3X10	D
12	LVDN	2.83	68	2.60	69	0.17	35	150	185	0.1	6	347	352	4X10	C
13	LIB	1.55	37	1.46	47	0.17	18	120	145	0.11	5	272	345	3X10	B
14	BF/KT	1.78	43	2.60	84	0.16	25	140	172	0.09	6	219	428	4X10	A
15	BF/KT	1.78	43	2.60	84	0.16	32	140	172	0.09	6	219	428	4X10	A
16	FAM	3.04	73	3.54	114	0.15	28	130	158	0.1	6	372	581	4X10	A
17	LAUN	0.74	18	1.31	42	0.17	31	200	193	0.07	5	132	308	3X10	D
18	W/R	0.41	10	0.31	10	0.17	33	160	160	0.09	4	115	115	3X10	C
19	FOY	3.01	72	0.54	18	0.17	40	120	124	0.11	5	529	92	3X10	C
20	MUD	1.06	25	0.19	6	0.17	13	190	100	0.08	4	287	69	3X10	D
21	BAS	4.01	96	0.56	18	0.16	24	90	133	0.13	8	489	92	4X10	B
22	BAS	4.01	96	0.56	18	0.16	43	150	166	0.12	6	489	92	4X10	B
23	BAS	4.01	96	0.56	18	0.16	16	130	166	0.1	6	489	92	4X10	D
24	BAS	4.01	96	0.56	18	0.16	36	130	166	0.1	6	489	92	4X10	C

SUPPLY AIR TRUNK SIZE																RETURN AIR TRUNK SIZE									
	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY			
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)			
	TRUNK A	293	0.08	8.9	14	x	8	377	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.06	0	0	x	8	0	
	TRUNK B	549	0.08	11.2	18	x	8	549	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.06	0	0	x	8	0	
	TRUNK C	314	0.09	8.8	10	x	8	565	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.06	0	0	x	8	0	
	TRUNK D	582	0.07	11.8	16	x	8	655	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.06	0	0	x	8	0	
	TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.06	0	0	x	8	0	
	TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.06	0	0	x	8	0	
																TRUNK U	0	0.06	0	0	x	8	0		
																TRUNK V	0	0.06	0	0	x	8	0		
																TRUNK W	0	0.06	0	0	x	8	0		
																TRUNK X	1131	0.06	15.8	30	x	8	579		
																TRUNK Y	475	0.06	11.4	16	x	8	534		
																TRUNK Z	0	0.06	0	0	x	8	0		
																DROP	1131	0.06	15.8	24	x	10	579		

RETURN AIR #	1	2	3	4	5	6	7								BR
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AIR VOLUME	120	185	105	290	105	105	95	0	0	0	0	0	0	0	126
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	39	38	51	30	18	22	45	1	1	1	1	1	1	1	17
EQUIVALENT LENGTH	215	145	135	150	175	175	175	0	0	0	0	0	0	0	220
TOTAL EFFECTIVE LH	254	183	186	180	193	197	220	1	1	1	1	1	1	1	237
ADJUSTED PRESSURE	0.06	0.08	0.08	0.08	0.08	0.08	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.06
ROUND DUCT SIZE	6.8	7.5	6	8.8	6	6	6	0	0	0	0	0	0	0	6.9
INLET GRILL SIZE	8	8	8	8	6	8	8	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	30	12	14	14	0	0	0	0	0	0	0	14

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	39	38	51	30	18	22	45	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	215	145	135	150	175	175	175	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	254	183	186	180	193	197	220	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.06	0.08	0.08	0.08	0.08	0.08	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	6.8	7.5	6	8.8	6	6	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	30	12	14	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: VALLEYCREEK 4
 SITE NAME: RESSEL GARDENS PHASE 3

 LO # 88821
 LOT 285

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒	Forced Air
☐	Non Forced Air
☐	Electric Space Heat

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	6 @ 10.6 cfm	63.6 cfm
Table 9.32.3.A. TOTAL		190.8 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.6.
Total Ventilation Capacity	190.8	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	111.3	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANE 65H	Location: BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	$\Delta T^{\circ}F$	FACTOR	% LOSS
79.6 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
S-BATH	FV-05-11VK1	50	☒	0.3
ENS-4	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANE 65H		
165 cfm high	64 cfm low	
75 % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	December-20

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.6 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 18869

MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																														
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																														
LO#: 88621	Model: VALLEYCREEK 4	Builder: GREENPARK HOMES	Date: 14/12/2020																																																											
Volume Calculation			Air Change & Delta T Data																																																											
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1226</td> <td>9</td> <td>11034</td> </tr> <tr> <td>First</td> <td>1226</td> <td>10</td> <td>12260</td> </tr> <tr> <td>Second</td> <td>1579</td> <td>9</td> <td>14211</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>37,505.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1062.0 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1226	9	11034	First	1226	10	12260	Second	1579	9	14211	Third	0	9	0	Fourth	0	9	0	Total:			37,505.0 ft³	Total:			1062.0 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">WINTER NATURAL AIR CHANGE RATE</th> <th>0.310</th> </tr> </thead> <tbody> <tr> <td colspan="2">SUMMER NATURAL AIR CHANGE RATE</td> <td>0.111</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE		0.310	SUMMER NATURAL AIR CHANGE RATE		0.111	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																											
Bsmt	1226	9	11034																																																											
First	1226	10	12260																																																											
Second	1579	9	14211																																																											
Third	0	9	0																																																											
Fourth	0	9	0																																																											
Total:			37,505.0 ft³																																																											
Total:			1062.0 m³																																																											
WINTER NATURAL AIR CHANGE RATE		0.310																																																												
SUMMER NATURAL AIR CHANGE RATE		0.111																																																												
Design Temperature Difference																																																														
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																										
Winter DTDh	22	-17	39	71																																																										
Summer DTDc	24	31	7	13																																																										
5.2.3.1 Heat Loss due to Air Leakage $HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.310 x 295.01 x 39 °C x 1.2 = 4299 W = 14669 Btu/h			6.2.6 Sensible Gain due to Air Leakage $HG_{saib} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ 0.111 x 295.01 x 7 °C x 1.2 = 279 W = 952 Btu/h																																																											
5.2.3.2 Heat Loss due to Mechanical Ventilation $HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			6.2.7 Sensible heat Gain due to Ventilation $HL_{vaib} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																											
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																														
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																										
1	0.5	14,669	8,706	0.843																																																										
2	0.3		11,057	0.398																																																										
3	0.2		12,338	0.238																																																										
4	0		0	0.000																																																										
5	0		0	0.000																																																										
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																														

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: VALLEYCREEK 4	LOT 285	BUILDER: GREENPARK HOMES
SFQT: 2795	LO# 88621	SITE: RESSEL GARDENS PHASE 3

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	37505.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.65	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 54.0 ft	WIDTH: 34.0 ft	EXPOSED PERIMETER:	152.0 ft


2012 OBC - COMPLIANCE PACKAGE		Compliance Package A1	
Component		Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value		60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value		31	27.65
Exposed Floor Minimum RSI (R)-Value		31	29.80
Walls Above Grade Minimum RSI (R)-Value		22	17.03
Basement Walls Minimum RSI (R)-Value		20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value		-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value		10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value		10	11.13
Windows and Sliding Glass Doors Maximum U-Value		0.28	-
Skylights Maximum U-Value		0.49	-
Space Heating Equipment Minimum AFUE		0.96	-
HRV Minimum Efficiency		75%	-
Domestic Hot Water Heater Minimum EF		0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.5	
Floor Width (m):	10.4	
Exposed Perimeter (m):	46.3	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.4	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1451

TYPE: VALLEYCREEK 4
LO# 88621

LOT 285

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	 Insulation Configuration
Width (m):	4.3	
Exposed Perimeter (m):	7.3	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		59

TYPE: VALLEYCREEK 4
LO# 88621

LOT 285


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.71			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1062.0			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1415.7 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.310			
Cooling Air Leakage Rate (ACH/H):	0.111			

TYPE: VALLEYCREEK 4
LO# 88621

LOT 285



BASEMENT FLOOR PLAN 3


LOT 285
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.3 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 48777 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS				Sheet Title	
GREENPARK HOMES		MAKE GOODMAN	MODEL GMEC960603BNA	INPUT 60 MBTU/H	OUTPUT 57.6 MBTU/H	COOLING 3.0 TONS	FAN SPEED 1131 cfm @ 0.6" w.c.	BASEMENT HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO								Date DEC/2020	
								Scale 3/16" = 1'-0"	
								BCIN# 19669	
								LO# 88621	
LOT 285 VALLEYCREEK 4 2795 sqft									



FIRST FLOOR PLAN 3

LOT 285
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


HVAC LEGEND									
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	3.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.	
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No.	
								REVISIONS	
								Description	Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES
Project Name
**RUSSEL GARDENS PHASE 3
HAMILTON, ONTARIO**
**LOT 285
VALLEYCREEK 4 2795 sqft**

HVACDESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**FIRST FLOOR
HEATING
LAYOUT**
Date
DEC/2020
Scale
3/16" = 1'-0"
BCIN# 19669
LO# 88621



SECOND FLOOR PLAN '3'

LOT 285
WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 32.5 OF THE BUILDING CODE.
Michael O'Rourke
REGISTERED PROFESSIONAL ENGINEER 19669
HVAC DESIGNS LTD.

HVAC LEGEND									
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.	
	SUPPLY AIR GRILLE 8" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.	
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.	
								No.	Description
									Date

REVISIONS

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.® AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PHASE 3 HAMILTON, ONTARIO			Date DEC/2020	
LOT 285 VALLEYCREEK 4 2795 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 88621	