

20.130062.000.00.CM

Issue Date: 02/05/21

LAMPONE INVESTMENT INC

ALL CONSTRUCTION SHALL COMPLY WITH THE
ONTARIO BUILDING CODE.

CITY OF MARKHAM

HEAT LOSS/HEAT GAIN CALCULATIONS

MODEL NAME : KIMBERLY 2

ELEV 1, 2 & 3

SITE NAME: LAMPONE INVESTMENTS

BUILDER: GREENPARK HOMES

TYPE: KIMBERLY 2

GFA: 2866

DATE: Jul-20

LO# 86802

WINTER NATURAL AIR CHANGE RATE 0.361

SUMMER NATURAL AIR CHANGE RATE 0.113

HEAT LOSS ΔT °F. 78

HEAT GAIN ΔT °F. 13

CSA-F280-12

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	BED-2	BED-3	BED-4	ENS-2	S-BATH
			36	10	31	33	39	6	6
			9	9	9	9	9	9	9
FACTORS									
GRS.WALL AREA	LOSS	GAIN	324	90	279	297	351	54	54
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	21.8	16.0	0	0	0	0	0	0	0
EAST	21.8	41.6	0	0	0	0	0	0	0
SOUTH	21.8	24.9	0	0	0	0	0	0	0
WEST	21.8	41.6	21	457	873	0	0	0	0
SKYLT.	38.1	101.5	0	0	0	0	0	0	0
DOORS	25.8	4.3	0	0	0	0	0	0	0
NET EXPOSED WALL	4.6	0.8	303	1384	228	76	347	57	54
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	247
EXPOSED CLG	1.3	0.6	323	424	190	180	236	106	41
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	112
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	147
SUBTOTAL HT LOSS			2266	889	1950	3211	3121	509	686
SUB TOTAL HT GAIN				1290	1107	2381	3061	273	155
LEVEL FACTOR / MULTIPLIER	0.20	0.30	0.20	0.30	0.20	0.30	0.20	0.30	0.20
AIR CHANGE HEAT LOSS			681	267	586	964	937	153	206
AIR CHANGE HEAT GAIN			100	40	86	185	238	21	12
DUCT LOSS			0	0	0	418	0	0	89
DUCT GAIN			0	0	0	353	0	0	89
HEAT GAIN PEOPLE	240	2	480	0	1	240	1	240	0
HEAT GAIN APPLIANCES/LIGHTS			721	0	721	721	721	0	721
TOTAL HT LOSS BTU/H			2947	1156	2535	4593	4059	662	982
TOTAL HT GAIN x 1.3 BTU/H			3369	717	2801	5044	5538	383	1269

ROOM USE	EXP. WALL	CLG. HT.	FAM	KT/BF	LV/DN	LAUN	FOY	MUD	WOD	BAS
			32	51	46	9	16	28	47	170
			11	11	11	9	12	12	9	9
FACTORS										
GRS.WALL AREA	LOSS	GAIN	352	561	506	81	192	336	423	1346
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	21.8	16.0	0	0	0	0	0	0	0	0
EAST	21.8	41.6	0	0	0	0	0	0	0	0
SOUTH	21.8	24.9	0	0	0	0	0	0	0	0
WEST	21.8	41.6	24	523	997	64	1394	2659	0	0
SKYLT.	38.1	101.5	0	0	0	0	0	0	0	0
DOORS	25.8	4.3	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.6	0.8	328	1498	247	497	2270	374	467	2133
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	102	134
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2021	3665	2983	625	1728	1961	0	4748
SUB TOTAL HT GAIN				1244	3033	1572	284	323	1256	6075
LEVEL FACTOR / MULTIPLIER	0.30	0.48	0.30	0.48	0.30	0.48	0.30	0.48	0.50	1.36
AIR CHANGE HEAT LOSS			977	1771	1442	188	835	947	662	9953
AIR CHANGE HEAT GAIN			97	236	122	32	22	25	79	79
DUCT LOSS			0	0	0	0	0	0	0	0
DUCT GAIN			0	0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			721	721	721	721	721	0	0	721
TOTAL HT LOSS BTU/H			2998	5436	4425	812	2563	2908	1256	16028
TOTAL HT GAIN x 1.3 BTU/H			2680	5187	3140	1507	398	452	861	1489

TOTAL HEAT GAIN BTU/H:

35108

TONS: 2.93

LOSS DUE TO VENTILATION LOAD BTU/H: 1670

STRUCTURAL HEAT LOSS: 53358

TOTAL COMBINED HEAT LOSS BTU/H: 55028





SITE NAME: LAMPONE INVESTMENTS
BUILDER: GREENPARK HOMES

TYPE: KIMBERLY 2

DATE: Jul-20

GFA: 2866 LO# 86802

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 53,358 TOTAL HEAT GAIN 34,834
AIR FLOW RATE CFM 21.2 AIR FLOW RATE CFM 32.47

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	13	6	4
R/A	0	0	5	2	1

plenium pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.02 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15

MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

DESIGN CFM = 1131
CFM @ .6" E.S.P.

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-3	BED-2	BED-3	BED-4	ENS-2	BED-4	BED-3	MBR	S-BATH	S-BATH	FAM	KT/BF	KT/BF	LV/DN	LAUN	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.47	1.16	1.53	2.54	1.53	2.03	0.66	2.03	1.53	1.47	0.49	0.49	3.00	2.72	2.72	4.42	0.81	2.56	2.91	4.32	4.32	4.32	4.32
CFM PER RUN HEAT	31	24	32	54	32	43	14	43	32	31	10	10	64	58	58	94	17	54	62	92	92	92	92
RM GAIN MBH.	1.68	0.72	1.68	2.80	1.68	2.77	0.38	2.77	1.68	1.68	0.63	0.63	2.68	2.59	2.59	3.14	1.51	0.40	0.45	0.59	0.59	0.59	0.59
CFM PER RUN COOLING	55	23	55	91	55	90	12	90	55	55	21	21	87	84	84	102	49	13	15	19	19	19	19
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.17	0.16	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	34	17	60	59	47	48	28	48	48	40	37	54	41	26	16	28	34	41	38	34	18	18	28
EQUIVALENT LENGTH	190	190	140	140	130	170	180	140	120	150	170	160	130	120	140	110	120	150	140	140	130	90	130
TOTAL EFFECTIVE LENGTH	224	207	200	199	177	218	208	188	168	190	207	214	171	146	156	138	154	191	178	174	148	108	158
ADJUSTED PRESSURE	0.08	0.08	0.09	0.08	0.1	0.07	0.08	0.09	0.1	0.09	0.08	0.08	0.09	0.11	0.1	0.12	0.11	0.09	0.1	0.09	0.11	0.15	0.1
ROUND DUCT SIZE	5	4	5	6	5	6	4	6	5	5	4	4	6	6	6	6	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	228	275	235	275	235	219	161	219	235	228	115	115	326	296	296	479	195	396	455	469	469	469	469
COOLING VELOCITY (ft/min)	404	264	404	464	404	459	138	459	404	404	241	241	444	428	428	520	562	95	110	97	97	97	97
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	3X10	4X10	3X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	B	B	B	C	B	A	A	A	B	D	B	C	C	D	D	A	D	A	C	C	D	B	A

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
TRUNK	STATIC	ROUND	RECT	VELOCITY						TRUNK	STATIC	ROUND	RECT	VELOCITY					
CFM	PRESS.	DUCT	DUCT	(ft/min)						CFM	PRESS.	DUCT	DUCT	(ft/min)					
TRUNK A	340	0.07	9.7	12	x	8	510			TRUNK G	0	0.00	0	0	x	8	0		
TRUNK B	593	0.07	11.9	16	x	8	667			TRUNK H	0	0.00	0	0	x	8	0		
TRUNK C	282	0.08	8.7	10	x	8	508			TRUNK I	0	0.00	0	0	x	8	0		
TRUNK D	538	0.08	11.1	14	x	8	692			TRUNK J	0	0.00	0	0	x	8	0		
TRUNK E	0	0.00	0	0	x	8	0			TRUNK K	0	0.00	0	0	x	8	0		
TRUNK F	0	0.00	0	0	x	8	0			TRUNK L	0	0.00	0	0	x	8	0		

RETURN AIR #	1	2	3	4	5	6	7	BR											
AIR VOLUME	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	176	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
ACTUAL DUCT LGH.	37	40	78	54	49	27	36	1	1	1	1	1	1	1	1	1	1	17	
EQUIVALENT LENGTH	155	195	235	175	235	200	200	0	0	0	0	0	0	0	0	0	0	225	
TOTAL EFFECTIVE LH	192	235	313	229	284	227	236	1	1	1	1	1	1	1	1	1	1	242	
ADJUSTED PRESSURE	0.08	0.06	0.05	0.06	0.05	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.06		
ROUND DUCT SIZE	6	6	6	6	6	10	7.5	0	0	0	0	0	0	0	0	0	7.9		
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8		
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	24		

TYPE: KIMBERLY 2
SITE NAME: LAMPONE INVESTMENTS

LO # 86802

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm	
Other Bedrooms	<u>3</u> @ 10.6 cfm <u>31.8</u> cfm	
Kitchen & Bathrooms	<u>4</u> @ 10.6 cfm <u>42.4</u> cfm	
Other Rooms	<u>6</u> @ 10.6 cfm <u>63.6</u> cfm	
Table 9.32.3.A.	TOTAL <u>180.2</u> cfm	

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL 79.5 cfm		

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>180.2</u> cfm	
Less Principal Ventil. Capacity	<u>79.5</u> cfm	
Required Supplemental Capacity	<u>100.7</u> cfm	

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
<u>79.5</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	X 78 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
ENS-2	FV-05-11VK1	50	☒	0.3
PWD	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
<u>155</u> cfm high	<u>64</u> cfm low	
<u>75</u> % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	July-20

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 86802	Model: KIMBERLY 2	Builder: GREENPARK HOMES	Date: 29/07/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1253</td> <td>9</td> <td>11277</td> </tr> <tr> <td>First</td> <td>1253</td> <td>11</td> <td>13783</td> </tr> <tr> <td>Second</td> <td>1613</td> <td>9</td> <td>14517</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>39,577.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1120.7 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1253	9	11277	First	1253	11	13783	Second	1613	9	14517	Third	0	9	0	Fourth	0	9	0	Total:			39,577.0 ft³	Total:			1120.7 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.361</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.113</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-21</td> <td style="text-align: center;">43</td> <td style="text-align: center;">78</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">24</td> <td style="text-align: center;">31</td> <td style="text-align: center;">7</td> <td style="text-align: center;">13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.361	SUMMER NATURAL AIR CHANGE RATE	0.113	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1253	9	11277																																																									
First	1253	11	13783																																																									
Second	1613	9	14517																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			39,577.0 ft³																																																									
Total:			1120.7 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.361																																																											
SUMMER NATURAL AIR CHANGE RATE	0.113																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.361 x 311.30 x 43 °C x 1.2 = 5834 W = 19906 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.113 x 311.30 x 7 °C x 1.2 = 299 W = 1022 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 78 °F x 1.08 x 0.25 = 1670 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	19,906	7,331	1.358																																																								
2	0.3		12,358	0.483																																																								
3	0.2		13,256	0.300																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** KIMBERLY 2**BUILDER:** GREENPARK HOMES**SFQT:** 2866**LO#** 86802**SITE:** LAMPONE INVESTMENTS**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	39577.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.5 ft
LENGTH: 48.0 ft	WIDTH: 37.0 ft	EXPOSED PERIMETER:	170.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Markham	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	14.6	 Insulation Configuration
Floor Width (m):	11.3	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	2.29	
Window Area (m ²):	1.7	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1391

TYPE: KIMBERLY 2

LO# 86802

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Markham			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.92			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1120.7			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1493.9 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.361			
Cooling Air Leakage Rate (ACH/H):	0.113			

TYPE: KIMBERLY 2

LO# 86802