

20.130122.000.00.CM

Issue Date: 02/19/21

LAMPONE INVESTMENT INC

ALL CONSTRUCTION SHALL COMPLY WITH THE
ONTARIO BUILDING CODE.

CITY OF MARKHAM

HEAT LOSS/HEAT GAIN CALCULATIONS

MODEL NAME : PEYTON 3

ELEV 1A, 1B, 2, 3A & 3B

SITE NAME: LAMPONE INVESTMENTS

BUILDER: GREENPARK HOMES

TYPE: PEYTON 3

GFA: 1949

DATE: Jul-20

LO# 86809

WINTER NATURAL AIR CHANGE RATE 0.359

SUMMER NATURAL AIR CHANGE RATE 0.109

HEAT LOSS ΔT °F. 78

HEAT GAIN ΔT °F. 13

CSA-F280-12

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	MBR	ENS	TYPE	PEYTON 3	GFA: 1949	BED-2	BED-3	BATH	WINTER NATURAL AIR CHANGE RATE 0.359	HEAT LOSS ΔT °F. 78	CSA-F280-12
GRS.WALL AREA	15	9	129	275	95	327	77	1371	1413	1413	1413	1413	1413	1413	1413	1413
GLAZING	15	9	129	275	95	327	77	1371	1413	1413	1413	1413	1413	1413	1413	1413
NORTH	21.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	21.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	21.8	24.9	0	0	0	24	523	598	0	0	0	0	11	240	274	0
WEST	21.8	41.6	22	479	914	11	240	457	0	0	0	0	0	0	0	0
SKYLT.	38.1	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	25.8	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.6	0.8	107	489	80	240	1097	181	62	281	46	293	1338	220	66	303
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	300	394	176	194	255	114	116	152	68	198	260	116	117	154
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	32	90	40	40	113	50	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	148	386	64	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1362			2115			1629			2451			697	
SUB TOTAL HT GAIN				1171			1349			1590		1800			393	
LEVEL FACTOR / MULTIPLIER	0.20	0.29				0.20	0.29		0.20	0.29		0.20	0.29		0.20	0.29
AIR CHANGE HEAT LOSS			401			623			480			722			205	
AIR CHANGE HEAT GAIN				74		85				100		114			25	
DUCT LOSS			0			0			211			0			0	
DUCT GAIN				0		0				238		0			0	
HEAT GAIN PEOPLE	240		2		480	0			1		240	1		240	0	
HEAT GAIN APPLIANCES/LIGHTS					448	0				448		448			0	
TOTAL HT LOSS BTU/H				1763		2737			2320		3173		902			
TOTAL HT GAIN x 1.3 BTU/H				2825		1865			3401		3382		543			

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	FAM	KIT	LV/DN	LAUN	W/R	FOY	MUD	WOD	BAS
GRS.WALL AREA	35	10	336	106	461	0	64	138	170	292	917	122	9	9
GLAZING	35	10	336	106	461	0	64	138	170	292	917	122	9	9
NORTH	21.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	21.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	21.8	24.9	0	0	0	0	0	0	0	0	0	0	0	0
WEST	21.8	41.6	66	1438	2742	13	283	540	0	0	0	0	0	0
SKYLT.	38.1	101.5	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	25.8	4.3	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.6	0.8	270	1233	203	93	423	70	421	1922	316	0	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2671			706			2794			287		
SUB TOTAL HT GAIN				2945		610			1545			76		
LEVEL FACTOR / MULTIPLIER	0.30	0.41				0.30	0.41		0.20	0.29		0.30	0.41	
AIR CHANGE HEAT LOSS			1103			292			1154			84		
AIR CHANGE HEAT GAIN				186		39			98			5		
DUCT LOSS			0			0			37			0		
DUCT GAIN				0		0			53			0		
HEAT GAIN PEOPLE	240		0		0	0		0	0		0	0		0
HEAT GAIN APPLIANCES/LIGHTS				448		448			448			448		
TOTAL HT LOSS BTU/H				3775		998			3948			408		
TOTAL HT GAIN x 1.3 BTU/H				4654		1426			2719			756		

TOTAL HEAT GAIN BTU/H:

25042

TONS: 2.09

LOSS DUE TO VENTILATION LOAD BTU/H: 1336

STRUCTURAL HEAT LOSS: 35779

TOTAL COMBINED HEAT LOSS BTU/H: 37115





SITE NAME: LAMPONE INVESTMENTS
BUILDER: GREENPARK HOMES

TYPE: PEYTON 3

DATE: Jul-20

GFA: 1949

LO# 86809

HEATING CFM 890 COOLING CFM 890
TOTAL HEAT LOSS 35,779 TOTAL HEAT GAIN 24,822
AIR FLOW RATE CFM 24.88 AIR FLOW RATE CFM 35.85

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

#GOODMAN
GMEC960402BNA 40
FAN SPEED
LOW

AFUE = 96 %
INPUT (BTU/H) = 40,000
OUTPUT (BTU/H) = 38,400

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	9	8	4
R/A	0	0	4	2	1

plenum pressure s/a 0.18
max s/a dif press. loss 0.02
min adjusted pressure s/a 0.16

r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15

MEDLOW
MEDIUM 695
MEDIUM HIGH
HIGH 890

DESIGN CFM = 890
CFM @ .6" E.S.P.

TEMPERATURE RISE 40 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	10	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-2	BED-2	BED-3	BED-3	BATH	MBR	FAM	FAM	KIT	LV/DN	LV/DN	LAUN	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	0.88	2.74	1.16	1.16	1.59	1.59	0.90	0.88	1.89	1.89	1.00	1.97	1.97	0.41	0.63	1.86	1.70	2.89	2.89	2.89	2.89
CFM PER RUN HEAT	22	68	29	29	39	39	22	22	47	47	25	49	49	10	16	46	42	72	72	72	72
RM GAIN MBH.	1.41	1.86	1.70	1.70	1.69	1.69	0.54	1.41	2.33	2.33	1.43	1.36	1.36	0.76	0.37	1.09	0.27	0.38	0.38	0.38	0.38
CFM PER RUN COOLING	51	67	61	61	61	61	19	51	83	83	51	49	49	27	13	39	10	14	14	14	14
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	53	63	48	43	52	45	33	48	35	48	39	31	23	39	25	22	28	40	44	25	25
EQUIVALENT LENGTH	150	200	160	170	200	170	180	130	170	160	160	110	140	150	160	100	140	100	160	110	130
TOTAL EFFECTIVE LENGTH	203	263	208	213	252	215	213	178	205	208	199	141	163	189	185	122	168	140	204	135	155
ADJUSTED PRESSURE	0.08	0.07	0.08	0.08	0.07	0.08	0.08	0.1	0.08	0.08	0.09	0.12	0.11	0.09	0.09	0.14	0.1	0.12	0.08	0.13	0.11
ROUND DUCT SIZE	5	6	5	5	5	5	4	5	6	6	5	4	4	4	4	4	4	5	5	5	5
HEATING VELOCITY (ft/min)	162	347	213	213	286	286	252	162	240	240	184	562	562	115	184	528	482	529	529	529	529
COOLING VELOCITY (ft/min)	374	342	448	448	448	448	218	374	423	423	374	562	562	310	149	447	115	103	103	103	103
OUTLET GRILL SIZE	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	A	A	B	B	C	C	B	A	A	A	A	C	C	B	B	C	B	B	A	B	C

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE								RETURN AIR TRUNK SIZE							
TRUNK	STATIC	ROUND	RECT	VELOCITY				TRUNK	STATIC	ROUND	RECT	VELOCITY			
CFM	PRESS.	DUCT	DUCT	(ft/min)				CFM	PRESS.	DUCT	DUCT	(ft/min)			
TRUNK A	303	0.07	9.3	10	x	8	545	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	595	0.07	11.9	16	x	8	669	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	294	0.07	9.2	10	x	8	529	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	889	0.07	13.9	22	x	8	727	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR #	1	2	3	4	5	6	BR									
AIR VOLUME	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	125
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	76	47	51	78	20	47	1	1	1	1	1	1	1	1	1	14
EQUIVALENT LENGTH	225	215	255	215	195	200	0	0	0	0	0	0	0	0	0	150
TOTAL EFFECTIVE LH	301	262	306	293	215	247	1	1	1	1	1	1	1	1	1	164
ADJUSTED PRESSURE	0.05	0.06	0.05	0.05	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.09
ROUND DUCT SIZE	6	6	6	6	9.2	7.5	0	0	0	0	0	0	0	0	0	6.2
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	14

TYPE: PEYTON 3
SITE NAME: LAMPONE INVESTMENTS

LO # 86809

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm	
Other Bedrooms	<u>2</u> @ 10.6 cfm <u>21.2</u> cfm	
Kitchen & Bathrooms	<u>4</u> @ 10.6 cfm <u>42.4</u> cfm	
Other Rooms	<u>3</u> @ 10.6 cfm <u>31.8</u> cfm	
Table 9.32.3.A.	TOTAL <u>137.8</u> cfm	

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL <u>63.6</u> cfm		

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>137.8</u> cfm	
Less Principal Ventil. Capacity	<u>63.6</u> cfm	
Required Supplemental Capacity	<u>74.2</u> cfm	

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
<u>63.6</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
63.6 CFM	X 78 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
BATH	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
<u>155</u> cfm high	<u>64</u> cfm low	
<u>75</u> % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	July-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 86809	Model: PEYTON 3	Builder: GREENPARK HOMES	Date: 29/07/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>875</td> <td>9</td> <td>7525</td> </tr> <tr> <td>First</td> <td>875</td> <td>10</td> <td>8400</td> </tr> <tr> <td>Second</td> <td>1074</td> <td>9</td> <td>9236.4</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>25,161.4 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>712.5 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	875	9	7525	First	875	10	8400	Second	1074	9	9236.4	Third	0	9	0	Fourth	0	9	0	Total:			25,161.4 ft³	Total:			712.5 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.359</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.109</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-21</td> <td style="text-align: center;">43</td> <td style="text-align: center;">78</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">24</td> <td style="text-align: center;">31</td> <td style="text-align: center;">7</td> <td style="text-align: center;">13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.359	SUMMER NATURAL AIR CHANGE RATE	0.109	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	875	9	7525																																																									
First	875	10	8400																																																									
Second	1074	9	9236.4																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			25,161.4 ft³																																																									
Total:			712.5 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.359																																																											
SUMMER NATURAL AIR CHANGE RATE	0.109																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.359 x 197.91 x 43 °C x 1.2 = 3685 W = 12572 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.109 x 197.91 x 7 °C x 1.2 = 184 W = 627 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 64 CFM x 78 °F x 1.08 x 0.25 = 1336 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 64 CFM x 13 °F x 1.08 x 0.25 = 220 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	12,572	5,288	1.189																																																								
2	0.3		9,130	0.413																																																								
3	0.2		8,540	0.294																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** PEYTON 3**BUILDER:** GREENPARK HOMES**SFQT:** 1949**LO#** 86809**SITE:** LAMPONE INVESTMENTS**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	ATTACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	25161.4	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	4
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.1 ft
LENGTH: 47.0 ft	WIDTH: 24.0 ft	EXPOSED PERIMETER:	122.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Markham	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	14.3	 Insulation Configuration
Floor Width (m):	7.3	
Exposed Perimeter (m):	37.2	
Wall Height (m):	2.6	
Depth Below Grade (m):	2.16	
Window Area (m ²):	1.1	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		965

TYPE: PEYTON 3

LO# 86809

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Markham			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.38			
Building Configuration				
Type:	Semi			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	712.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	949.8 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	30.0	30.0		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.359			
Cooling Air Leakage Rate (ACH/H):	0.109			

TYPE: PEYTON 3

LO# 86809