

SITE NAME: RUSSELL GARDENS PH 4										WUB				DATE: Jul-21		WINTER NATURAL AIR CHANGE RATE 0.310				HEAT LOSS AT °F. 71		CSA-F280-12					
BUILDER: GREENPARK HOMES										TYPE: MOUNTAINASH 3				GFA: 3872		LO# 81964		SUMMER NATURAL AIR CHANGE RATE 0.111				HEAT GAIN AT °F. 13		SB-12 PACKAGE A1			
ROOM USE		EXP. WALL		CLG. HT.		FACTORS		MBR		ENS		WIC-3		BED-2		BED-3		BED-4		ENS-2		S-ENS					
								42		29		7		27		32		18		8		8					
								9		9		9		9		9		9		9		9					
GRS.WALL AREA		LOSS		GAIN		378		281		63		243		288		182		72		64		LOSS GAIN					
GLAZING		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS		GAIN		LOSS GAIN					
NORTH		19.8	14.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	7	138	105	9	0	0		
EAST		19.8	38.4	0	0	0	0	0	0	0	18	356	591	44	870	1899	52	1028	1998	0	0	0	0	0	0		
SOUTH		19.8	23.1	0	0	0	7	138	162	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
WEST		19.8	38.4	32	633	1228	14	277	537	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SKYLT.		34.6	101.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
DOORS		23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
NET EXPOSED WALL		4.1	0.8	348	1434	280	240	985	180	45	187	34	189	825	150	235	978	177	146	605	110	65	280	49	47	195	35
NET EXPOSED BSMT WALL ABOVE GR		3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG		1.2	0.6	612	610	301	204	243	120	46	55	27	227	271	133	235	280	138	272	324	160	56	67	33	72	88	42
NO ATTIC EXPOSED CLG		2.6	1.3	0	0	0	0	0	0	0	0	0	25	64	31	45	116	57	0	0	0	0	0	0	0	0	
EXPOSED FLOOR		2.4	0.4	0	0	0	0	0	0	42	100	18	252	597	108	51	121	22	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS																											
SLAB ON GRADE HEAT LOSS																											
SUBTOTAL HT LOSS						2577		1653		687		2626		2522		1246		475		419							
SUB TOTAL HT GAIN				1789		1000		770		2112		2390		840		188		239									
LEVEL FACTOR / MULTIPLIER		0.20		0.26		0.20		0.26		0.20		0.26		0.20		0.26		0.20		0.26		0.20		0.26			
AIR CHANGE HEAT LOSS				705		435		183		691		664		328		125		110									
AIR CHANGE HEAT GAIN				129		72		55		152		172		46		13		17									
DUCT LOSS				0		0		88		332		319		0		0		0									
DUCT GAIN				0		0		83		307		337		0		0		0									
HEAT GAIN PEOPLE		240		2		480		0		0		1		240		1		240		1		0		0			
HEAT GAIN APPLIANCES/LIGHTS						565		0		0		565		565		565		565		0		0		0			
TOTAL HT LOSS BTU/H				3382		2088		965		3649		3504		1574		599		528									
TOTAL HT GAIN x 1.3 BTU/H				3852		1393		1180		4388		4815		1938		260		334									

ROOM USE	EXP. WALL	CLG. HT.	FACTORS		L/D		FM		K/B		L/H		LND		WVR		FOY		WUB	
			LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
GRS.WALL AREA	19.8	14.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GLAZING	19.8	38.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NORTH	19.8	38.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	19.8	38.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	19.8	38.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
WEST	19.8	38.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SKYL.	34.6	101.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	264	1094	198	296	1227	222	264	1094	198	257	1065	193	282	1189	212	23	95	17
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1806			1899			2839		1856		1796		1172		1812		240	
SUB TOTAL HT GAIN				1031		1528			2963		1729		417		349		501		1634	
LEVEL FACTOR / MULTIPLIER	0.30	0.37			0.30	0.37			0.30	0.37		0.30	0.37		0.30	0.37		0.30	0.37	
AIR CHANGE HEAT LOSS			676			711			1063		685		573		439		604		253	
AIR CHANGE HEAT GAIN				74		110			214		124		30		25		36		0.50	
DUCT LOSS			0			0			0		0		0		0		0		0	
DUCT GAIN			0			0			0		0		0		0		0		0	
HEAT GAIN PEOPLE	240		0		0	0		0	0		0		0		0		0		0	
HEAT GAIN APPLIANCES/LIGHTS					565	565			565		565		565				565		0	
TOTAL HT LOSS BTU/H			2492			2610			3902		2551		2489		1611		2216		1634	
TOTAL HT GAIN x 1.3 BTU/H			2171			2863			4892		3143		1315		487		698		328	

TOTAL HEAT GAIN BTU/H: 35847


TONS: 2.99

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 50998

TOTAL COMBINED HEAT LOSS BTU/H: 62513

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.



INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

SITE NAME: RUSSELL GARDENS PH 4
BUILDER: GREENPARK HOMESWUB
TYPE: MOUNTAINASH 3

DATE: Jul-21

GFA: 3072 LO# 91954

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 50,998 TOTAL HEAT GAIN 35,572
AIR FLOW RATE CFM 22.18 AIR FLOW RATE CFM 31.79furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35plenum pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.02 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15#GOODMAN
GMCC960303BNA 60FAN SPEED LOW
MEDLOW 928
MEDIUM 1017
MEDIUM HIGH 1131AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600DESIGN CFM = 1131
CFM @ .8" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	8	4
R/A	0	0	5	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	WIC-3	BED-2	BED-3	BED-4	ENS-2	BED-2	BED-3	MBR	S-ENS	L/D	FM	K/B	K/B	L/H	LND	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.89	2.09	0.97	1.82	1.75	1.57	0.60	1.82	1.75	1.69	0.53	2.48	2.61	1.95	1.95	2.55	2.47	1.61	2.22	4.22	4.22	4.22	4.22
CFM PER RUN HEAT	38	46	21	40	39	35	13	40	39	38	12	55	58	43	43	57	55	36	49	93	93	93	93
RM GAIN MBH	1.93	1.39	1.18	2.19	2.41	1.94	0.26	2.19	2.41	1.93	0.33	2.17	2.86	2.45	2.45	3.14	1.32	0.49	0.70	0.46	0.46	0.46	0.46
CFM PER RUN COOLING	61	44	38	70	77	62	8	70	77	61	11	69	91	78	78	100	42	15	22	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.16	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	57	28	43	51	48	26	55	56	47	46	30	17	47	23	33	37	47	16	35	62	19	4	22
EQUIVALENT LENGTH	140	140	110	120	150	170	130	130	160	160	190	120	120	140	100	180	110	150	100	150	110	130	130
TOTAL EFFECTIVE LENGTH	197	168	153	171	198	196	185	186	207	206	220	137	167	163	133	187	157	166	135	212	129	134	152
ADJUSTED PRESSURE	0.09	0.1	0.11	0.1	0.09	0.09	0.09	0.09	0.08	0.08	0.08	0.13	0.1	0.11	0.13	0.09	0.11	0.1	0.13	0.08	0.13	0.12	0.11
ROUND DUCT SIZE	5	4	4	5	6	6	4	5	6	5	4	5	6	6	6	6	5	4	4	6	6	6	6
HEATING VELOCITY (ft/min)	279	528	241	294	199	178	149	294	199	279	138	404	296	219	219	291	404	413	562	474	474	474	474
COOLING VELOCITY (ft/min)	448	505	436	514	393	316	92	514	393	448	126	507	464	398	398	510	308	172	252	76	76	76	76
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	D	D	C	B	A	D	C	A	C	D	A	B	B	C	A	C	C	A	B	D	C

RUN #
ROOM NAME
RM LOSS MBH
CFM PER RUN HEAT
RM GAIN MBH
CFM PER RUN COOLING
ADJUSTED PRESSURE
ACTUAL DUCT LGH
EQUIVALENT LENGTH
TOTAL EFFECTIVE LENGTH
ADJUSTED PRESSURE
ROUND DUCT SIZE
HEATING VELOCITY (ft/min)
COOLING VELOCITY (ft/min)
OUTLET GRILL SIZE
TRUNK

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department

AUG 25 2021

REC BY _____ DATE _____
REF'D TO _____ DATE _____CITY OF HAMILTON
Building Division

Permit No. 20-196110-02

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by

JDC

SEP 28 2021

SUPPLY AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	295	0.08	8.9	10	531	TRUNK G	0	0.00	0	0	0
TRUNK B	555	0.08	11.2	14	714	TRUNK H	0	0.00	0	0	0
TRUNK C	325	0.08	9.2	10	585	TRUNK I	0	0.00	0	0	0
TRUNK D	574	0.08	11.4	16	646	TRUNK J	0	0.00	0	0	0
TRUNK E	0	0.00	0	0	0	TRUNK K	0	0.00	0	0	0
TRUNK F	0	0.00	0	0	0	TRUNK L	0	0.00	0	0	0

FOR CHIEF BUILDING OFFICER

RETURN AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK O	0	0.05	0	0	0
TRUNK P	0	0.05	0	0	0
TRUNK Q	0	0.05	0	0	0
TRUNK R	0	0.05	0	0	0
TRUNK S	0	0.05	0	0	0
TRUNK T	0	0.05	0	0	0
TRUNK U	0	0.05	0	0	0
TRUNK V	0	0.05	0	0	0
TRUNK W	0	0.05	0	0	0
TRUNK X	801	0.05	14.5	24	601
TRUNK Y	650	0.05	13.4	20	585
TRUNK Z	270	0.05	9.7	12	405
DROP	1131	0.05	16.5	24	679

RETURN AIR

AIR VOLUME	135	135	85	95	75	380	75	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	58	58	52	58	51	31	33	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	215	245	195	165	255	195	240	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	271	303	247	221	306	226	273	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.05	0.05	0.06	0.07	0.05	0.07	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7.5	7.5	6	6	6	10.1	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Michael O'Rourke

TYPE: MOUNTAINASH 3
 SITE NAME: RUSSELL GARDENS PH 4

 LO # 91954
 WUB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM		
☒	Forced Air	
☐	Electric Space Heat	

REC BY _____ DATE _____
 REF'D TO _____ DATE _____

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	7 @ 10.6 cfm	74.2 cfm
Table 9.32.3.A.	TOTAL	201.4 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL	79.5 cfm	

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	201.4 cfm	
Less Principal Ventil. Capacity	79.5 cfm	
Required Supplemental Capacity	121.9 cfm	

PRINCIPAL EXHAUST FAN CAPACITY		
Model:	VANEE V150H	Location: BSMT
79.5 cfm	3.0 sones	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION		
CFM	ΔT °F	FACTOR
79.5 CFM	71 F	1.08
X	X	X
		% LOSS
		0.25

SUPPLEMENTAL FANS		PANASONIC			
Location	Model	cfm	HVI	Sones	
ENS	FV-05-11VK1	50	☒	0.3	
ENS-2	FV-05-11VK1	50	☒	0.3	
S-ENS	FV-05-11VK1	50	☒	0.3	
W/R	FV-05-11VK1	50	☒	0.3	

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	
150 cfm high	35 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	CITY OF HAMILTON Building Division
BUILDER:	GREENPARK HOMES
Name:	20-196110-02
Address:	THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
City:	THE OTHER APPLICABLE CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	ADL SEP 28 2021
Address:	FOR CHIEF BUILDING OFFICIAL DATE
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	Michael O'Rourke
HRAI #	001820
Date:	July-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 91954		Model: MOUNTAINASH 3		Date: 2021-07-28																																																								
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>1378</td><td>9</td><td>12402</td></tr> <tr><td>First</td><td>1378</td><td>10</td><td>13780</td></tr> <tr><td>Second</td><td>1694</td><td>9</td><td>15246</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>41,428.0 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>1173.1 m³</td></tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1378	9	12402	First	1378	10	13780	Second	1694	9	15246	Third	0	9	0	Fourth	0	9	0	Total:			41,428.0 ft³	Total:			1173.1 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.310</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.111</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.310	SUMMER NATURAL AIR CHANGE RATE	0.111	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1378	9	12402																																																									
First	1378	10	13780																																																									
Second	1694	9	15246																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			41,428.0 ft³																																																									
Total:			1173.1 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.310																																																											
SUMMER NATURAL AIR CHANGE RATE	0.111																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-17	39	71																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage $HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.310 x 325.86 x 39 °C x 1.2 = 4749 W = 16203 Btu/h			6.2.6 Sensible Gain due to Air Leakage $HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ 0.111 x 325.86 x 7 °C x 1.2 = 308 W = 1052 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation $HL_{vailb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			6.2.7 Sensible heat Gain due to Ventilation $HL_{vailb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{cleve})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HL_{cleve})</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5" style="text-align: center;">16,203</td><td>8,760</td><td>0.925</td></tr> <tr><td>2</td><td>0.3</td><td>12,981</td><td>0.374</td></tr> <tr><td>3</td><td>0.2</td><td>12,315</td><td>0.263</td></tr> <tr><td>4</td><td>0</td><td>0</td><td>0.000</td></tr> <tr><td>5</td><td>0</td><td>0</td><td>0.000</td></tr> </tbody> </table>					Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{cleve})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{cleve})	1	0.5	16,203	8,760	0.925	2	0.3	12,981	0.374	3	0.2	12,315	0.263	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{cleve})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{cleve})																																																								
1	0.5	16,203	8,760	0.925																																																								
2	0.3		12,981	0.374																																																								
3	0.2		12,315	0.263																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												



375 Finley Ave. Suite 202 Ajax, ON L1S 2E2

Tel: 905.619.2300 Fax: 905.619.2375

Web: www.hvacdesigns.ca E-mail: info@hvacdesigns.ca

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: MOUNTAINASH 3	WUB	BUILDER: GREENPARK HOMES
SFQT: 3072	LO# 91954	SITE: RUSSELL GARDENS PH 4

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA


ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	41428.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 53.0 ft	WIDTH: 36.0 ft	EXPOSED PERIMETER:	151.0 ft

2012 OBC - COMPLIANCE PACKAGE		
Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE


Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.2	 Insulation Configuration
Floor Width (m):	11.0	
Exposed Perimeter (m):	46.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	0.8	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1455

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.8	
Width (m):	4.6	
Exposed Perimeter (m):	8.2	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		70

TYPE: MOUNTAINASH 3
LO# 91954

WUB

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.71			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1173.1			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1563.8 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.310			
Cooling Air Leakage Rate (ACH/H):	0.111			

TYPE: MOUNTAINASH 3
LO# 91954

WUB

X-24X8
24X10

Y-20X8

Z-12X8

BR FLC
5X10
C/W DAMPER
BR LW FOR
OPT. WUB

B-14X8

A-10X8

D-16X8

C-10X8

CITY OF HAMILTON
Building Division

Permit No. 20-196117-02

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by

FOR CHIEF BUILDING OFFICIAL

DATE

UNEXCAVATED

CITY OF HAMILTON
BUILDING DIVISION
Planning & Development Department

AUG 25 2021

REG BY _____ DATE _____
REF'D TO _____ DATE _____

BASEMENT PLAN ELEV. 1

BASEMENT PLAN ELEV. 2

BASEMENT PLAN ELEV. 3

CSA-F280-12

WUB

PACKAGE A1

HVAC LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

3.

2.

1.

No.

REVISIONS

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client

GREENPARK HOMES

Project Name

RUSSELL GARDENS PH 4
HAMILTON, ONTARIO

WUB

MOUNTAINASH 3 3072 sqft

HVACDESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca

Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply
branch outlets shall be equipped with a manual balancing damper.
Ductwork which passes through the garage or unheated spaces shall be
adequately insulated and be gas-proofed.

HEAT LOSS 52513 BTU/H
UNIT DATA

MAKE GOODMAN

MODEL GMEC960603BNA

INPUT 60 MBTU/H

OUTPUT 57.6 MBTU/H

COOLING 3.0 TONS

FAN SPEED 1131 cfm @ 0.8" w.g.

OF RUNS S/A R/A FANS

3RD FLOOR

2ND FLOOR 11 5 3

1ST FLOOR 8 2 2

BASEMENT 4 1 0

ALL S/A DIFFUSERS 4 "x10"
UNLESS NOTED OTHERWISE
ON LAYOUT. ALL S/A RUNS 5"
UNLESS NOTED OTHERWISE
ON LAYOUT. UNDERCUT
DOORS 1" min. FOR R/A

Sheet Title


BASEMENT
HEATING
LAYOUT

Date JULY/2021

Scale 3/16" = 1'-0"

BCIN# 19669

LO# 91954



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 9.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

GROUND FLOOR PLAN
ELEV. 3

CITY OF HAMILTON
Building Division
Permit No. **20-196110-01**

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by
SD
SEP 28 2021
DATE

GROUND FLOOR PLAN
ELEV. 1

GROUND FLOOR PLAN
ELEV. 2

CSA-F280-12
WUB PACKAGE A1

HVAC LEGEND							
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdsgns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date JULY/2021	
WUB MOUNTAINASH 3 3072 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669 LO# 91954	

REVISIONS	
No.	Description
3.	
2.	
1.	

