

SITE NAME: RUSSEL GARDENS PH 4

BUILDER: GREENPARK HOMES

WUB

TYPE: SPRINGFIELD 2

GFA: 3550

DATE: Apr-21

LO# 00169

WINTER NATURAL AIR CHANGE RATE 0.310

SUMMER NATURAL AIR CHANGE RATE 0.111

HEAT LOSS AT °F. 71

HEAT GAIN AT °F. 13

CSA-F280-12

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	MBR	ENS	WUB	BED-2	BED-3	BED-4	ENS-2	HALL	FX/B-5	ENS-3	FJWC	
						34	29	7	26	40	12	12	8	16	6	16	
						9	9	9	9	9	9	9	9	9	9	11	
GRS.WALL AREA			LOSS	GAIN		306	261	63	225	360	108	108	72	144	54	165	
GLAZING			LOSS	GAIN													
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EAST	19.8	41.6	0	0	0	0	0	0	27	534	1122	48	949	1934	0	0	
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0	0	12	237	499	0	0	
WEST	19.8	41.6	37	731	1537	23	465	968	0	0	0	16	316	398	7	138	
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NET EXPOSED WALL	4.1	0.8	269	1115	202	238	987	179	63	261	47	92	381	69	96	398	
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.2	0.6	280	334	165	190	227	112	83	99	49	204	243	120	175	209	
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	65	156	82	0	0	
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	204	483	88	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SUBTOTAL HT LOSS			2180				1668		360			927		569			
SUB TOTAL HT GAIN				1904			1246		96			580		663			
LEVEL FACTOR / MULTIPLIER	0.20	0.27				0.20	0.27		0.20	0.27		0.20	0.27		0.20	0.27	
AIR CHANGE HEAT LOSS			587				449		57			258		305		121	
AIR CHANGE HEAT GAIN				181			99		8			46		50		21	
DUCT LOSS			0				0		264			122		115		0	
DUCT GAIN			0				0		0			72		46		0	
HEAT GAIN PEOPLE	240		2			480	0		0			0		0		0	
HEAT GAIN APPLIANCES/LIGHTS						654	0		1			240		1		240	
TOTAL HT LOSS BTU/H			2768				2117		457			1339		1438		568	
TOTAL HT GAIN x 1.3 BTU/H				4147			1749		135			1024		2055		373	

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	FAM	LVDN	KT/BF	L/H/G	LND	W/R	FOY	MUD	WUB	BAS
						16	43	41	23	9	6	19	28	18	174
						10	10	10	10	9	10	11	11	9	9
GRS.WALL AREA			LOSS	GAIN		160	430	410	230	81	60	209	308	162	1044
GLAZING			LOSS	GAIN											
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0	22	435	914	5
SOUTH	19.8	24.9	0	0	0	36	712	896	8	158	199	0	0	0	0
WEST	19.8	41.6	40	791	1662	0	0	0	28	584	1163	0	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	120	497	90	394	1633	296	352	1459	265	162	872	122	20
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	10	25	13	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1314				2345		1391		358	1693	1755		
SUB TOTAL HT GAIN				1785			1193		2541		330	214	195		
LEVEL FACTOR / MULTIPLIER	0.30	0.45				0.30	0.45		0.30	0.45		0.30	0.45		
AIR CHANGE HEAT LOSS			566				1046		1163		175	160			
AIR CHANGE HEAT GAIN				140			95		202		104	26			
DUCT LOSS			0				0		0		0	0			
DUCT GAIN			0				0		0		0	0			
HEAT GAIN PEOPLE	240		0			0	0		0		0	0			
HEAT GAIN APPLIANCES/LIGHTS						654	654		654		654	0			
TOTAL HT LOSS BTU/H			1900				3391		3769		824	2448	2586		
TOTAL HT GAIN x 1.3 BTU/H				3327			2524		4417		1314	1603	694		

TOTAL HEAT GAIN BTU/H:

40920

TONS: 3.41

LOSS DUE TO VENTILATION LOAD BTU/H: 2425

STRUCTURAL HEAT LOSS: 56319

TOTAL COMBINED HEAT LOSS BTU/H: 57744

Michael O'Rourke

SITE NAME: RUSSEL GARDENS PH 4
 BUILDER: GREENPARK HOMES

 WJUB
 TYPE: SPRINGFIELD 2

DATE: Apr-21

GFA: 3550 LO# 90159

 HEATING CFM 1504 COOLING CFM 1504
 TOTAL HEAT LOSS 55,319 TOTAL HEAT GAIN 40,480
 AIR FLOW RATE CFM 27.19 AIR FLOW RATE CFM 37.15

 furnace pressure 0.6
 furnace filter 0.05
 a/c coil pressure 0.2
 available pressure for s/a & r/a 0.35

 #GOODMAN
 GMEC960804CNA 80
 FAN SPEED
 LOW 868
 MEDLOW 978
 MEDIUM 1112
 MEDIUM HIGH 1504
 HIGH 1615

 AFUE = 98 %
 INPUT (BTU/H) = 80,000
 OUTPUT (BTU/H) = 76,800

 DESIGN CFM = 1504
 CFM @ .8" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	16	11	6
R/A	0	0	6	3	1

 All S/A diffusers 4"x10" unless noted otherwise on layout.
 All S/A runs 5"Ø unless noted otherwise on layout.

 plenum pressure s/a 0.18 r/a pressure 0.17
 max s/a dif press. loss 0.02 r/a grille press. Loss 0.02
 min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	ENS-2	HALL	FX/B-5	MBR	ENS-3	FAM	LV/DN	KT/BF	KT/BF	L/H/G	LND	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.38	1.06	0.46	1.45	1.66	1.18	0.87	1.27	1.44	1.38	0.57	0.95	3.39	1.88	1.88	1.01	0.82	0.52	2.45	2.59	3.15	3.15	3.15	3.15
CFM PER RUN HEAT	38	29	12	40	45	32	18	35	39	38	15	26	92	51	51	27	22	14	67	70	86	86	86	86
RM GAIN MBH.	2.07	0.87	0.13	1.78	2.27	1.98	0.51	0.65	2.05	2.07	0.37	1.66	2.52	2.21	2.21	1.50	1.31	0.30	1.60	0.69	0.22	0.22	0.22	0.22
CFM PER RUN COOLING	77	32	5	66	85	73	19	24	76	77	14	62	94	82	82	56	49	11	60	26	8	8	8	8
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	67	46	33	58	40	26	35	63	24	56	23	50	10	38	34	54	63	47	35	50	66	40	27	15
EQUIVALENT LENGTH	180	180	200	150	140	200	170	160	200	180	170	110	130	180	160	160	170	130	100	150	170	120	100	100
TOTAL EFFECTIVE LENGTH	227	226	233	208	180	226	205	223	224	236	193	160	140	218	194	214	233	177	135	200	236	160	127	115
ADJUSTED PRESSURE	0.08	0.08	0.07	0.08	0.09	0.08	0.08	0.08	0.08	0.07	0.09	0.11	0.12	0.07	0.08	0.08	0.07	0.1	0.13	0.09	0.07	0.1	0.13	0.14
ROUND DUCT SIZE	6	4	4	5	6	6	4	4	6	6	4	5	6	6	6	5	5	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	194	333	138	294	229	163	207	402	199	194	172	191	469	260	260	198	162	161	492	514	438	438	438	438
COOLING VELOCITY (ft/min)	393	367	57	485	433	372	218	275	388	393	161	455	479	418	418	411	360	126	441	191	41	41	41	41
OUTLET GRILL SIZE	4X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	C	C	D	C	D	A	C	B	C	B	D	B	B	A	A	A	D	A	A	B	C	C

RUN #	25	26	27	28	29	30	31	32	33
ROOM NAME	BAS	BED-2	BED-3	ENS	ENS-2	FAM	F-WIC	L/H/G	BAS
RM LOSS MBH.	3.15	1.45	1.66	1.06	0.67	0.95	1.62	1.01	3.15
CFM PER RUN HEAT	86	40	45	29	18	26	44	27	86
RM GAIN MBH.	0.22	1.78	2.27	0.87	0.51	1.66	1.78	1.50	0.22
CFM PER RUN COOLING	8	66	85	32	19	62	66	56	8
ADJUSTED PRESSURE	0.16	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.16
ACTUAL DUCT LGH.	24	42	26	40	43	40	24	60	38
EQUIVALENT LENGTH	120	190	160	180	180	130	100	80	110
TOTAL EFFECTIVE LENGTH	144	232	186	230	223	170	124	120	148
ADJUSTED PRESSURE	0.11	0.07	0.09	0.07	0.08	0.1	0.14	0.14	0.11
ROUND DUCT SIZE	6	5	6	4	4	5	5	5	6
HEATING VELOCITY (ft/min)	438	294	229	333	207	191	323	198	438
COOLING VELOCITY (ft/min)	41	485	433	367	218	455	485	411	41
OUTLET GRILL SIZE	4X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10
TRUNK	D	D	D	C	D	B	D	A	B

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)							
TRUNK A	319	0.07	9.5	10	x	574	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0					
TRUNK B	712	0.07	12.8	20	x	641	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0					
TRUNK C	1051	0.07	14.8	26	x	728	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0					
TRUNK D	455	0.07	10.8	14	x	585	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0					
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0				

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	115	75	130	130	85	115	330	135	135	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	66	44	49	49	55	51	18	51	57	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	215	245	205	175	175	225	185	235	240	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	281	289	254	224	230	276	203	286	297	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.05	0.05	0.06	0.07	0.06	0.05	0.07	0.05	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	6	7	6.8	6	7	9.6	7.5	7.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	14	30	14	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: SPRINGFIELD 2
SITE NAME: RUSSEL GARDENS PH 4

LO # 90159
WUB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting Induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	5 @ 10.6 cfm	53 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	8 @ 10.6 cfm	84.8 cfm
Table 9.32.3.A.	TOTAL	233.2 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
6 Bedrooms		
As Per Ashrea 62.2 Dwelling- Unit Ventilation		
4.1.1 Total Ventilation Rate		
$Q_{tot} = 0.03A_{floor} + 7.5(N_{br} + 1)$		
TOTAL		159 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	233.2	cfm
Less Principal Ventil. Capacity	159	cfm
Required Supplemental Capacity	74.2	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE G2400H ECM
Location:	BSMT
159.0 cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
159.0 CFM	71 F	1.08	X	0.20

SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR				
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
W/R	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE G2400H ECM	
210	cfm high	
80	cfm low	
80	% Sensible Efficiency	
@ 32 deg F (0 deg C)		
☒ HVI Approved		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 90159

Model: SPRINGFIELD 2

Builder: GREENPARK HOMES

Date: 06/04/2021

Volume Calculation
Air Change & Delta T Data
House Volume

Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)
Bsmt	1603	9	14427
First	1603	10	16030
Second	1947	9	17523
Third	0	9	0
Fourth	0	9	0
Total:			47,980.0 ft ³
Total:			1358.6 m ³

WINTER NATURAL AIR CHANGE RATE	0.310
SUMMER NATURAL AIR CHANGE RATE	0.111

Design Temperature Difference

	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage
6.2.6 Sensible Gain due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.310 \times 377.40 \times 39^\circ\text{C} \times 1.2 = 5500 \text{ W}$$

$$= 18766 \text{ Btu/h}$$

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$0.111 \times 377.40 \times 7^\circ\text{C} \times 1.2 = 357 \text{ W}$$

$$= 1218 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation
6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$159 \text{ CFM} \times 71^\circ\text{F} \times 1.08 \times 0.20 = 2425 \text{ Btu/h}$$

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$159 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.20 = 440 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$$

Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	18,766	9,504	0.987
2	0.3		12,616	0.446
3	0.2		13,932	0.269
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: SPRINGFIELD 2	WUB	BUILDER: GREENPARK HOMES
SFQT: 3550	LO# 90159	SITE: RUSSEL GARDENS PH 4

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	47980.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	7
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 57.0 ft	WIDTH: 39.0 ft	EXPOSED PERIMETER:	174.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	17.4	 Insulation Configuration
Floor Width (m):	11.9	
Exposed Perimeter (m):	53.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.4	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1696

TYPE: SPRINGFIELD 2
LO# 90159

WUB

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	0.9	
Width (m):	4.6	
Exposed Perimeter (m):	5.5	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		43

TYPE: SPRINGFIELD 2
LO# 90159

WUB


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Hamilton		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	6.71		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	1358.6		
Air Leakage/Ventilation			
Air Tightness Type:	Present (1961-) (3.57 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	1811.1 cm ²	
	3.57	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	75.0	75.0	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.310		
Cooling Air Leakage Rate (ACH/H):	0.111		

TYPE: SPRINGFIELD 2
LO# 90159

WUB




I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.3 OF THE BUILDING CODE.


Michael O'Rourke
Michael O'Rourke, BCIN 19669
HVAC DESIGNS LTD.

HVAC LEGEND							
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE	3.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE	2.	
	SUPPLY AIR BOOT ABOVE		8" SUPPLY AIR STACK 2nd FLOOR		FRA - FLOOR RETURN AIR GRILLE	1.	
					REDUCER	No.	Description
						Date	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 57744 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS				Sheet Title	
GREENPARK HOMES			MAKE GOODMAN	3RD FLOOR					BASEMENT HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			MODEL GMEC960804CNA	2ND FLOOR		16	6	4		
			INPUT 80 MBTU/H	1ST FLOOR		11	3	2		
			OUTPUT 76.8 MBTU/H	BASEMENT		6	1	0	Date APR/2021	
		COOLING 3.5 TONS			ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A				Scale 3/16" = 1'-0"	
WUB SPRINGFIELD 2 3550 sqft		FAN SPEED 1504 cfm @ 0.8" w.c.					BCIN# 19669			
							LO#		90159	





PART. SECOND FLOOR PLAN
W/ OPT. BEDROOM 5

WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C. 12.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 8" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title	
GREENPARK HOMES			SECOND FLOOR HEATING LAYOUT	
Project Name			Date	APR/2021
RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Scale	3/16" = 1'-0"
WUB		BCIN# 19669		
SPRINGFIELD 2 3550 sqft		LO#	90159	