

SITE NAME: RUSSEL GARDENS PH 4				WUB				DATE: Apr-21				WINTER NATURAL AIR CHANGE RATE 0.310				HEAT LOSS AT °F. 71				CSA-F280-12																
BUILDER: GREENPARK HOMES				TYPE: SPRINGFIELD 4				GFA: 4078				LO# 90169				SUMMER NATURAL AIR CHANGE RATE 0.111				HEAT GAIN AT °F. 13				SB-12 PACKAGE A1												
ROOM USE				MBR		ENS		WIC		BED-2		BED-3		BED-4		ENS-2		ENS-3		FLB-5		ENS-4		HALL												
EXP. WALL				34		31		8		37		13		14		6		6		11		6		39												
CLG. HT.				9		9		9		9		9		9		9		9		9		9		9												
FACTORS																																				
GRS.WALL AREA		LOSS GAIN		306		279		72		333		117		126		84		54		99		54		351												
GLAZING		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN												
NORTH		19.8	16.0	0	0	0	0	0	0	0	14	277	224	0	0	0	7	138	112	0	0	0	16	316	256	0	0	0	0							
EAST		19.8	41.6	0	0	0	0	0	0	0	62	1226	2576	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							
SOUTH		19.8	24.9	0	0	0	0	0	0	0	0	0	0	11	217	274	11	217	274	0	0	0	7	138	174	0	0	0	0							
WEST		19.8	41.6	32	633	1330	16	316	965	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							
SKYLT.		34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							
DOORS		23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							
NET EXPOSED WALL		4.1	0.8	274	1136	206	263	1090	188	72	298	54	257	1055	183	106	438	80	116	477	86	47	195	35	47	195	35	83	344	62	47	195	35	231	1206	219
NET EXPOSED BSMT WALL ABOVE GR		3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
EXPOSED CLG		1.2	0.6	343	409	202	228	272	134	112	134	66	202	241	119	247	294	145	252	300	148	72	86	42	90	107	53	264	315	155	90	107	53	165	197	97
NO ATTIC EXPOSED CLG		2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
EXPOSED FLOOR		2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
BASEMENT/CRAWL HEAT LOSS				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
SLAB ON GRADE HEAT LOSS				0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
SUBTOTAL HT LOSS				2177		1678		432		3425		951		995		523		441		975		441		263		473		263		2809		2809		2809		
SUB TOTAL HT GAIN				1737		996		120		3246		499		508		208		208		263		473		263		473		263		2809		2809		2809		
LEVEL FACTOR / MULTIPLIER		0.20	0.29		0.20	0.29		0.20	0.29	0.20	0.29		0.20	0.29	0.20	0.29		0.20	0.29	0.20	0.29		0.20	0.29	0.20	0.29		0.20	0.29	0.20	0.29		0.20	0.29		
AIR CHANGE HEAT LOSS				628		484		125		987		274		287		151		151		127		281		127		281		127		747		747		747		
AIR CHANGE HEAT GAIN				161		92		11		300		46		47		19		19		24		44		24		44		24		260		260		260		
DUCT LOSS				0		0		0		441		0		0		67		67		0		0		44		44		24		0		0		0		
DUCT GAIN				0		0		0		454		0		0		23		23		0		0		44		44		24		0		0		0		
HEAT GAIN PEOPLE		240	2	480	0	0	0	0	0	1	240	1	240	1	240	0	0	0	0	0	1	240	0	0	0	1	240	0	0	0	0	0	0	0		
HEAT GAIN APPLIANCES/LIGHTS				754		0		0		754		754		754		754		754		754		754		754		754		754		754		754		754		
TOTAL HT LOSS BTU/H				2805		2162		557		4854		1226		1281		742		568		1256		568		1256		568		3336		3336		3336		3336		
TOTAL HT GAIN x 1.3 BTU/H				4072		1415		170		6492		2001		2015		325		325		373		373		1964		1964		373		3989		3989		3989		

ROOM USE	EXP. WALL		CLG. HT.		FACTORS		FAM		LV/DN		KT/BK		L/HO/G		LND		W/R		FOY		MUD		REC'D BY		DATE		WUB		BAS		
GRS.WALL AREA	LOSS	GAIN	400	280	450	100	0	60	530	275	243	1062																			
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN																			
NORTH	19.8	16.0	0	0	0	0	23	455	367	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	99	80		
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	7	138	291	0	0	0	0	0	0	8	168	332	
SOUTH	19.8	24.9	0	0	0	36	712	896	0	0	0	12	237	299	0	0	0	7	138	174	0	0	0	0	0	0	10	198	249		
WEST	19.8	41.6	47	929	1953	0	0	0	52	1028	2161	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
DOORS	23.5	4.3	0	0	0	0	0	0	20	469	85	0	0	0	0	0	0	0	40	938	170	20	469	85	20	469	85	20	469	85	
NET EXPOSED WALL	4.1	0.8	353	1463	265	244	1012	183	355	1472	267	88	365	66	0	0	0	53	220	40	483	2002	353	255	1057	192	223	924	168	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	531	1775	322	
NO ATTIC EXPOSED CLG	2.6	1.3	10	26	13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SUBTOTAL HT LOSS			2418		1723	3423	602	380	358	3079	1526	240	1634														253				
SUB TOTAL HT GAIN			2231		1080	2880	365	113	214	824	277	1634																			
LEVEL FACTOR / MULTIPLIER	0.30	0.49		0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49	0.30	0.49				0.50	1.05			
AIR CHANGE HEAT LOSS			1185		852	1692	288	110	177	1522	754																				
AIR CHANGE HEAT GAIN			206		100	266	34	10	20	76	26																				
DUCT LOSS			0		0	0	0	49	0	0	0																				
DUCT GAIN			0		0	0	0	88	0	0	0																				
HEAT GAIN PEOPLE	240	0	0	0	0	0	1	240	0	0	0								0	0	0	0	0				0	0	0	0	
HEAT GAIN APPLIANCES/LIGHTS			754		754	754	754	754	754	0	0								0	0	0	0	0				0	0	0	0	
TOTAL HT LOSS BTU/H			3613		2576	5115	900	538	635	4601	2281	1634																			
TOTAL HT GAIN x 1.3 BTU/H			4149		2514	6070	1811	1256	304	1170	393																				

TOTAL HEAT GAIN BTU/H:

42214

TONS: 3.52

LOSS DUE TO VENTILATION LOAD BTU/H: 2866

STRUCTURAL HEAT LOSS: 60585

TOTAL COMBINED HEAT LOSS BTU/H: 63251

SITE NAME: RUSSEL GARDENS PH 4
BUILDER: GREENPARK HOMES

WUB
TYPE: SPRINGFIELD 4

DATE: Apr-21

GFA: 4076 LO# 90169

HEATING CFM 1504 COOLING CFM 1504
TOTAL HEAT LOSS 60,585 TOTAL HEAT GAIN 41,731
AIR FLOW RATE CFM 24.82 AIR FLOW RATE CFM 36.04

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#*GOODMAN

AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = 76,800

FAN SPEED
LOW 868
MEDLOW 978
MEDIUM 1112
MEDIUM HIGH 1504
HIGH 1615

DESIGN CFM = 1504
CFM @ .8" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	18	9	6
R/A	0	0	6	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	ENS-2	ENS-3	FL/B-5	MBR	ENS-4	FAM	LV/DN	KT/BK	KT/BK	L/HO/G	LND	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.40	1.08	0.56	1.82	1.23	1.28	0.37	0.57	1.26	1.40	0.57	1.81	2.57	2.56	2.56	0.90	0.54	0.54	4.60	2.28	3.51	3.51	3.51	3.51
CFM PER RUN HEAT	35	27	14	40	30	32	9	14	31	35	14	45	64	63	63	22	13	13	114	57	87	87	87	87
RM GAIN MBH	2.04	0.71	0.17	2.16	2.00	2.01	0.16	0.37	1.96	2.04	0.37	2.07	2.51	2.54	2.54	1.81	1.26	0.30	1.17	0.39	0.31	0.31	0.31	0.31
CFM PER RUN COOLING	73	26	6	78	72	73	6	13	71	73	13	75	91	91	91	65	45	11	42	14	11	11	11	11
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.17	0.17	0.15	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	49	49	42	39	47	50	37	39	28	37	44	28	21	36	41	31	24	34	36	20	35	55	16	23
EQUIVALENT LENGTH	120	130	100	140	190	120	190	160	150	160	150	140	130	110	90	140	190	150	110	130	100	110	110	100
TOTAL EFFECTIVE LENGTH	169	179	142	179	237	170	227	199	178	197	194	168	151	146	131	171	214	184	146	150	135	165	126	123
ADJUSTED PRESSURE	0.1	0.1	0.12	0.1	0.07	0.1	0.08	0.09	0.1	0.09	0.09	0.1	0.11	0.11	0.12	0.1	0.08	0.09	0.1	0.11	0.12	0.1	0.13	0.13
ROUND DUCT SIZE	5	5	4	5	6	5	4	4	5	5	4	5	6	6	6	5	5	4	6	5	6	6	6	6
HEATING VELOCITY (ft/min)	257	198	161	294	153	235	103	161	228	257	161	330	326	321	321	162	95	149	581	419	444	444	444	444
COOLING VELOCITY (ft/min)	536	191	69	573	367	536	69	149	521	536	149	551	464	464	464	477	330	126	214	103	56	56	56	56
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	3X10	4X10	4X10	4X10	4X10
TRUNK	C	A	C	E	D	A	E	F	C	A	F	A	F	B	B	E	E	D	D	F	B	A	C	C

RUN #	25	26	27	28	29	30	31	32	33
ROOM NAME	BAS	BAS	HALL	HALL	ENS	BED-2	BED-2	FAM	ENS-2
RM LOSS MBH	3.51	3.51	1.67	1.67	1.08	1.62	1.62	1.81	0.37
CFM PER RUN HEAT	87	87	41	41	27	40	40	45	9
RM GAIN MBH	0.31	0.31	1.99	1.99	0.71	2.16	2.16	2.07	0.16
CFM PER RUN COOLING	11	11	72	72	26	78	78	75	6
ADJUSTED PRESSURE	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	31	38	50	45	43	46	52	42	37
EQUIVALENT LENGTH	110	120	180	190	110	150	170	110	210
TOTAL EFFECTIVE LENGTH	141	158	230	235	153	196	222	152	247
ADJUSTED PRESSURE	0.11	0.1	0.07	0.07	0.11	0.09	0.08	0.11	0.07
ROUND DUCT SIZE	6	6	6	6	4	5	5	5	4
HEATING VELOCITY (ft/min)	444	444	209	209	310	294	294	330	103
COOLING VELOCITY (ft/min)	56	56	367	367	298	573	573	551	69
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10
TRUNK	E	D	D	D	A	E	A	A	E

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)			
TRUNK A	298	0.09	8.7	10	X	8	536	TRUNK G	0	0.00	0	0	X	8	0	TRUNK O	0	0.05	0	0	X	8	0
TRUNK B	213	0.11	7.3	8	X	8	479	TRUNK H	0	0.00	0	0	X	8	0	TRUNK P	0	0.05	0	0	X	8	0
TRUNK C	765	0.09	12.3	18	X	8	765	TRUNK I	0	0.00	0	0	X	8	0	TRUNK Q	0	0.05	0	0	X	8	0
TRUNK D	326	0.07	9.5	10	X	8	587	TRUNK J	0	0.00	0	0	X	8	0	TRUNK R	0	0.05	0	0	X	8	0
TRUNK E	586	0.07	11.9	16	X	8	659	TRUNK K	0	0.00	0	0	X	8	0	TRUNK S	0	0.05	0	0	X	8	0
TRUNK F	735	0.07	12.9	20	X	8	662	TRUNK L	0	0.00	0	0	X	8	0	TRUNK T	0	0.05	0	0	X	8	0
RETURN AIR #	1	2	3	4	5	6	7	8	9					BR		TRUNK U	0	0.05	0	0	X	8	0
	0	0	0	0	0	0	0	0	0	0	0	0	0	0		TRUNK V	0	0.05	0	0	X	8	0
AIR VOLUME	115	130	85	75	115	115	155	310	155	0	0	0	0	0	249	TRUNK W	230	0.05	9.1	10	X	8	414
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	TRUNK X	1504	0.05	18.4	32	X	10	677
ACTUAL DUCT LGH.	40	41	33	51	55	60	44	42	34	1	1	1	1	1	19	TRUNK Y	460	0.05	11.8	16	X	8	518
EQUIVALENT LENGTH	275	155	185	235	225	265	200	195	210	0	0	0	0	0	225	TRUNK Z	465	0.05	11.8	16	X	8	523
TOTAL EFFECTIVE LH	315	196	228	286	280	325	244	237	244	1	1	1	1	1	244	DROP	1504	0.05	18.4	24	X	14	645
ADJUSTED PRESSURE	0.05	0.08	0.06	0.05	0.05	0.05	0.06	0.06	0.06	14.80	14.80	14.80	14.80	14.80	0.06								
ROUND DUCT SIZE	7	6.5	6	6	7	7	7.5	9.7	7.5	0	0	0	0	0	9								
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	0	0	0	0	0	8								
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X								
INLET GRILL SIZE	14	14	14	14	14	14	14	30	14	0	0	0	0	0	30								

TYPE: SPRINGFIELD 4
 SITE NAME: RUSSEL GARDENS PH 4

 LO # 90169
 WUB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	5 @ 10.6 cfm	53 cfm
Kitchen & Bathrooms	6 @ 10.6 cfm	63.6 cfm
Other Rooms	6 @ 10.6 cfm	63.6 cfm
Table 9.32.3.A	TOTAL	222.6 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
6 Bedrooms		
As Per Ashrea 62.2 Dwelling- Unit Ventilation		
4.1.1 Total Ventilation Rate		
$Q_{tot} = 0.03A_{floor} + 7.5(N_{br} + 1)$		
TOTAL		174.8 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	222.6	cfm
Less Principal Ventil. Capacity	174.8	cfm
Required Supplemental Capacity	47.8	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANE G2400H ECM	Location: BSMT
174.8 cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
174.8 CFM	X 71 F	X 1.08	X	0.20

SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR				
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5
W/R	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANE G2400H ECM		
210 cfm high	50 cfm low	
80 % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																														
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																														
LO#: 90169	Model: SPRINGFIELD 4	Builder: GREENPARK HOMES	Date: 05/04/2021																																																											
Volume Calculation			Air Change & Delta T Data																																																											
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1863</td> <td>9</td> <td>16767</td> </tr> <tr> <td>First</td> <td>1863</td> <td>10</td> <td>18630</td> </tr> <tr> <td>Second</td> <td>2213</td> <td>9</td> <td>19917</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>55,314.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1566.3 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1863	9	16767	First	1863	10	18630	Second	2213	9	19917	Third	0	9	0	Fourth	0	9	0	Total:			55,314.0 ft³	Total:			1566.3 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">WINTER NATURAL AIR CHANGE RATE</th> <th>0.310</th> </tr> </thead> <tbody> <tr> <td colspan="2">SUMMER NATURAL AIR CHANGE RATE</td> <td>0.111</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE		0.310	SUMMER NATURAL AIR CHANGE RATE		0.111	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																											
Bsmt	1863	9	16767																																																											
First	1863	10	18630																																																											
Second	2213	9	19917																																																											
Third	0	9	0																																																											
Fourth	0	9	0																																																											
Total:			55,314.0 ft³																																																											
Total:			1566.3 m³																																																											
WINTER NATURAL AIR CHANGE RATE		0.310																																																												
SUMMER NATURAL AIR CHANGE RATE		0.111																																																												
Design Temperature Difference																																																														
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																										
Winter DTDh	22	-17	39	71																																																										
Summer DTDc	24	31	7	13																																																										
5.2.3.1 Heat Loss due to Air Leakage $HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.310 x 435.09 x 39 °C x 1.2 = 6341 W = 21635 Btu/h			6.2.6 Sensible Gain due to Air Leakage $HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ 0.111 x 435.09 x 7 °C x 1.2 = 412 W = 1404 Btu/h																																																											
5.2.3.2 Heat Loss due to Mechanical Ventilation $HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 175 CFM x 71 °F x 1.08 x 0.20 = 2666 Btu/h			6.2.7 Sensible heat Gain due to Ventilation $HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 175 CFM x 13 °F x 1.08 x 0.20 = 483 Btu/h																																																											
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																														
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HL_{clevel})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5">21,635</td> <td>10,256</td> <td>1.055</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>13,130</td> <td>0.494</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>15,007</td> <td>0.288</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})	1	0.5	21,635	10,256	1.055	2	0.3	13,130	0.494	3	0.2	15,007	0.288	4	0	0	0.000	5	0	0	0.000																																
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})																																																										
1	0.5	21,635	10,256	1.055																																																										
2	0.3		13,130	0.494																																																										
3	0.2		15,007	0.288																																																										
4	0		0	0.000																																																										
5	0		0	0.000																																																										



375 Finley Ave. Suite 202 Ajax, ON L1S 2E2

Tel: 905.619.2300 Fax: 905.619.2375

Web: www.hvacdesigns.ca E-mail: info@hvacdesigns.ca

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: SPRINGFIELD 4	WUB	BUILDER: GREENPARK HOMES
SFQT: 4076	LO# 90169	SITE: RUSSEL GARDENS PH 4

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	55314.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	7
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 63.0 ft	WIDTH: 39.0 ft	EXPOSED PERIMETER:	177.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component

Compliance Package

A1

Nominal	Min. Eff.
---------	-----------


Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	19.2	 Insulation Configuration
Floor Width (m):	11.9	
Exposed Perimeter (m):	53.9	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	2.1	
Door Area (m ²):	3.7	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1735

TYPE: SPRINGFIELD 4
LO# 90169

WUB

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.8	 Insulation Configuration
Width (m):	4.6	
Exposed Perimeter (m):	8.2	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):	70	

TYPE: SPRINGFIELD 4
LO# 90169

WUB

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Hamilton		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	6.71		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	1566.3		
Air Leakage/Ventilation			
Air Tightness Type:	Present (1961-) (3.57 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	2088.0 cm ²	
	3.57	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	82.5	82.5	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.310		
Cooling Air Leakage Rate (ACH/H):	0.111		


TYPE: SPRINGFIELD 4
LO# 90169

WUB

BASEMENT PLAN - ELEV. '2'

BASEMENT PLAN - ELEV. '3'

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BEng 1969
HVAC DESIGNS LTD.



BASEMENT PLAN WALK-UP CONDITION

WUB
CSA-F280-12
PACKAGE A1

HVAC LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

3.		
2.		
1.		
No.	Description	Date
REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES
Project Name
**RUSSELL GARDENS PH 4
HAMILTON, ONTARIO**
WUB
SPRINGFIELD 4 4076 sqft


HVACDESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

HEAT LOSS 63251 BTU/H		# OF RUNS		S/A	R/A	FANS
UNIT DATA		3RD FLOOR				
MAKE	GOODMAN	2ND FLOOR	18	6	6	
MODEL	GMEC960804CNA	1ST FLOOR	9	3	2	
INPUT	80 MBTU/H	BASEMENT	6	1	0	
OUTPUT	76.8 MBTU/H	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5' UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A				
COOLING	3.5 TONS					
FAN SPEED	1504 cfm @ 0.6" w.g.					

Sheet Title
**BASEMENT
HEATING
LAYOUT**
Date
APR/2021
Scale
3/16" = 1'-0"
BCIN# 19669
LO# 90169

GROUND FLOOR PLAN - ELEV. '2'

GROUND FLOOR PLAN - ELEV. '3'



GROUND FLOOR PLAN
WALK-UP CONDITION

WUB
CSA-F280-12
PACKAGE A1


I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								REVISIONS	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO WUB SPRINGFIELD 4 4076 sqft	HVAC DESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdsgns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT Date APR/2021 Scale 3/16" = 1'-0" BCIN# 19669 LO# 90169
--	---	---

PARTIAL OPT. SECOND FLOOR PLAN W/ BEDROOM 5



I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.
							No.	Description
							REVISIONS	
							Date	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client

GREENPARK HOMES

Project Name

**RUSSELL GARDENS PH 4
HAMILTON, ONTARIO**

**WUB
SPRINGFIELD 4 4076 sqft**

HVAC DESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca

Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title


**SECOND FLOOR
HEATING
LAYOUT**

Date **APR/2021**

Scale **3/16" = 1'-0"**

BCIN# 19669

LO# **90169**



PARTIAL OPT. GROUND FLOOR PLAN W/ GUEST SUITE

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

WUB
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.® AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title GUEST SUITE HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date APR/2021	
WUB SPRINGFIELD 4 4076 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO#	90169