

SITE NAME: RUSSELL GARDENS PH3
BUILDER: GREENPARK HOMES

TYPE: VALLEY CREEK 2 GFA: 2612

DATE: Mar-21
LO# 90134

WINTER/NATURAL AIR CHANGE RATE 0.338
SUMMER/NATURAL AIR CHANGE RATE 0.121

HEAT LOSS AT OF: 71
HEAT GAIN AT OF: 13

CSA-F280-12
SB-12/PACKAGE A1

ROOM/USE	EXP. WALL	CLG. INT.	MBR	ENS	WC	BED-2	BED-3	BED-4	BATH	ENS-2
			37	23	8	29	32	15	9	9
			9	9	9	9	9	9	9	9
GRS. WALL AREA	LOSS	GAIN	333	207	72	261	288	135	81	81
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	19.8	16.0	0	0	0	0	0	0	0	7
EAST	19.8	41.6	0	0	0	17	336	706	26	514
SOUTH	19.8	24.9	0	0	0	8	158	199	0	0
WEST	19.8	41.6	35	682	1454	15	297	623	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	298	1235	224	184	763	138	55	228
SLAB ON GRADE HEAT LOSS	3.3	0.6	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	358	427	210	129	154	76	29	35
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	29	69	12	274	849
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2354		1371	667	2464	2220	1082	639
SUBTOTAL HT GAIN			1889		1037	777	1536	2332	606	334
LEVEL FACTOR MULTIPLIER	0.20	0.25		0.20	0.25	0.20	0.25	0.20	0.25	0.20
AIR CHANGE HEAT LOSS			596		347	169	624	562	274	162
AIR CHANGE HEAT GAIN			144		79	69	117	178	46	25
DUCT LOSS			0		0	84	309	278	0	80
DUCT GAIN			0		0	84	242	328	0	36
HEAT GAIN PEOPLE	240	2	480	0	0	0	1	240	1	240
HEAT GAIN APPLIANCES/LIGHTS			529	0	0	0	529	529	529	529
TOTAL HT LOSS BTU/H			2950		1718	920	3396	3060	1356	881
TOTAL HT GAIN BTU/H			3954		1450	1196	3463	4688	1847	514

ROOM/USE	EXP. WALL	CLG. INT.	FAM	DIN	K/D	LAUND	W/R	FOY	WOD	BAS
			36	26	35	27	6	35	43	166
			10	10	10	10	10	11	8	8
GRS. WALL AREA	LOSS	GAIN	360	260	350	270	60	385	344	959
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	19.8	16.0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	7	138	112	0	0
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0
WEST	19.8	41.6	30	593	1247	0	0	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	330	1368	248	233	966	175	287	1190
SLAB ON GRADE HEAT LOSS	3.3	0.6	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1961		1590	2435	1615	358	2465	447
SUBTOTAL HT GAIN			1495		847	2833	380	214	994	7252
LEVEL FACTOR MULTIPLIER	0.30	0.42		0.30	0.42	0.30	0.42	0.30	0.42	0.50
AIR CHANGE HEAT LOSS			820		627	1018	675	150	1030	7198
AIR CHANGE HEAT GAIN			114		65	216	29	16	34	68
DUCT LOSS			0		0	0	0	0	0	0
DUCT GAIN			0		0	0	0	0	0	0
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			529	529	529	529	529	529	529	529
TOTAL HT LOSS BTU/H			2781		2126	3453	2290	508	3495	625
TOTAL HT GAIN BTU/H			2779		1873	4652	1219	300	625	1307

TOTAL HEAT GAIN BTU/H:

31098

TONS: 2.59

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 45104

TOTAL COMBINED HEAT LOSS BTU/H: 46619

SITE NAME: RUSSELL GARDENS PH 4
 BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 2

DATE: Mar-21

GFA: 2612 LO# 90134

HEATING CFM 928
 TOTAL HEAT LOSS 45,104
 AIR FLOW RATE CFM 20.57

COOLING CFM 928
 TOTAL HEAT GAIN 30,823
 AIR FLOW RATE CFM 30.11

furnace pressure 0.6
 furnace filter 0.05
 a/c coil pressure 0.2
 available pressure for s/a & r/a 0.35

plenum pressure s/a 0.18
 max s/a dif press. loss 0.02
 min adjusted pressure s/a 0.16

r/a pressure 0.17
 r/a grille press. Loss 0.02
 adjusted pressure r/a 0.15

#GOODMAN
 GMEC960603BNA 60
 FAN SPEED LOW
 MEDLOW
 MEDIUM 928
 MEDIUM HIGH 1017
 HIGH 1131

AFUE = 96 %
 INPUT (BTU/H) = 60,000
 OUTPUT (BTU/H) = 57,600

DESIGN CFM = 928
 CFM @ .5" E.S.P.

TEMPERATURE RISE 57 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	7	4
R/A	0	0	3	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
 All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	BED-2	BED-3	MBR	ENS-2	FAM	DIN	K/D	K/D	LAUND	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.47	1.72	0.92	1.70	1.53	1.36	0.88	1.70	1.53	1.47	0.73	2.78	2.13	1.73	1.73	2.29	0.51	3.50	3.86	3.86	3.86	3.86
CFM PER RUN HEAT	30	35	19	35	31	28	18	35	31	30	15	57	44	36	36	47	10	72	79	79	79	79
RM GAIN MBH	1.98	1.45	1.20	1.73	2.34	1.85	0.51	1.73	2.34	1.98	0.33	2.78	1.87	2.33	2.33	1.22	0.30	0.63	0.48	0.48	0.48	0.48
CFM PER RUN COOLING	60	44	36	52	71	56	15	52	71	60	10	84	56	70	70	37	9	19	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	47	29	45	55	54	19	36	49	61	38	48	31	34	39	28	29	32	36	30	32	29	39
EQUIVALENT LENGTH	140	150	130	150	150	120	160	140	150	140	180	120	100	140	120	120	160	100	110	140	150	130
TOTAL EFFECTIVE LENGTH	187	179	175	205	204	139	196	189	211	178	228	151	134	179	148	149	192	136	140	172	179	169
ADJUSTED PRESSURE	0.09	0.1	0.1	0.08	0.08	0.12	0.09	0.09	0.08	0.1	0.08	0.11	0.13	0.1	0.12	0.12	0.09	0.13	0.12	0.1	0.1	0.1
ROUND DUCT SIZE	5	4	4	5	6	6	5	5	6	5	4	6	5	5	5	4	4	5	5	5	5	5
HEATING VELOCITY (ft/min)	220	402	218	257	158	143	207	257	158	220	172	291	323	264	264	539	115	529	580	580	580	580
COOLING VELOCITY (ft/min)	441	505	413	382	382	286	172	382	362	441	115	428	411	514	514	424	103	140	110	110	110	110
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	D	C	B	B	A	C	B	B	A	D	B	C	B	D	D	C	C	A	C	D	A	A

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	BED-2	BED-3	MBR	ENS-2	FAM	DIN	K/D	K/D	LAUND	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.47	1.72	0.92	1.70	1.53	1.36	0.88	1.70	1.53	1.47	0.73	2.78	2.13	1.73	1.73	2.29	0.51	3.50	3.86	3.86	3.86	3.86
CFM PER RUN HEAT	30	35	19	35	31	28	18	35	31	30	15	57	44	36	36	47	10	72	79	79	79	79
RM GAIN MBH	1.98	1.45	1.20	1.73	2.34	1.85	0.51	1.73	2.34	1.98	0.33	2.78	1.87	2.33	2.33	1.22	0.30	0.63	0.48	0.48	0.48	0.48
CFM PER RUN COOLING	60	44	36	52	71	56	15	52	71	60	10	84	56	70	70	37	9	19	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	47	29	45	55	54	19	36	49	61	38	48	31	34	39	28	29	32	36	30	32	29	39
EQUIVALENT LENGTH	140	150	130	150	150	120	160	140	150	140	180	120	100	140	120	120	160	100	110	140	150	130
TOTAL EFFECTIVE LENGTH	187	179	175	205	204	139	196	189	211	178	228	151	134	179	148	149	192	136	140	172	179	169
ADJUSTED PRESSURE	0.09	0.1	0.1	0.08	0.08	0.12	0.09	0.09	0.08	0.1	0.08	0.11	0.13	0.1	0.12	0.12	0.09	0.13	0.12	0.1	0.1	0.1
ROUND DUCT SIZE	5	4	4	5	6	6	5	5	6	5	4	6	5	5	5	4	4	5	5	5	5	5
HEATING VELOCITY (ft/min)	220	402	218	257	158	143	207	257	158	220	172	291	323	264	264	539	115	529	580	580	580	580
COOLING VELOCITY (ft/min)	441	505	413	382	382	286	172	382	362	441	115	428	411	514	514	424	103	140	110	110	110	110
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	D	C	B	B	A	C	B	B	A	D	B	C	B	D	D	C	C	A	C	D	A	A

SUPPLY AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	302	0.08	9	10	544	TRUNK G	0	0.00	0	0	0
TRUNK B	468	0.08	10.6	14	602	TRUNK H	0	0.00	0	0	0
TRUNK C	246	0.10	7.8	8	554	TRUNK I	0	0.00	0	0	0
TRUNK D	211	0.09	7.6	8	475	TRUNK J	0	0.00	0	0	0
TRUNK E	457	0.09	10.2	12	686	TRUNK K	0	0.00	0	0	0
TRUNK F	0	0.00	0	0	0	TRUNK L	0	0.00	0	0	0

RETURN AIR

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	17	18	19	21	22	23	24
AIR VOLUME	155	125	155	155	200	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	56	53	54	44	13	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	185	175	180	190	135	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LENGTH	241	228	234	234	148	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.06	0.06	0.06	0.06	0.10	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7.5	6.9	7.5	7.5	7.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

RETURN AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK O	0	0.06	0	0	0	TRUNK Q	0	0.06	0	0	0
TRUNK P	0	0.06	0	0	0	TRUNK R	0	0.06	0	0	0
TRUNK Q	0	0.06	0	0	0	TRUNK S	0	0.06	0	0	0
TRUNK R	0	0.06	0	0	0	TRUNK T	0	0.06	0	0	0
TRUNK S	0	0.06	0	0	0	TRUNK U	0	0.06	0	0	0
TRUNK T	0	0.06	0	0	0	TRUNK V	0	0.06	0	0	0
TRUNK U	0	0.06	0	0	0	TRUNK W	0	0.06	0	0	0
TRUNK V	0	0.06	0	0	0	TRUNK X	618	0.06	12.6	18	618
TRUNK W	0	0.06	0	0	0	TRUNK Y	310	0.06	9.7	12	465
TRUNK X	618	0.06	12.6	18	618	TRUNK Z	0	0.06	0	0	0
TRUNK Y	310	0.06	9.7	12	465	DROP	928	0.06	14.7	24	557

TYPE: VALLEYCREEK 2
SITE NAME: RUSSELL GARDENS PH 4

LO # 90134

(RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY)

COMBUSTION APPLIANCES		9.32.3.1(1)
a) ☒	Direct vent (sealed combustion) only	
b) ☐	Positive venting induced draft (except fireplaces)	
c) ☐	Natural draft, B-vent or induced draft gas fireplace	
d) ☐	Solid Fuel (including fireplaces)	
e) ☐	No Combustion Appliances	

HEATING SYSTEM	
☒	Forced Air
☐	Non Forced Air
☐	Electric Space Heat

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>3</u> @ 10.6 cfm	<u>31.8</u> cfm
Kitchen & Bathrooms	<u>5</u> @ 10.6 cfm	<u>53</u> cfm
Other Rooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Table 9.32.3.A.	TOTAL	<u>169.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>79.5</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>169.6</u>	cfm
Less Principal Ventil. Capacity	<u>79.5</u>	cfm
Required Supplemental Capacity	<u>90.1</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
<u>79.5</u> cfm	<u>3.0</u> sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	ΔT °F	FACTOR	% LOSS
79.5 CFM	X 71°F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC	
Location	Model	cfm	HVI
ENS	FV-05-11VK1	50	☒
BATH	FV-05-11VK1	50	☒
ENS-2	FV-05-11VK1	50	☒
W/R	FV-05-11VK1	50	☒

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H		
<u>150</u> cfm high	<u>35</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township:	Plan:
Address:	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	March-21

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage and Ventilation Calculation)																																																												
LO#: 90134	Model: VALLEYCREEK	Builder: GREENPARK HOMES	Date: 31/03/2021																																																									
Volume Calculation			Air Change & Delta T Data																																																									
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>1158</td><td>8</td><td>9264</td></tr> <tr><td>First</td><td>1158</td><td>10</td><td>11580</td></tr> <tr><td>Second</td><td>1432</td><td>9</td><td>12888</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>33,732.0 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>955.2 m³</td></tr> </tbody> </table>			Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)	Bsmt	1158	8	9264	First	1158	10	11580	Second	1432	9	12888	Third	0	9	0	Fourth	0	9	0	Total:			33,732.0 ft ³	Total:			955.2 m ³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.338</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.121</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin (°C)</th> <th>Tout (°C)</th> <th>ΔT (°C)</th> <th>ΔT (°F)</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE	0.338	SUMMER NATURAL AIR CHANGE RATE	0.121	Design Temperature Difference						Tin (°C)	Tout (°C)	ΔT (°C)	ΔT (°F)	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)																																																									
Bsmt	1158	8	9264																																																									
First	1158	10	11580																																																									
Second	1432	9	12888																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			33,732.0 ft ³																																																									
Total:			955.2 m ³																																																									
WINTER NATURAL AIR CHANGE RATE	0.338																																																											
SUMMER NATURAL AIR CHANGE RATE	0.121																																																											
Design Temperature Difference																																																												
	Tin (°C)	Tout (°C)	ΔT (°C)	ΔT (°F)																																																								
Winter DTDh	22	-17	39	71																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss Due to Air Leakage			6.2.6 Sensible Gain Due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.338 x 265.33 x 39°C x 1.2 = 4219W = 14395 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.121 x 265.33 x 7°C x 1.2 = 274W = 935 Btu/h																																																									
5.2.3.2 Heat Loss Due to Mechanical Ventilation			6.2.7 Sensible Heat Gain Due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71°F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13°F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairbv Air Leakage & Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF ÷ (HL_{airbv} + HL_{level}))</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5">14,395</td><td>8,246</td><td>0.873</td></tr> <tr><td>2</td><td>0.3</td><td>10,334</td><td>0.418</td></tr> <tr><td>3</td><td>0.2</td><td>11,378</td><td>0.253</td></tr> <tr><td>4</td><td>0</td><td>0</td><td>0.000</td></tr> <tr><td>5</td><td>0</td><td>0</td><td>0.000</td></tr> </tbody> </table> *HL_{airbv} = Air Leakage Heat Loss & Ventilation Heat Loss *For balanced air supply only ventilation system HL_{airr} = 0					Level	Level Factor (LF)	HLairbv Air Leakage & Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss (HL _{level})	Air Leakage Heat Loss Multiplier (LF ÷ (HL _{airbv} + HL _{level}))	1	0.5	14,395	8,246	0.873	2	0.3	10,334	0.418	3	0.2	11,378	0.253	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairbv Air Leakage & Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss (HL _{level})	Air Leakage Heat Loss Multiplier (LF ÷ (HL _{airbv} + HL _{level}))																																																								
1	0.5	14,395	8,246	0.873																																																								
2	0.3		10,334	0.418																																																								
3	0.2		11,378	0.253																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: VALLEYCREEK2

BUILDER: GREENPARK HOMES

SFQT: 2612

LO# 90134

SITE: RUSSELL GARDENS PH2

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+ BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	33732.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.0 ft
LENGTH: 50.0 ft	WIDTH: 33.0 ft	EXPOSED PERIMETER:	166.0 ft

2012 CBC COMPLIANCE PACKAGE

Component

Compliance Package A1

Nominal Min. Eff.

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 i	21.12
Below Grade Slab Entire Surface 2500mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab 500mm below grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab 500mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EFF	0.8	-


INDIVIDUAL BCIN: 119669

MICHAEL D'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental Tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal Conductivity: Dry Sand, Foam, Clay	
Water Table:	Normal (7-10m, 23-33ft)	
Foundation Dimensions		
Floor Length (m):	15.2	 Insulation Configuration
Floor Width (m):	10.1	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.52	
Window Area (m ²):	1.1	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1603


TYPE: VALLEYCREEK
LO# 90134

Air Infiltration Residential Load Calculator


Supplemental Tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer Height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.62			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	955.2			
Air Leakage/Ventilation				
Airtightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1273.3 m ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.338			
Cooling Air Leakage Rate (ACH/H):	0.121			

TYPE: VALLEYCREEK
LO# 90134



PARTIAL BASEMENT PLAN FOR DECK CONDITION



BASEMENT PLAN 2

CITY OF HAMILTON
Building Division

Permit No. 20-187704-02

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by
[Signature] 16022021
FOR CHIEF BUILDING OFFICIAL DATE

BASEMENT PLAN 3


CSA-F280-12
PACKAGE A1

I MICHAEL O'BROUKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
[Signature]
Michael O'Brooke, TCC# 19669
HVAC DESIGNS LTD.


HVAC LEGEND								REVISIONS	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 46619 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS				Sheet Title BASEMENT HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			MAKE GOODMAN		3RD FLOOR				Date MAR/2021	
VALLEYCREEK 2 2612 sqft			MODEL GMEC960603BNA		2ND FLOOR				Scale 3/16" = 1'-0"	
			INPUT 60 MBTU/H		1ST FLOOR				BCIN# 19669	
			OUTPUT 57.6 MBTU/H		BASEMENT				LO# 90134	
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.		COOLING 2.5 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5" UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A						
		FAN SPEED 928 cfm @ 0.6" w.c.								



FIRST FLOOR PLAN 1



FIRST FLOOR PLAN 2



FIRST FLOOR PLAN 3

CITY OF HAMILTON
Building Division

201877042

Permit No.

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE

THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by

[Signature] *[Signature]*
FOR CHIEF BUILDING OFFICIAL DATE


CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
[Signature]
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


HVAC LEGEND							
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title	
GREENPARK HOMES			FIRST FLOOR HEATING LAYOUT	
Project Name			Date	MAR/2021
RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Scale	3/16" = 1'-0"
VALLEYCREEK 2 2612 sqft			BCIN# 19669	
		LO#	90134	



SECOND FLOOR PLAN 1



SECOND FLOOR PLAN 2



SECOND FLOOR PLAN 3

CITY OF HAMILTON
Building Division
Permit No. 20187704-02
THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW

These drawings and/or specifications have been reviewed by
[Signature] 16/05/2021
FOR CHIEF BUILDING OFFICIAL DATE

CSA-F280-12
PACKAGE A1

I, MICHAEL O'DOURKE HAVE REVIEWED
AND TAKE RESPONSIBILITY FOR THE
DESIGN WORK AND AM QUALIFIED
UNDER DIVISION C, 3.2.5 OF THE
BUILDING CODE.
[Signature]
Michael O'Dourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								REVISIONS		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNSLTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date MAR/2021	
VALLEYCREEK 2 2612 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO#	90134