

SITE NAME: RUSSELL GARDENS PH 4

BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 4A

GFA: 2819

DATE: Apr-21

LO# 90137

WINTER NATURAL AIR CHANGE RATE 0.338

SUMMER NATURAL AIR CHANGE RATE 0.121

HEAT LOSS AT °F. 71

HEAT GAIN AT °F. 13

CSA-F280-12

SB-12 PACKAGE A1

ROOM USE			MBR			ENS			BED-2			BED-3			BED-4			S-BATH						HEAT GAIN AT °F.			SB-12 PACKAGE A					
EXP. WALL			41			30			11			28			39			6						7								
CLG. HT.			9			9			9			9			9			9						9								
FACTORS																																
GRS.WALL AREA			LOSS			GAIN			369			270															ENS-4					
GLAZING									LOSS			GAIN			LOSS			GAIN									LOSS			GAIN		
NORTH			19.8			16.0			0			0			0			9			178			144								
EAST			19.8			41.6			0			0			0			0			0			0								
SOUTH			19.8			24.9			16			316			398			0			0			0								
WEST			19.8			41.6			36			712			1498			16			316			695								
SKYLT.			34.6			101.5			0			0			0			0			0			0								
DOORS			23.5			4.3			0			0			0			0			0			0								
NET EXPOSED WALL			4.1			0.8			317			1314			238			245			1016			184								
NET EXPOSED BSMT WALL ABOVE GR			3.3			0.6			0			0			0			0			0			0								
EXPOSED CLG			1.2			0.6			363			433			213			220			262			129								
NO ATTIC EXPOSED CLG			2.6			1.3			0			0			0			0			0			0								
EXPOSED FLOOR			2.4			0.4			0			0			0			0			0			0								
BASEMENT/CRAWL HEAT LOSS																																
SLAB ON GRADE HEAT LOSS																																
SUBTOTAL HT LOSS									2775						1772																	
SUB TOTAL HT GAIN												2346						1122														
LEVEL FACTOR / MULTIPLIER						0.20			0.26						0.20			0.26														
AIR CHANGE HEAT LOSS									713						455																	
AIR CHANGE HEAT GAIN												184						88														
DUCT LOSS									0						0																	
DUCT GAIN												0						0														
HEAT GAIN PEOPLE			240						2						480			0			0											
HEAT GAIN APPLIANCES/LIGHTS															788			0														
TOTAL HT LOSS BTU/H									3488						2227																	
TOTAL HT GAIN x 1.3 BTU/H									4938						1573																	

THESE DRAWINGS SHALL BE AVAILABLE ON SITE
 THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
 THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
 These drawings and/or specifications have been reviewed by
 DATE

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LOSS	GAIN	LV/DN	LIB	BF/KT	FAM	LAUN	WIR	FOY	MUD	WOD	BAS
GRS.WALL AREA			LOSS	GAIN		LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
GLAZING															
NORTH	19.8	16.0	0	0	0	18	356	288	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	19.8	24.9	29	573	722	0	0	0	0	0	0	12	237	499	0
WEST	19.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0
SKYL.T.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	361	1497	271	182	765	137	298	1235	224	347	1439	261	73
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS															
SLAB ON GRADE HEAT LOSS															
SUBTOTAL HT LOSS						2070		1110		2263		1912		588	
SUB TOTAL HT GAIN							993		424		1226		322		
LEVEL FACTOR / MULTIPLIER			0.30	0.46		0.30	0.46		0.30	0.46		0.30	0.46		
AIR CHANGE HEAT LOSS						961		510		1040		879		164	
AIR CHANGE HEAT GAIN							78		33		187		96		25
DUCT LOSS						0		0		0		0		18	
DUCT GAIN							0		0		0		0		66
HEAT GAIN PEOPLE	240					0		0		0		0		0	
HEAT GAIN APPLIANCES/LIGHTS							788		788		788		788		788
TOTAL HT LOSS BTU/H						3021		1621		3303		2791		751	
TOTAL HT GAIN x 1.3 BTU/H							2418		1620		4369		2744		1476

TOTAL HEAT GAIN BTU/H:

35216

TONS: 2.93

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 48389

TOTAL COMBINED HEAT LOSS BTU/H: 49504

SITE NAME: RUSSELL GARDENS PH 4
BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 4A

DATE: Apr-21

GFA: 2819 LO# 90137

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 48,389 TOTAL HEAT GAIN 34,941
AIR FLOW RATE CFM 23.37 AIR FLOW RATE CFM 32.37

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

DESIGN CFM = 1131
CFM @ .8" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	8	4
R/A	0	0	5	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

plenum pressure s/a 0.18
max s/a dif press. loss 0.02
min adjusted pressure s/a 0.16
r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-3	BED-2	BED-3	BED-4	S-BATH	S-BATH	BED-4	MBR	ENS-4	LV/DN	LIB	BF/KT	BF/KT	FAM	LAUN	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.74	2.23	1.75	1.14	1.75	1.57	0.47	0.47	1.57	1.74	1.08	3.02	1.62	1.65	1.65	2.79	0.75	0.42	3.08	1.11	4.20	4.20	4.20	4.20
CFM PER RUN HEAT	41	52	41	27	41	37	11	11	37	41	25	71	38	39	39	65	18	10	72	26	98	98	98	98
RM GAIN MBH.	2.47	1.57	2.50	1.95	2.50	2.17	0.20	0.20	2.17	2.47	1.20	2.42	1.62	2.18	2.18	2.74	1.48	0.31	1.17	0.19	0.31	0.31	0.31	0.31
CFM PER RUN COOLING	80	51	81	63	81	70	6	6	70	80	39	78	52	71	71	89	48	10	38	6	10	10	10	10
ADJUSTED PRESSURE	0.17	0.17	0.16	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	48	44	46	30	42	51	32	36	44	33	34	35	18	25	32	28	31	33	40	13	24	26	16	36
EQUIVALENT LENGTH	180	120	140	160	130	170	160	150	130	140	120	150	150	120	140	130	200	160	120	190	100	90	150	130
TOTAL EFFECTIVE LENGTH	228	164	186	190	172	221	192	186	174	173	154	185	168	145	172	158	231	193	160	203	124	116	166	166
ADJUSTED PRESSURE	0.08	0.1	0.09	0.09	0.09	0.08	0.09	0.09	0.1	0.1	0.11	0.09	0.1	0.12	0.1	0.1	0.07	0.09	0.11	0.08	0.13	0.14	0.1	0.1
ROUND DUCT SIZE	6	5	6	6	6	6	4	4	6	6	4	6	5	5	5	6	5	4	5	4	6	6	6	6
HEATING VELOCITY (ft/min)	209	382	209	138	209	189	126	126	189	209	287	362	279	286	286	331	132	115	529	298	500	500	500	500
COOLING VELOCITY (ft/min)	408	374	413	321	413	357	69	69	357	408	447	398	382	521	521	454	352	115	279	69	51	51	51	51
OUTLET GRILL SIZE	4X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	4X10	4X10	3X10	4X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	A	D	B	D	C	D	D	C	A	D	C	B	A	A	A	D	C	C	D	B	B	D	C

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.74	41	2.47	80	0.17	48	180	228	0.08	6	209	408	4X10	A
2	ENS	2.23	52	1.57	51	0.17	44	120	164	0.1	5	382	374	3X10	A
3	BED-3	1.75	41	2.50	81	0.16	46	140	186	0.09	6	209	413	4X10	D
4	BED-2	1.14	27	1.95	63	0.17	30	160	190	0.09	6	138	321	4X10	B
5	BED-3	1.75	41	2.50	81	0.16	46	130	172	0.09	6	209	413	4X10	D
6	BED-4	1.57	37	2.17	70	0.17	51	170	221	0.08	6	189	357	4X10	C
7	S-BATH	0.47	11	0.20	6	0.17	32	160	192	0.09	4	126	69	3X10	D
8	S-BATH	0.47	11	0.20	6	0.17	36	150	186	0.09	4	126	69	3X10	D
9	BED-4	1.57	37	2.17	70	0.17	44	130	174	0.1	6	189	357	4X10	C
10	MBR	1.74	41	2.47	80	0.17	44	140	173	0.1	6	209	408	4X10	A
11	ENS-4	1.08	25	1.20	39	0.17	34	120	154	0.11	4	287	447	3X10	D
12	LV/DN	3.02	71	2.42	78	0.17	35	150	185	0.09	6	362	398	4X10	C
13	LIB	1.62	38	1.62	52	0.17	18	150	168	0.1	5	279	382	3X10	B
14	BF/KT	1.65	39	2.18	71	0.17	25	120	145	0.12	5	286	521	3X10	A
15	BF/KT	1.65	39	2.18	71	0.17	32	140	172	0.1	5	286	521	3X10	A
16	FAM	2.79	65	2.74	89	0.16	28	130	158	0.1	6	331	454	4X10	A
17	LAUN	0.75	18	1.48	48	0.17	31	200	231	0.07	5	132	352	3X10	D
18	W/R	0.42	10	0.31	10	0.17	33	160	193	0.11	4	115	115	3X10	C
19	FOY	3.08	72	1.17	38	0.17	40	120	160	0.08	5	529	279	3X10	C
20	MUD	1.11	26	0.19	6	0.17	13	190	203	0.13	4	298	69	3X10	D
21	BAS	4.20	98	0.31	10	0.16	24	100	124	0.13	6	500	51	4X10	B
22	BAS	4.20	98	0.31	10	0.16	26	90	116	0.14	6	500	51	4X10	B
23	BAS	4.20	98	0.31	10	0.16	16	150	166	0.1	6	500	51	4X10	D
24	BAS	4.20	98	0.31	10	0.16	36	130	166	0.1	6	500	51	4X10	C

SUPPLY AIR TRUNK SIZE															RETURN AIR TRUNK SIZE														
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)						
TRUNK A	277	0.08	8.7	12	X	8	416		TRUNK G	0	0.00	0	0	X	8	0	TRUNK O	0	0.05	0	0	X	8	0					
TRUNK B	538	0.08	11.1	16	X	8	605		TRUNK H	0	0.00	0	0	X	8	0	TRUNK P	0	0.05	0	0	X	8	0					
TRUNK C	325	0.08	9.2	10	X	8	585		TRUNK I	0	0.00	0	0	X	8	0	TRUNK Q	0	0.05	0	0	X	8	0					
TRUNK D	596	0.07	11.9	16	X	8	671		TRUNK J	0	0.00	0	0	X	8	0	TRUNK R	0	0.05	0	0	X	8	0					
TRUNK E	0	0.00	0	0	X	8	0		TRUNK K	0	0.00	0	0	X	8	0	TRUNK S	0	0.05	0	0	X	8	0					
TRUNK F	0	0.00	0	0	X	8	0		TRUNK L	0	0.00	0	0	X	8	0	TRUNK T	0	0.05	0	0	X	8	0					
																	TRUNK U	0	0.05	0	0	X	8	0					
																	TRUNK V	0	0.05	0	0	X	8	0					
																	TRUNK W	0	0.05	0	0	X	8	0					
																	TRUNK X	886	0.05	15.1	26	X	8	613					
																	TRUNK Y	405	0.05	11.2	14	X	8	521					
																	TRUNK Z	0	0.05	0	0	X	8	0					
																	DROP	1131	0.05	16.5	24	X	10	679					

RETURN AIR #	1	2	3	4	5	6	7	8								BR
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
AIR VOLUME	130	155	75	250	105	90	75	95	0	0	0	0	0	0	0	156
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	39	38	51	30	18	22	45	38	1	1	1	1	1	1	1	17
EQUIVALENT LENGTH	215	145	235	150	175	175	230	175	0	0	0	0	0	0	0	220
TOTAL EFFECTIVE LH	254	183	286	180	193	197	275	213	1	1	1	1	1	1	1	237
ADJUSTED PRESSURE	0.06	0.08	0.05	0.08	0.08	0.08	0.05	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.06
ROUND DUCT SIZE	7	7	6	8.3	6	5.7	6	6	0	0	0	0	0	0	0	7.5
INLET GRILL SIZE	8	8	8	8	6	8	8	8	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	24	12	14	14	14	0	0	0	0	0	0	0	14

TYPE: VALLEYCREEK 4A
SITE NAME: RUSSELL GARDENS PH 4

LO # 90137

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	6 @ 10.6 cfm	63.6 cfm
Table 9.32.3.A.	TOTAL	190.8 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	190.8	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	111.3	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
79.5 cfm	3.0 sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	X 71 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
S-BATH	FV-05-11VK1	50	☒	0.3
ENS-4	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H		
150 cfm high	35 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 *Michael O'Rourke* MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																														
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																														
LO#: 90137	Model: VALLEYCREEK 4A	Builder: GREENPARK HOMES	Date: 05/04/2021																																																											
Volume Calculation			Air Change & Delta T Data																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <caption>House Volume</caption> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1236</td> <td>9</td> <td>11124</td> </tr> <tr> <td>First</td> <td>1236</td> <td>10</td> <td>12360</td> </tr> <tr> <td>Second</td> <td>1583</td> <td>9</td> <td>14247</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>37,731.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1068.4 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1236	9	11124	First	1236	10	12360	Second	1583	9	14247	Third	0	9	0	Fourth	0	9	0	Total:			37,731.0 ft³	Total:			1068.4 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Air Change & Delta T Data</th> </tr> </thead> <tbody> <tr> <td>WINTER NATURAL AIR CHANGE RATE</td> <td>0.338</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.121</td> </tr> </tbody> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-17</td> <td>39</td> <td>71</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </tbody> </table>		Air Change & Delta T Data		WINTER NATURAL AIR CHANGE RATE	0.338	SUMMER NATURAL AIR CHANGE RATE	0.121	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-17	39	71	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																											
Bsmt	1236	9	11124																																																											
First	1236	10	12360																																																											
Second	1583	9	14247																																																											
Third	0	9	0																																																											
Fourth	0	9	0																																																											
Total:			37,731.0 ft³																																																											
Total:			1068.4 m³																																																											
Air Change & Delta T Data																																																														
WINTER NATURAL AIR CHANGE RATE	0.338																																																													
SUMMER NATURAL AIR CHANGE RATE	0.121																																																													
Design Temperature Difference																																																														
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																										
Winter DTDh	22	-17	39	71																																																										
Summer DTDc	24	31	7	13																																																										
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																											
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.338 x 296.78 x 39 °C x 1.2 = 4719 W = 16102 Btu/h			$HG_{salb} = LR_{aire} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.121 x 296.78 x 7 °C x 1.2 = 306 W = 1046 Btu/h																																																											
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																											
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 71 °F x 1.08 x 0.25 = 1515 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																											
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																														
$HL_{abrr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">16,102</td> <td>8,738</td> <td>0.921</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>10,513</td> <td>0.459</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>12,535</td> <td>0.257</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	16,102	8,738	0.921	2	0.3	10,513	0.459	3	0.2	12,535	0.257	4	0	0	0.000	5	0	0	0.000																																
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																										
1	0.5	16,102	8,738	0.921																																																										
2	0.3		10,513	0.459																																																										
3	0.2		12,535	0.257																																																										
4	0		0	0.000																																																										
5	0		0	0.000																																																										

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** VALLEYCREEK 4A**BUILDER:** GREENPARK HOMES**SFQT:** 2819**LO#** 90137**SITE:** RUSSELL GARDENS PH 4**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	37731.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 54.0 ft	WIDTH: 34.0 ft	EXPOSED PERIMETER:	176.0 ft

2012 OBC - COMPLIANCE PACKAGE		Compliance Package A1	
Component		Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value		60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value		31	27.65
Exposed Floor Minimum RSI (R)-Value		31	29.80
Walls Above Grade Minimum RSI (R)-Value		22	17.03
Basement Walls Minimum RSI (R)-Value		20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value		-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value		10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value		10	11.13
Windows and Sliding Glass Doors Maximum U-Value		0.28	-
Skylights Maximum U-Value		0.49	-
Space Heating Equipment Minimum AFUE		0.96	-
HRV Minimum Efficiency		75%	-
Domestic Hot Water Heater Minimum EF		0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.5	 Insulation Configuration
Floor Width (m):	10.4	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.2	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1708	

TYPE: VALLEYCREEK 4A
LO# 90137


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.62			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1068.4			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1424.2 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.338			
Cooling Air Leakage Rate (ACH/H):	0.121			

TYPE: VALLEYCREEK 4A


LO# 90137



BASEMENT FLOOR PLAN '1'



BASEMENT FLOOR PLAN 3



BASEMENT FLOOR PLAN '2'

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

WOD
CSA-F280-12
PACKAGE A1

Client

GREENPARK HOMES

Project Name


**RUSSEL GARDENS PH 4
HAMILTON, ONTARIO**

VALLEYCREEK 4A 2819 sqft


375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.


HEAT LOSS 49904 BTU/H			# OF RUNS S/A R/A FANS			Sheet Title	
UNIT DATA			3RD FLOOR			BASEMENT HEATING LAYOUT	
MAKE GOODMAN			2ND FLOOR 12 5 3				
MODEL GMEC960603BNA			1ST FLOOR 8 3 2				
INPUT 60 MBTU/H			BASEMENT 4 1 0			Date APRIL/2021	
OUTPUT 57.6 MBTU/H			ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5'Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			Scale 3/16" = 1'-0"	
COOLING 3.0 TONS						BCIN# 19669	
FAN SPEED 1131 cfm @ 0.6" w.g.						LO# 90137	



FIRST FLOOR PLAN '1'



FIRST FLOOR PLAN 3



FIRST FLOOR PLAN '2'


WOD
CSA-F280-12
PACKAGE A1

I, MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


HVAC LEGEND						3.	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA - FLOOR RETURN AIR GRILLE		REDUCER
						REVISIONS	
						No.	Description
						Date	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSEL GARDENS PH 4 HAMILTON, ONTARIO			Date APRIL/2021	
VALLEYCREEK 4A 2819 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 90137	



SECOND FLOOR PLAN '1'



SECOND FLOOR PLAN '3'



SECOND FLOOR PLAN '2'

WOD
CSA-F280-12
PACKAGE A1

I MICHAEL O'BROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.3 OF THE BUILDING CODE.
Michael O'Brourke
Michael O'Brourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						REVISIONS		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	DATE
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacadesigns.ca Web: www.hvacadesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title	
GREENPARK HOMES			SECOND FLOOR HEATING LAYOUT	
Project Name			Date	APRIL/2021
RUSSEL GARDENS PH 4 HAMILTON, ONTARIO			Scale	3/16" = 1'-0"
VALLEYCREEK 4A 2819 sqft			BCIN# 19669	
		LO#	90137	