

SITE NAME: RUSSELL GARDENS PH 4

BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 10

GFA: 2608

DATE: Apr-21

LO# 90225

WINTER NATURAL AIR CHANGE RATE 0.338

HEAT LOSS AT °F. 71

CSA-F280-12

SUMMER NATURAL AIR CHANGE RATE 0.121

HEAT GAIN AT °F. 13

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	BED-2	BED-3	BED-4	BATH	ENS-4				
			35	29	12	13	29	21	7				
			9	9	9	9	10	9	10				
GRS.WALL AREA	LOSS	GAIN	315	261	108	117	276	189	67				
GLAZING	LOSS	GAIN											
NORTH	19.8	16.0	0	0	0	0	0	0	0				
EAST	19.8	41.6	0	0	0	39	771	1621	30	593	1247	12	237
SOUTH	19.8	24.9	30	593	747	0	0	0	30	593	747	0	0
WEST	19.8	41.6	24	474	997	16	316	665	0	0	0	26	514
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	261	1082	196	236	978	177	41	168	30	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	304	362	179	208	248	122	98	117	58	55	66
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0	36	92
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2612	1721									
SUB TOTAL HT GAIN			2119	1108									
LEVEL FACTOR / MULTIPLIER	0.20	0.23			0.20	0.23			0.20	0.23			
AIR CHANGE HEAT LOSS			573	392									
AIR CHANGE HEAT GAIN			126	66									
DUCT LOSS			0	0									
DUCT GAIN			0	0									
HEAT GAIN PEOPLE	240	2	480	0	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			677	0									
TOTAL HT LOSS BTU/H			3085	2113									
TOTAL HT GAIN x 1.3 BTU/H			4422	1527									

CITY OF HAMILTON
Building Division

Permit No. 2

150626

THESE STAMPED DRAWINGS SHALL BE AVAILABLE ON SITE
THE OWNER AND/OR CONTRACTOR SHALL COMPLY WITH
THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE LAW
These drawings and/or specifications have been reviewed by
FOR CHIEF BUILDING OFFICIAL
DATE OCT 04 2021

ROOM USE	EXP. WALL	CLG. HT.	LIV/DIN	KIT/FM	LAUN	WR	FOY	MUD	WOD	BAS
			56	67	12	13	15	14	43	164
			11	11	10	10	10	12	9	9
GRS.WALL AREA	LOSS	GAIN	616	737	114	130	160	168	387	1113
GLAZING	LOSS	GAIN								
NORTH	19.8	16.0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	46	909	1911	0	0	0	0	0
SOUTH	19.8	24.9	61	1206	1519	39	771	971	0	0
WEST	19.8	41.6	0	0	0	0	0	0	4	79
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	509	2110	383	601	2492	452	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	126	150	74	254	849
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	30	77	38	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			4225	5279	1309	726	1491	1083	928	7329
SUB TOTAL HT GAIN			3813	4603	1139	280	270	196	320	734
LEVEL FACTOR / MULTIPLIER	0.30	0.35			0.20	0.23	0.30	0.35		
AIR CHANGE HEAT LOSS			1465	1831	298	252	517	375		
AIR CHANGE HEAT GAIN			227	274	68	17	18	12		
DUCT LOSS			0	0	0	0	0	0		
DUCT GAIN			0	0	0	0	0	0		
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			677	677	677	677	677	677	0	0
TOTAL HT LOSS BTU/H			5691	7110	1607	978	2008	1458	928	14730
TOTAL HT GAIN x 1.3 BTU/H			6132	7221	2449	386	372	270	416	1036

TOTAL HEAT GAIN BTU/H:

37212

TONS: 3.10

LOSS DUE TO VENTILATION LOAD BTU/H: 1515

STRUCTURAL HEAT LOSS: 49372

TOTAL COMBINED HEAT LOSS BTU/H: 50887

SITE NAME: RUSSELL GARDENS PH 4
 BUILDER: GREENPARK HOMES

TYPE: VALLEYCREEK 10

DATE: Apr-21

GFA: 2608 LO# 90225

 HEATING CFM 1131 COOLING CFM 1131
 TOTAL HEAT LOSS 49,372 TOTAL HEAT GAIN 36,937
 AIR FLOW RATE CFM 22.91 AIR FLOW RATE CFM 30.62

 furnace pressure 0.6
 furnace filter 0.05
 a/c coil pressure 0.2
 available pressure for s/a & r/a 0.35

 #GOODMAN
 GMEC960603BNA 60
 FAN SPEED LOW
 MEDLOW
 MEDIUM 928
 MEDIUM HIGH 1017
 HIGH 1131

 AFUE = 96 %
 INPUT (BTU/H) = 60,000
 OUTPUT (BTU/H) = 57,600

 DESIGN CFM = 1131
 CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	8	4
R/A	0	0	5	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-3	BED-2	BED-3	BED-4	BATH	ENS-4	BED-4	MBR	LIV/DIN	LIV/DIN	KIT/FM	KIT/FM	KIT/FM	LAUN	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.54	2.11	1.24	1.52	1.24	1.43	1.78	1.03	1.43	1.54	2.85	2.85	2.37	2.37	2.37	1.61	0.98	2.01	1.46	3.91	3.91	3.91	3.91
CFM PER RUN HEAT	35	48	28	35	28	33	41	24	33	35	65	65	54	54	54	37	22	46	33	90	90	90	90
RM GAIN MBH	2.21	1.53	2.09	2.06	2.09	2.16	1.11	1.04	2.16	2.21	3.07	3.07	2.41	2.41	2.41	2.45	0.39	0.37	0.27	0.36	0.36	0.36	0.36
CFM PER RUN COOLING	68	47	64	63	64	66	34	32	66	68	94	94	74	74	74	75	12	11	8	11	11	11	11
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	50	44	69	69	67	73	72	65	71	56	52	33	19	13	20	30	25	17	13	11	10	44	44
EQUIVALENT LENGTH	190	140	170	140	160	170	180	180	160	190	110	170	130	180	130	150	80	120	140	100	120	150	120
TOTAL EFFECTIVE LENGTH	240	184	239	209	227	243	252	245	231	246	162	203	149	193	150	180	105	137	157	113	131	160	164
ADJUSTED PRESSURE	0.07	0.09	0.07	0.08	0.08	0.07	0.07	0.07	0.07	0.07	0.1	0.08	0.12	0.09	0.11	0.1	0.16	0.13	0.11	0.14	0.12	0.1	0.1
ROUND DUCT SIZE	8	5	6	6	6	6	5	4	6	6	6	6	5	5	5	5	4	5	4	6	6	6	6
HEATING VELOCITY (ft/min)	178	352	143	178	143	168	301	275	168	178	331	331	396	396	396	272	252	338	379	459	459	459	459
COOLING VELOCITY (ft/min)	347	345	326	321	326	337	250	367	337	347	479	479	543	543	543	551	138	81	92	56	56	56	56
OUTLET GRILL SIZE	4X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	B	C	A	B	A	A	A	A	A	B	A	A	B	B	C	B	C	B	C	C	C	B	A

RUN #	ROOM NAME	RM LOSS MBH	CFM PER RUN HEAT	RM GAIN MBH	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.54	35	2.21	68	0.17	50	190	240	0.07	8	178	347	4X10	B
2	ENS	2.11	48	1.53	47	0.17	44	140	184	0.09	5	352	345	3X10	C
3	BED-3	1.24	28	2.09	64	0.17	69	170	239	0.07	6	143	326	4X10	A
4	BED-2	1.52	35	2.06	63	0.17	69	140	209	0.08	6	178	321	4X10	B
5	BED-3	1.24	28	2.09	64	0.17	67	160	227	0.08	6	143	326	4X10	A
6	BED-4	1.43	33	2.16	66	0.17	73	170	243	0.07	6	168	337	4X10	A
7	BATH	1.78	41	1.11	34	0.17	72	180	252	0.07	5	301	250	3X10	A
8	ENS-4	1.03	24	1.04	32	0.17	65	180	245	0.07	4	275	367	3X10	A
9	BED-4	1.43	33	2.16	66	0.17	71	160	231	0.07	6	168	337	4X10	A
10	MBR	1.54	35	2.21	68	0.17	56	190	246	0.07	6	178	347	4X10	B
12	LIV/DIN	2.85	65	3.07	94	0.16	52	110	162	0.1	6	331	479	4X10	A
13	LIV/DIN	2.85	65	3.07	94	0.16	33	170	203	0.08	6	331	479	4X10	A
14	KIT/FM	2.37	54	2.41	74	0.17	19	130	149	0.12	5	396	543	3X10	B
15	KIT/FM	2.37	54	2.41	74	0.17	13	180	193	0.09	5	396	543	3X10	B
16	KIT/FM	2.37	54	2.41	74	0.17	20	130	150	0.11	5	396	543	3X10	C
17	LAUN	1.61	37	2.45	75	0.17	30	150	180	0.1	5	272	551	3X10	B
18	W/R	0.98	22	0.39	12	0.17	25	80	105	0.16	4	252	138	3X10	C
19	FOY	2.01	46	0.37	11	0.17	17	120	137	0.13	5	338	81	3X10	B
20	MUD	1.46	33	0.27	8	0.17	13	140	157	0.11	4	379	92	3X10	C
21	BAS	3.91	90	0.36	11	0.16	11	100	113	0.14	6	459	56	4X10	C
22	BAS	3.91	90	0.36	11	0.16	11	120	131	0.12	6	459	56	4X10	C
23	BAS	3.91	90	0.36	11	0.16	11	150	160	0.1	6	459	56	4X10	B
24	BAS	3.91	90	0.36	11	0.16	11	120	164	0.1	6	459	56	4X10	A

SUPPLY AIR TRUNK SIZE												RETURN AIR TRUNK SIZE												
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)	
	TRUNK A	407	0.07	10.4	14	x	8	523	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0
	TRUNK B	793	0.07	13.3	22	x	8	649	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0
	TRUNK C	337	0.09	9.1	10	x	8	607	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0
	TRUNK D	0	0.00	0	0	x	8	0	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0
	TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0
	TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	145	75	115	115	135	310	85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	42	72	65	71	44	17	51	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	185	205	245	250	235	135	205	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	227	277	310	321	279	152	256	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.07	0.05	0.05	0.05	0.05	0.10	0.08	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	6	7	7	7	7.5	8.6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8
INLET GRILL SIZE	14	14	14	14	14	14	30	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14	14

TYPE: VALLEYCREEK 10
SITE NAME: RUSSELL GARDENS PH 4

LO # 90225

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	4 @ 10.6 cfm	42.4 cfm
Table 9.32.3.A.	TOTAL	169.6 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	169.6	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	90.1	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
79.5 cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION					
CFM	ΔT °F	FACTOR			% LOSS
79.5 CFM	X 71 F	X 1.08	X		0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
BATH	BY INSTALLING CONTRACTOR	50	☒	3.5
W/R	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H		
150	cfm high	35 cfm low
75	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 90225

Model: VALLEYCREEK 10

Builder: GREENPARK HOMES

Date: 08/04/2021

Volume Calculation
House Volume

Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)
Bsmt	1121	9	10089
First	1121	10	11210
Second	1487	9	13383
Third	0	9	0
Fourth	0	9	0
Total:			34,682.0 ft ³
Total:			982.1 m ³

Air Change & Delta T Data

WINTER NATURAL AIR CHANGE RATE	0.338
SUMMER NATURAL AIR CHANGE RATE	0.121

Design Temperature Difference				
	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage

$$HL_{airb} = LR_{airb} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.338 \times 272.80 \times 39^\circ\text{C} \times 1.2 = 4338 \text{ W}$$

$$= 14801 \text{ Btu/h}$$

6.2.6 Sensible Gain due to Air Leakage

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$= 0.121 \times 272.80 \times 7^\circ\text{C} \times 1.2 = 282 \text{ W}$$

$$= 961 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 71^\circ\text{F} \times 1.08 \times 0.25 = 1515 \text{ Btu/h}$$

6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	14,801	8,258	0.896
2	0.3		12,804	0.347
3	0.2		12,983	0.228
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** VALLEYCREEK 10**BUILDER:** GREENPARK HOMES**SFQT:** 2608**LO#** 90225**SITE:** RUSSELL GARDENS PH 4**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA


ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	34682.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 49.0 ft	WIDTH: 33.0 ft	EXPOSED PERIMETER:	164.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1**

	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	14.9	 Insulation Configuration
Floor Width (m):	10.1	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.9	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1562	


TYPE: VALLEYCREEK 10
LO# 90225

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.62			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	982.1			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1309.1 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.338			
Cooling Air Leakage Rate (ACH/H):	0.121			

TYPE: VALLEYCREEK 10
LO# 90225



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THIS DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


WOD
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES	Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO	 375 Finley Ave, Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 50887 BTU/H UNIT DATA MAKE GOODMAN MODEL GMEC960603BNA INPUT 60 MBTU/H OUTPUT 57.6 MBTU/H COOLING 3.0 TONS FAN SPEED 1131 cfm @ 0.5" w.g.	# OF RUNS S/A R/A FANS 3RD FLOOR 2ND FLOOR 11 5 3 1ST FLOOR 8 2 2 BASEMENT 4 1 0	Sheet Title BASEMENT HEATING LAYOUT Date APR/2021 Scale 3/16" = 1'-0" BCIN# 19669 LO# 90225

VALLEYCREEK 10 2608 sqft



I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

WOD
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA - FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.® AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date APR/2021	
VALLEYCREEK 10 2608 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 90225	

