

SITE NAME: RUSSELL GARDENS PH 4
BUILDER: GREENPARK HOMES

WMB
TYPE: VALLEYCREEK 5A

GFA: 2922

DATE: Oct-21
LO# 93027

WINTER NATURAL AIR CHANGE RATE 0.365
SUMMER NATURAL AIR CHANGE RATE 0.130

HEAT LOSS AT °F. 71
HEAT GAIN AT °F. 13

CSA-F280-12
SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	WIC-4	ENS-4
FACTORS			35	28	17	12	29	36	6	7	6
GRS.WALL AREA	LOSS	GAIN	315	262	153	108	261	324	54	63	54
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	19.8	16.0	0	0	0	0	0	0	7	138	112
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0	0
WEST	19.8	41.6	35	692	1454	15	297	623	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	280	1161	210	222	920	167	134	556	101
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	309	368	182	197	235	116	229	273	135
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2221		1748		1204		936		2761
SUB TOTAL HT GAIN				1848		1146		708		435	2311
LEVEL FACTOR / MULTIPLIER	0.20	0.28							0.20	0.28	
AIR CHANGE HEAT LOSS	618			467		335		261		768	
AIR CHANGE HEAT GAIN			165		96		59		36		194
DUCT LOSS			0		0		0		0		353
DUCT GAIN			0		0		0		0		344
HEAT GAIN PEOPLE	240		2		480		0		1		240
HEAT GAIN APPLIANCES/LIGHTS			700		0		0		1		240
TOTAL HT LOSS BTU/H			2839		2235		1539		1197		3882
TOTAL HT GAIN x 1.3 BTU/H			4135		1614		998		1834		4925

ROOM USE	EXP. WALL	CLG. HT.	FAM	DIN	KT/BF	LJB	LAUN	W/R	FOY	WOB	BAS
FACTORS			34	12	36	19	26	3	30	20	160
GRS.WALL AREA	LOSS	GAIN	340	120	360	190	286	33	330	180	960
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0
SOUTH	19.8	24.9	0	0	0	0	0	0	0	0	0
WEST	19.8	41.6	30	593	1247	0	0	0	0	0	0
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.1	0.8	310	1285	233	103	427	77	295	1223	222
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1878		763		2508		975		1681
SUB TOTAL HT GAIN				1480		501		2923		433	392
LEVEL FACTOR / MULTIPLIER	0.30	0.52							0.30	0.52	
AIR CHANGE HEAT LOSS	984			400		1314		511		881	
AIR CHANGE HEAT GAIN			124		42		245		36		33
DUCT LOSS			0		0		0		0		16
DUCT GAIN			0		0		0		0		0
HEAT GAIN PEOPLE	240		0		0		0		0		0
HEAT GAIN APPLIANCES/LIGHTS			700		700		700		0		0
TOTAL HT LOSS BTU/H			2852		1163		3822		1486		2562
TOTAL HT GAIN x 1.3 BTU/H			2994		1615		5027		1519		1461

TOTAL HEAT GAIN BTU/H: 34846 TONS: 2.90 LOSS DUE TO VENTILATION LOAD BTU/H: 1515 STRUCTURAL HEAT LOSS: 48192 TOTAL COMBINED HEAT LOSS BTU/H: 49708

Michael O'Rourke

SITE NAME: RUSSELL GARDENS PH 4
BUILDER: GREENPARK HOMES

WUB
TYPE: VALLEYCREEK 5A

DATE: Oct-21

GFA: 2922 LO# 93027

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 48,192 TOTAL HEAT GAIN 34,572
AIR FLOW RATE CFM 23.47 AIR FLOW RATE CFM 32.71

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA
FAN SPEED 60
LOW
MEDLOW 928
MEDIUM 1017
MEDIUM HIGH 1131
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

DESIGN CFM = 1131
CFM @ .8" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	14	8	4
R/A	0	0	5	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-ENS	WIC-4	BED-3	MBR	ENS-4	FAM	DIN	KT/BF	KT/BF	LIB	LAUN	W/R	FOY	BED-4	BAS	BAS	BAS	BAS
RM LOSS MBH	1.42	1.12	1.54	1.20	1.94	1.51	0.48	0.85	1.94	1.42	0.51	2.86	1.16	1.91	1.91	1.49	2.56	0.38	3.43	1.51	3.86	3.86	3.86	3.86
CFM PER RUN HEAT	33	26	36	28	46	36	11	20	46	33	12	67	27	45	45	35	60	9	80	36	91	91	91	91
RM GAIN MBH	2.07	0.81	1.00	1.83	2.46	2.19	0.20	0.96	2.46	2.07	0.34	2.99	1.61	2.51	2.51	1.52	1.46	0.27	0.95	2.19	0.29	0.29	0.29	0.29
CFM PER RUN COOLING	68	26	33	60	81	72	7	31	81	68	11	98	53	82	82	50	48	9	31	72	9	9	9	9
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.16	0.17	0.17	0.16	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	50	36	31	27	44	58	36	39	50	36	44	27	19	26	32	37	20	37	44	47	44	43	13	34
EQUIVALENT LENGTH	190	150	170	130	130	160	150	120	140	120	200	130	130	120	140	150	130	150	120	130	90	130	160	140
TOTAL EFFECTIVE LENGTH	240	186	201	157	174	218	186	159	190	156	244	157	149	146	172	187	150	187	164	177	134	173	173	174
ADJUSTED PRESSURE	0.07	0.09	0.09	0.11	0.09	0.08	0.09	0.11	0.09	0.11	0.07	0.1	0.12	0.11	0.09	0.09	0.11	0.09	0.1	0.1	0.12	0.09	0.09	0.09
ROUND DUCT SIZE	6	4	4	6	6	6	4	4	6	6	4	6	5	6	6	5	5	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	168	298	413	143	235	184	126	229	235	168	138	342	198	229	229	257	441	103	587	264	464	464	464	464
COOLING VELOCITY (ft/min)	347	298	379	306	413	367	80	356	413	347	126	500	389	418	418	367	352	103	228	529	46	46	46	46
OUTLET GRILL SIZE	4X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	4X10	4X10	3X10	4X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	A	D	B	D	C	D	D	D	A	C	A	B	A	A	C	B	C	C	C	B	B	D	C

RUN #	25	26
ROOM NAME	ENS	S-ENS
RM LOSS MBH	1.12	0.48
CFM PER RUN HEAT	26	11
RM GAIN MBH	0.81	0.20
CFM PER RUN COOLING	26	7
ADJUSTED PRESSURE	0.17	0.17
ACTUAL DUCT LGH	58	32
EQUIVALENT LENGTH	190	180
TOTAL EFFECTIVE LENGTH	248	212
ADJUSTED PRESSURE	0.07	0.08
ROUND DUCT SIZE	4	4
HEATING VELOCITY (ft/min)	298	126
COOLING VELOCITY (ft/min)	298	80
OUTLET GRILL SIZE	3X10	3X10
TRUNK	A	D

SUPPLY AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	275	0.07	8.9	14	354
TRUNK B	572	0.07	11.8	18	572
TRUNK C	299	0.07	9.2	10	538
TRUNK D	560	0.07	11.7	16	630
TRUNK E	0	0.00	0	0	0
TRUNK F	0	0.00	0	0	0

RETURN AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK G	0	0.00	0	0	0
TRUNK H	0	0.00	0	0	0
TRUNK I	0	0.00	0	0	0
TRUNK J	0	0.00	0	0	0
TRUNK K	0	0.00	0	0	0
TRUNK L	0	0.00	0	0	0

RETURN AIR #

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	155	170	85	75	170	235	85	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	38	36	53	57	25	40	34	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	150	135	185	225	145	230	205	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LENGTH	188	171	238	282	170	270	239	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.08	0.09	0.06	0.05	0.09	0.05	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	7	6	6	7	9.2	6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TRUNK O	0	0.05	0	0	X	8	0
TRUNK P	0	0.05	0	0	X	8	0
TRUNK Q	0	0.05	0	0	X	8	0
TRUNK R	0	0.05	0	0	X	8	0
TRUNK S	0	0.05	0	0	X	8	0
TRUNK T	0	0.05	0	0	X	8	0
TRUNK U	0	0.05	0	0	X	8	0
TRUNK V	0	0.05	0	0	X	8	0
TRUNK W	0	0.05	0	0	X	8	0
TRUNK X	1131	0.05	16.5	32	X	8	636
TRUNK Y	325	0.05	10.4	12	X	8	488
TRUNK Z	395	0.05	11.1	14	X	8	508
DROP	1131	0.05	16.5	24	X	10	679

TYPE: VALLEYCREEK 5A
SITE NAME: RUSSELL GARDENS PH 4

LO # 93027
WUB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	5 @ 10.6 cfm	53.0 cfm
Table 9.32.3.A.	TOTAL	180.2 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	180.2	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	100.7	cfm

PRINCIPAL EXHAUST FAN CAPACITY			
Model:	VANEE V150H		
Location:	BSMT		
79.5 cfm	3.0 sones		
☒ HVI Approved			
PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	ΔT °F	FACTOR	% LOSS
79.5 CFM	X 71 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		PANASONIC	
Location	Model	cfm	HVI
ENS	FV-05-11VK1	50	☒
S-ENS	FV-05-11VK1	50	☒
ENS-4	FV-05-11VK1	50	☒
W/R	FV-05-11VK1	50	☒

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	
150 cfm high	35 cfm low	
75 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	October-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 93027

Model: VALLEYCREEK 5A

Builder: GREENPARK HOMES

Date: 2021-10-19

Volume Calculation
Air Change & Delta T Data
House Volume

Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)
Bsmt	1276	9	11484
First	1276	10	12760
Second	1646	9	14814
Third	0	9	0
Fourth	0	9	0
Total:			39,058.0 ft ³
Total:			1106.0 m ³

WINTER NATURAL AIR CHANGE RATE	0.365
SUMMER NATURAL AIR CHANGE RATE	0.130

Design Temperature Difference

	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage
6.2.6 Sensible Gain due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.365 \times 307.22 \times 39^\circ\text{C} \times 1.2 = 5273 \text{ W}$$

$$= 17993 \text{ Btu/h}$$

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$0.130 \times 307.22 \times 7^\circ\text{C} \times 1.2 = 342 \text{ W}$$

$$= 1167 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation
6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 71^\circ\text{F} \times 1.08 \times 0.25 = 1515 \text{ Btu/h}$$

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) + (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	17,993	6,451	1.395
2	0.3		10,301	0.524
3	0.2		12,929	0.278
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairv = 0

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: VALLEYCREEK 5A	WUB	BUILDER: GREENPARK HOMES
SFQT: 2922	LO# 93027	SITE: RUSSELL GARDENS PH 4

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	39058.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.50	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 57.0 ft WIDTH: 33.0 ft		EXPOSED PERIMETER:	160.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	20.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

Michael O'Rourke

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	4.6	 Insulation Configuration
Floor Width (m):	10.1	
Exposed Perimeter (m):	48.8	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.42	
Window Area (m ²):	1.0	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		836

TYPE: VALLEYCREEK 5A
LO# 93027

WUB

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	 Insulation Configuration
Width (m):	4.6	
Exposed Perimeter (m):	6.1	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		51

TYPE: VALLEYCREEK 5A
LO# 93027

WUB


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280



Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.53			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1106.0			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1474.3 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.365			
Cooling Air Leakage Rate (ACH/H):	0.130			

TYPE: VALLEYCREEK 5A
LO# 93027

WUB



BASEMENT PLAN 1 FOR
WALKOUT CONDITION



BASEMENT FLOOR PLAN 2 BASEMENT FLOOR PLAN 3




WUB
CSA-F280-12
PACKAGE A1

I MICHAEL O'Rourke HAVE REVIEW
AND TAKE RESPONSIBILITY FOR THE
DESIGN WORK AND AM QUALIFIED
UNDER DIVISION C. 3.2.5 OF THE
BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND							3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	Date	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO WUB VALLEYCREEK 5A 2922 sqft	HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacadesigns.ca Web: www.hvacadesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 49708 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title BASEMENT HEATING LAYOUT Date OCT/2021 Scale 3/16" = 1'-0" BCIN# 19669 LO# 93027
		MAKE GOODMAN		3RD FLOOR			
		MODEL GMEC960603BNA		2ND FLOOR	14	5	4
		INPUT 60 MBTU/H		1ST FLOOR	8	2	2
		OUTPUT 57.6 MBTU/H		BASEMENT	4	1	0
		COOLING 3.0 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			
		FAN SPEED 1131 cfm @ 0.6" w.c.					



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

WUB
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date OCT/2021	
WUB VALLEYCREEK 5A 2922 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 93027	