

SITE NAME: RUSSEL GARDENS PH 4 BUILDER: GREENPARK HOMES		OPT 5 BED TYPE: SPRINGFIELD 3S		GFA: 3631		DATE: Apr-21 LO# 90165		WINTER NATURAL AIR CHANGE RATE 0.338 SUMMER NATURAL AIR CHANGE RATE 0.121		HEAT LOSS AT "F. 71 HEAT GAIN AT "F. 13		CSA-F280-12 SB-12 PACKAGE A1	
ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	WIC-2	BED-2	BED-3	BED-4	ENS-3	BED-5	ENS-4		
GRS.WALL AREA	FACTORS		42	30	13	34	37	23	0	20	6		
GLAZING	LOSS GAIN		9	9	9	9	9	9	9	9	9		
NORTH	19.8	16.0	0	0	0	0	0	0	0	0	0		
EAST	19.8	41.6	0	0	0	0	0	0	0	0	0		
SOUTH	19.8	24.9	0	0	0	10	198	416	47	929	1953		
WEST	19.8	41.6	32	633	1330	31	613	1288	0	0	0		
SKYLT.	34.6	101.5	0	0	0	0	0	0	0	0	0		
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0		
NET EXPOSED WALL	4.1	0.8	346	1434	260	239	991	180	107	444	80		
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0		
EXPOSED CLG	1.2	0.6	328	391	193	221	263	130	42	50	25		
NO ATTIC EXPOSED CLG	2.6	1.3	0	0	0	0	0	0	0	0	0		
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0		
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0		
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0		
SUBTOTAL HT LOSS			2468		1867	691	3088	2860		1510	303		
SUB TOTAL HT GAIN				1782	1598	521	2466	3231		740	85		
LEVEL FACTOR / MULTIPLIER	0.20	0.27		0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27		
AIR CHANGE HEAT LOSS			660		501		186	829		768			
AIR CHANGE HEAT GAIN				144	129	42	199	405		81			
DUCT LOSS			0	0	0	0	392	260		60	7		
DUCT GAIN			0	0	0	0	0	0		38			
HEAT GAIN PEOPLE	240		2	480	0	0	0	0		0	9		
HEAT GAIN APPLIANCES/LIGHTS				506	0	0	1	240		240	0		
TOTAL HT LOSS BTU/H			3118		2368	877	4309	3628		1915	506		
TOTAL HT GAIN x 1.3 BTU/H			3785		2244	731	4878	5508		2009	134		
ROOM USE	EXP. WALL	CLG. HT.	FAM	LVDN	KT/BF	L/H/G	LND	G-EPD	FOY	MUD			
GRS.WALL AREA	FACTORS		39	36	42	26	0	6	18	27			
GLAZING	LOSS GAIN		10	10	10	11	9	10	11	11			
NORTH	19.8	16.0	0	0	0	0	0	0	0	0			
EAST	19.8	41.6	0	0	0	0	0	0	0	0			
SOUTH	19.8	24.9	0	0	0	36	712	896	0	0			
WEST	19.8	41.6	40	791	1662	0	0	0	7	138	291		
SKYLT.	34.6	101.5	0	0	0	55	1087	2285	0	0	0		
DOORS	23.5	4.3	0	0	0	0	0	0	0	0	0		
NET EXPOSED WALL	4.1	0.8	350	1451	263	314	1302	236	355	1472	267		
NET EXPOSED BSMT WALL ABOVE GR	3.3	0.6	0	0	0	0	0	0	0	0	0		
EXPOSED CLG	1.2	0.6	0	0	0	0	0	0	0	0	0		
NO ATTIC EXPOSED CLG	2.6	1.3	10	26	13	0	0	0	0	0	0		
EXPOSED FLOOR	2.4	0.4	0	0	0	0	0	0	0	0	0		
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0		
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0		
SUBTOTAL HT LOSS			2267		2013	2793	2015	124	358	1703	1742		
SUB TOTAL HT GAIN				1938	1132	2595	2492	61	214	574	415		
LEVEL FACTOR / MULTIPLIER	0.30	0.48		0.30	0.48	0.30	0.48	0.20	0.27	0.30	0.48		
AIR CHANGE HEAT LOSS			1084		963	1336	963	33	171	814	833		
AIR CHANGE HEAT GAIN				156	91	209	201	5	17	46	33		
DUCT LOSS			0	0	0	0	0	0	0	0	0		
DUCT GAIN			0	0	0	0	0	0	0	0	0		
HEAT GAIN PEOPLE	240		0	0	0	0	0	0	0	0	0		
HEAT GAIN APPLIANCES/LIGHTS				506	506	506	506	0	0	0	0		
TOTAL HT LOSS BTU/H			3351		2976	4129	2978	187	529	2517	506		
TOTAL HT GAIN x 1.3 BTU/H			3360		2248	4302	4469	743	301	1465	2576		
TOTAL HEAT GAIN BTU/H:		42902	TONS: 3.58		LOSS DUE TO VENTILATION LOAD BTU/H: 2461		STRUCTURAL HEAT LOSS: 69078		TOTAL COMBINED HEAT LOSS BTU/H: 61538				

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke

INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE

SITE NAME: RUSSEL GARDENS PH 4
BUILDER: GREENPARK HOMESOPT 5 BED
TYPE: SPRINGFIELD 3S

DATE: Apr-21

GFA: 3631 LO# 90165

HEATING CFM 1504
TOTAL HEAT LOSS 59,078
AIR FLOW RATE CFM 25.46
COOLING CFM 1504
TOTAL HEAT GAIN 42,456
AIR FLOW RATE CFM 35.43furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35#GOODMAN
GMEC960804CNA 80
FAN SPEED LOW 868
MEDLOW 978
MEDIUM 1112
MEDIUM HIGH 1504
HIGH 1615AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = 76,800DESIGN CFM = 1504
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	15	10	5
R/A	0	0	6	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	ENS	WIC-2	BED-3	BED-4	ENS-3	BED-2	BED-5	MBR	ENS-4	FAM	LV/DN	KT/BF	KT/BF	L/H/G	LND	G-E/PD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH	1.56	1.18	1.18	0.88	1.81	1.92	0.21	2.15	2.70	1.56	0.60	1.68	2.98	2.06	2.06	1.49	0.16	0.53	2.52	2.58	3.99	3.99	3.99	3.99
CFM PER RUN HEAT	40	30	30	22	46	49	5	55	69	40	15	43	76	53	53	38	4	13	64	66	101	101	101	101
RM GAIN MBH	1.89	1.12	1.12	0.73	2.75	2.01	0.07	2.44	2.37	1.89	0.39	1.69	2.25	2.15	2.23	0.74	0.30	1.46	1.24	0.45	0.45	0.45	0.45	0.45
CFM PER RUN COOLING	67	40	40	26	98	71	2	86	84	67	14	60	80	76	76	79	26	11	52	44	16	16	16	16
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH	64	29	32	63	49	28	38	57	52	48	31	40	11	35	28	36	11	26	43	42	28	18	16	16
EQUIVALENT LENGTH	150	140	170	170	150	150	170	140	190	160	140	160	90	100	120	130	150	100	140	130	150	110	130	100
TOTAL EFFECTIVE LENGTH	214	169	202	233	199	176	208	197	242	208	171	200	101	135	148	166	161	126	183	172	192	138	148	116
ADJUSTED PRESSURE	0.08	0.1	0.09	0.07	0.08	0.1	0.08	0.08	0.07	0.08	0.1	0.09	0.17	0.13	0.12	0.1	0.11	0.14	0.09	0.1	0.08	0.12	0.11	0.14
ROUND DUCT SIZE	6	4	4	4	6	6	4	6	6	6	4	5	6	6	6	5	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	204	344	344	252	235	250	57	280	352	204	172	316	388	270	270	279	46	149	470	485	515	515	515	515
COOLING VELOCITY (ft/min)	342	459	459	298	500	362	23	438	428	342	161	441	408	388	388	580	298	126	382	323	82	82	82	82
OUTLET GRILL SIZE	4X10	3X10	3X10	3X10	4X10	4X10	3X10	4X10	4X10	4X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	E	D	C	E	D	D	D	A	D	A	E	B	B	C	B	D	C	A	A	B	B	E

RUN #	25	26	27	28	29	30
ROOM NAME	BAS	BED-2	BED-3	FAM	L/H/G	ENS-3
RM LOSS MBH	3.99	2.15	1.81	1.68	1.49	0.21
CFM PER RUN HEAT	101	55	46	43	38	5
RM GAIN MBH	0.45	2.44	2.75	1.69	2.23	0.07
CFM PER RUN COOLING	16	86	98	60	79	2
ADJUSTED PRESSURE	0.16	0.16	0.16	0.17	0.17	0.17
ACTUAL DUCT LGH	34	61	53	47	37	41
EQUIVALENT LENGTH	150	150	180	140	120	130
TOTAL EFFECTIVE LENGTH	184	211	233	187	157	171
ADJUSTED PRESSURE	0.09	0.08	0.07	0.09	0.11	0.1
ROUND DUCT SIZE	6	6	6	5	5	4
HEATING VELOCITY (ft/min)	515	280	235	316	279	57
COOLING VELOCITY (ft/min)	82	438	500	441	580	23
OUTLET GRILL SIZE	4X10	4X10	4X10	3X10	3X10	3X10
TRUNK	C	D	C	A	C	D

SUPPLY AIR TRUNK SIZE

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	333	0.08	9.3	10	599	TRUNK G	0	0.00	0	0	0
TRUNK B	675	0.08	12.1	18	675	TRUNK H	0	0.00	0	0	0
TRUNK C	333	0.07	9.6	14	428	TRUNK I	0	0.00	0	0	0
TRUNK D	572	0.07	11.8	18	572	TRUNK J	0	0.00	0	0	0
TRUNK E	828	0.07	13.5	22	677	TRUNK K	0	0.00	0	0	0
TRUNK F	0	0.00	0	0	0	TRUNK L	0	0.00	0	0	0

RETURN AIR

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	115	105	95	115	130	115	115	365	130	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH	57	56	54	51	62	58	46	26	44	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	245	155	195	235	195	245	245	240	220	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	302	211	249	286	257	303	291	266	264	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.05	0.07	0.06	0.05	0.06	0.05	0.05	0.06	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	6.2	6.2	7	7	7	7	10.3	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	14	14	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TRUNK	CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK O	0	0.05	0	0	0
TRUNK P	0	0.05	0	0	0
TRUNK Q	0	0.05	0	0	0
TRUNK R	0	0.05	0	0	0
TRUNK S	0	0.05	0	0	0
TRUNK T	0	0.05	0	0	0
TRUNK U	0	0.05	0	0	0
TRUNK V	0	0.05	0	0	0
TRUNK W	0	0.05	0	0	0
TRUNK X	909	0.05	15.2	26	8
TRUNK Y	375	0.05	10.9	14	8
TRUNK Z	585	0.05	13	20	8
DROP	1504	0.05	18.4	24	14

TYPE: SPRINGFIELD 3S
SITE NAME: RUSSEL GARDENS PH 4

LO # 90165
OPT 5 BED

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	5 @ 10.6 cfm	53 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	7 @ 10.6 cfm	74.2 cfm
Table 9.32.3.A.	TOTAL	222.6 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
6 Bedrooms		
As Per Ashrea 62.2 Dwelling- Unit Ventilation		
4.1.1 Total Ventilation Rate		
$Q_{tot} = 0.03A_{floor} + 7.5(N_{br} + 1)$		
TOTAL		161.4 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	222.6	cfm
Less Principal Ventil. Capacity	161.4	cfm
Required Supplemental Capacity	61.2	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE G2400H ECM
Location:	BSMT
161.4 cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
161.4 CFM	X 71 F	X 1.08	X	0.20

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5
G-E/PD	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE G2400H ECM	
210 cfm high	50 cfm low	
80 % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
 Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 90165

Model: SPRINGFIELD 3S

Builder: GREENPARK HOMES

Volume Calculation

Date: 09/04/2021

House Volume

Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)
Bsmt	1547	9	13923
First	1547	10	15470
Second	2084	9	18756
Third	0	9	0
Fourth	0	9	0
Total:			48,149.0 ft³
Total:			1363.4 m³

Air Change & Delta T Data

WINTER NATURAL AIR CHANGE RATE	0.338
SUMMER NATURAL AIR CHANGE RATE	0.121

Design Temperature Difference

	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-17	39	71
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

0.338 x 378.73 x 39 °C x 1.2 = 6022 W
 = 20548 Btu/h

6.2.6 Sensible Gain due to Air Leakage

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

0.121 x 378.73 x 7 °C x 1.2 = 391 W
 = 1334 Btu/h

5.2.3.2 Heat Loss due to Mechanical Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

161 CFM x 71 °F x 1.08 x 0.20 = 2461 Btu/h

6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

161 CFM x 13 °F x 1.08 x 0.20 = 446 Btu/h

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	20,548	9,652	1.064
2	0.3		12,892	0.478
3	0.2		15,311	0.268
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** SPRINGFIELD 3S**OPT 5 BED****BUILDER:** GREENPARK HOMES**SFQT:** 3631**LO#** 90165**SITE:** RUSSEL GARDENS PH 4**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	1	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	48149.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	7
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 55.0 ft	WIDTH: 40.0 ft	EXPOSED PERIMETER:	190.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

Michael O'Rourke

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Hamilton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.8	 Insulation Configuration
Floor Width (m):	12.2	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	2.0	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1865	

TYPE: SPRINGFIELD 3S
LO# 90165

OPT 5 BED


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Hamilton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.62			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1363.4			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1817.5 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	76.2	76.2		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.338			
Cooling Air Leakage Rate (ACH/H):	0.121			

TYPE: SPRINGFIELD 3S
LO# 90165

OPT 5 BED




I MICHAEL O'Rourke HAVE REVIEW
AND TAKE RESPONSIBILITY FOR THE
DESIGN WORK AND AM QUALIFIED
UNDER DIVISION C, 3.2.5 OF THE
BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


HVAC LEGEND						3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No. Description Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date APR/2021	Scale 3/16" = 1'-0"
OPT 5 BED SPRINGFIELD 3S 3631 sqft		BCIN# 19669		
		LO#	90165	




PART. BASEMENT PLAN ELEV. '1'
FOR OPT. GUEST SUITE COND.




BASEMENT PLAN ELEV. '2'




BASEMENT PLAN ELEV. '3'



GROUND FLOOR PLAN ELEV. '2'



GROUND FLOOR PLAN ELEV. '3'



PART. GROUND FLOOR PLAN -
W/ OPT. GUEST SUITE

WOD
CSA-F280-12
PACKAGE A1

I MICHAEL O'DRISKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Drisko
Michael O'Drisko, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND						3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No. Description Date
REVISIONS								

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title ELEVATIONS & OPT GUEST HEATING LAYOUT	
Project Name RUSSELL GARDENS PH 4 HAMILTON, ONTARIO			Date APR/2021	
OPT 5 BED SPRINGFIELD 3S 3631 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO# 90165	