

Block 121 Units 1 to 6

SITE NAME: BARLASSINA				WOB				DATE: Dec-22				WINTER NATURAL AIR CHANGE RATE 0.376				HEAT LOSS ΔT °F. 72				CSA-F280-12							
BUILDER: GREENPARK HOMES				TYPE: CHERRY 3E				GFA: 2140				LO# 99794				SUMMER NATURAL AIR CHANGE RATE 0.100				HEAT GAIN ΔT °F. 9				SB-12 PACKAGE A1			
ROOM USE				MBR				ENS				BED-2		BED-3		FLEX		BATH									
EXP. WALL				37				8				10		30		13		10									
CLG. HT.				9				9				9		9		9		9									
FACTORS																											
GRS.WALL AREA		LOSS GAIN		333				72				90		270		117		90									
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN									
NORTH		20.3	15.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST		20.3	40.5	0	0	0	0	0	0	0	0	27	547	1095	24	487	973	0	0	0	0	0	0	0	0	0	0
SOUTH		20.3	23.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	18	365	430	7	142	167	0	0	0	
WEST		20.3	40.5	18	365	730	16	324	649	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SKYLT.		35.5	99.8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS		19.1	2.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NET EXPOSED WALL		4.3	0.5	315	1339	170	56	238	30	63	268	34	246	1046	133	99	421	53	83	353	45						
NET EXPOSED BSMT WALL ABOVE GR		3.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG		1.2	0.5	348	425	183	136	166	72	206	252	109	160	196	84	252	308	133	80	98	42						
NO ATTIC EXPOSED CLG		2.6	1.1	0	0	0	0	0	0	0	0	0	13	34	15	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED FLOOR		2.4	0.3	0	0	0	0	0	0	206	500	64	32	78	10	0	0	0	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS				0		0		0		0		0		0		0		0		0		0		0		0	
SLAB ON GRADE HEAT LOSS				0		0		0		0		0		0		0		0		0		0		0		0	
SUBTOTAL HT LOSS				2130		729				1568		1840		1094		593											
SUB TOTAL HT GAIN				1083		751				1301		1215		616		254											
LEVEL FACTOR / MULTIPLIER		0.20	0.35			0.20	0.35			0.20	0.35	0.20		0.35	0.20		0.35										
AIR CHANGE HEAT LOSS				753		258				554		651		387		210											
AIR CHANGE HEAT GAIN				59		41				71		66		34		14											
DUCT LOSS				0		0				212		249		0		0											
DUCT GAIN				0		0				239		230		0		0											
HEAT GAIN PEOPLE		240		2	480	0	0			1	240	1	240	0	0	0	0	0	0	0	0	0	0	0	0	0	
HEAT GAIN APPLIANCES/LIGHTS				780		0				780		780		780		780											
TOTAL HT LOSS BTU/H				2883		986				2334		2740		1481		802											
TOTAL HT GAIN x 1.3 BTU/H				3124		1029				3421		3291		1859		349											

ROOM USE															
EXP. WALL															
CLG. HT.															
FACTORS															
GRS.WALL AREA	LOSS	GAIN													
GLAZING															
NORTH	20.3	15.0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	20.3	40.5	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	20.3	23.9	50	1014	1195	0	0	0	7	142	167	0	0	0	0
WEST	20.3	40.5	48	973	1946	0	0	0	0	0	0	0	0	0	0
SKYLT.	35.5	99.8	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	19.1	2.4	10	191	24	0	0	0	0	0	0	14	267	34	20
NET EXPOSED WALL	4.3	0.5	502	2134	271	0	0	0	73	310	39	455	1934	246	90
NET EXPOSED BSMT WALL ABOVE GR	3.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.2	0.5	0	0	0	48	59	25	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.6	1.1	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.3	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS															
SLAB ON GRADE HEAT LOSS															
SUBTOTAL HT LOSS															
SUB TOTAL HT GAIN															
LEVEL FACTOR / MULTIPLIER	0.30	0.53				0.20	0.35		0.30	0.53		0.30	0.53		0.30
AIR CHANGE HEAT LOSS															
AIR CHANGE HEAT GAIN															
DUCT LOSS															
DUCT GAIN															
HEAT GAIN PEOPLE	240														
HEAT GAIN APPLIANCES/LIGHTS															
TOTAL HT LOSS BTU/H															
TOTAL HT GAIN x 1.3 BTU/H															

TOTAL HEAT GAIN BTU/H:

25020

TONS: 2.09

LOSS DUE TO VENTILATION LOAD BTU/H: 1243

STRUCTURAL HEAT LOSS: 36230

TOTAL COMBINED HEAT LOSS BTU/H: 37473

SITE NAME: BARLASSINA
BUILDER: GREENPARK HOMES

WOB
TYPE: CHERRY 3E
furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

DATE: Dec-22

GFA: 2140 LO# 99794

HEATING CFM 890 COOLING CFM 890
TOTAL HEAT LOSS 36,230 TOTAL HEAT GAIN 24,862
AIR FLOW RATE CFM 24.57 AIR FLOW RATE CFM 35.8

#GOODMAN
GMEC960402BNA 40
FAN SPEED LOW
MEDLOW
MEDIUM 695
MEDIUM HIGH 890
AFUE = 96 %
INPUT (BTU/H) = 40,000
OUTPUT (BTU/H) = 38,400

DESIGN CFM = 890
CFM @ .6" E.S.P.

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	10	6	4
R/A	0	0	4	1	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	4	5	6	7	8	9	10	13	14	15	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-2	BED-3	FLEX	BATH	BED-2	BED-3	MBR	K/L/D	K/L/D	K/L/D	LAUN	PWD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.44	0.99	1.17	1.37	1.48	0.80	1.17	1.37	1.44	2.21	2.21	2.21	0.08	0.69	3.72	1.17	3.18	3.18	3.18	3.18
CFM PER RUN HEAT	35	24	29	34	36	20	29	34	35	54	54	54	2	17	91	29	78	78	78	78
RM GAIN MBH.	1.56	1.03	1.71	1.65	1.86	0.35	1.71	1.65	1.56	1.91	1.91	1.91	1.05	0.28	1.00	0.13	0.90	0.90	0.90	0.90
CFM PER RUN COOLING	56	37	61	59	67	12	61	59	56	68	68	68	38	10	36	5	32	32	32	32
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	48	38	58	60	48	40	59	62	46	23	16	35	35	35	49	39	47	11	40	36
EQUIVALENT LENGTH	170	160	140	170	170	120	150	180	150	140	110	100	140	90	130	140	140	100	140	100
TOTAL EFFECTIVE LENGTH	218	198	198	230	218	160	209	242	196	163	126	135	175	125	179	179	187	111	180	136
ADJUSTED PRESSURE	0.08	0.09	0.09	0.07	0.08	0.11	0.08	0.07	0.09	0.11	0.14	0.13	0.1	0.14	0.09	0.1	0.09	0.15	0.1	0.13
ROUND DUCT SIZE	5	4	5	5	5	4	5	5	5	5	5	5	4	4	6	4	5	5	5	5
HEATING VELOCITY (ft/min)	257	275	213	250	264	229	213	250	257	396	396	396	23	195	464	333	573	573	573	573
COOLING VELOCITY (ft/min)	411	424	448	433	492	138	448	433	411	499	499	499	436	115	184	57	235	235	235	235
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10
TRUNK	A	A	D	C	D	D	D	C	B	D	B	A	B	D	C	D	A	B	C	A

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.44	35	1.56	56	0.17	48	170	218	0.08	5	257	411	3X10	A
2	ENS	0.99	24	1.03	37	0.17	38	160	198	0.09	4	275	424	3X10	A
4	BED-2	1.17	29	1.71	61	0.17	58	140	198	0.09	5	213	448	3X10	D
5	BED-3	1.37	34	1.65	59	0.17	60	170	230	0.07	5	250	433	3X10	C
6	FLEX	1.48	36	1.86	67	0.17	48	170	218	0.08	5	264	492	3X10	D
7	BATH	0.80	20	0.35	12	0.17	40	120	160	0.11	4	229	138	3X10	D
8	BED-2	1.17	29	1.71	61	0.17	59	150	209	0.08	5	213	448	3X10	D
9	BED-3	1.37	34	1.65	56	0.17	62	180	242	0.07	5	250	433	3X10	C
10	MBR	1.44	35	1.56	56	0.17	46	150	196	0.09	5	257	411	3X10	B
13	K/L/D	2.21	54	1.91	68	0.17	23	140	163	0.11	5	396	499	3X10	D
14	K/L/D	2.21	54	1.91	68	0.17	16	110	126	0.14	5	396	499	3X10	B
15	K/L/D	2.21	54	1.91	68	0.17	35	100	135	0.13	5	396	499	3X10	A
17	LAUN	0.08	2	1.05	38	0.17	35	90	175	0.1	4	23	436	3X10	B
18	PWD	0.69	17	0.28	10	0.17	35	130	125	0.14	4	195	115	3X10	D
19	FOY	3.72	91	1.00	36	0.16	49	140	179	0.09	6	464	184	4X10	C
20	MUD	1.17	29	0.13	5	0.17	39	140	179	0.1	4	333	57	3X10	D
21	BAS	3.18	78	0.90	32	0.17	47	100	187	0.09	5	573	235	3X10	A
22	BAS	3.18	78	0.90	32	0.17	11	140	111	0.15	5	573	235	3X10	B
23	BAS	3.18	78	0.90	32	0.17	40	140	180	0.1	5	573	235	3X10	C
24	BAS	3.18	78	0.90	32	0.17	36	100	136	0.13	5	573	235	3X10	A

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)			
TRUNK A	269	0.08	8.6	8	x	8	605	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0
TRUNK B	438	0.08	10.3	12	x	8	657	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0
TRUNK C	237	0.07	8.5	8	x	8	533	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0
TRUNK D	451	0.07	10.8	14	x	8	580	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
AIR VOLUME	85	85	85	95	384	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	82	75	66	70	41	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	225	235	195	150	185	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	307	310	261	220	226	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.05	0.05	0.06	0.07	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	6.3	6.3	6	6	10.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: CHERRY 3E
SITE NAME: BARLASSINA

LO # 99794
WOB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>2</u> @ 10.6 cfm	<u>21.2</u> cfm
Kitchen & Bathrooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Other Rooms	<u>5</u> @ 10.6 cfm	<u>53.0</u> cfm
Table 9.32.3.A.	TOTAL	<u>159.0</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>63.6</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>159</u>	cfm
Less Principal Ventil. Capacity	<u>63.6</u>	cfm
Required Supplemental Capacity	<u>95.4</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE V150H
Location:	BSMT
<u>63.6</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
63.6 CFM	X 72 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
BATH	BY INSTALLING CONTRACTOR	50	☒	3.5
LAUN	BY INSTALLING CONTRACTOR	50	☒	3.5
PWD	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	
<u>150</u> cfm high	<u>35</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	December-22

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 99794	Model: CHERRY 3E	Builder: GREENPARK HOMES	Date: 12/22/2022																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>981</td> <td>9</td> <td>8829</td> </tr> <tr> <td>First</td> <td>981</td> <td>10</td> <td>9810</td> </tr> <tr> <td>Second</td> <td>1159</td> <td>9</td> <td>10431</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>29,070.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>823.2 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	981	9	8829	First	981	10	9810	Second	1159	9	10431	Third	0	9	0	Fourth	0	9	0	Total:			29,070.0 ft³	Total:			823.2 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.376</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.100</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-18</td> <td>40</td> <td>72</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>29</td> <td>5</td> <td>9</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.376	SUMMER NATURAL AIR CHANGE RATE	0.100	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-18	40	72	Summer DTDc	24	29	5	9
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	981	9	8829																																																									
First	981	10	9810																																																									
Second	1159	9	10431																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			29,070.0 ft³																																																									
Total:			823.2 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.376																																																											
SUMMER NATURAL AIR CHANGE RATE	0.100																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-18	40	72																																																								
Summer DTDc	24	29	5	9																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.376 x 228.66 x 40 °C x 1.2 = 4153 W = 14169 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.100 x 228.66 x 5 °C x 1.2 = 140 W = 477 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 64 CFM x 72 °F x 1.08 x 0.25 = 1243 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 64 CFM x 9 °F x 1.08 x 0.25 = 158 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center; vertical-align: middle;">14,169</td> <td>5,636</td> <td>1.257</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>7,954</td> <td>0.534</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>8,011</td> <td>0.354</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table>					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	14,169	5,636	1.257	2	0.3	7,954	0.534	3	0.2	8,011	0.354	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	14,169	5,636	1.257																																																								
2	0.3		7,954	0.534																																																								
3	0.2		8,011	0.354																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												
				Michael O'Rourke BCIN# 19669																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: CHERRY 3E	WOB	BUILDER: GREENPARK HOMES
SFQT: 2140	LO# 99794	SITE: BARLASSINA

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	0	OUTDOOR DESIGN TEMP.	84
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	ATTACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	29070.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	4
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 62.0 ft	WIDTH: 20.0 ft	EXPOSED PERIMETER:	125.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	30.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Cambridge	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	4.6	 Insulation Configuration
Floor Width (m):	6.1	
Exposed Perimeter (m):	38.1	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.46	
Window Area (m ²):	0.7	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		493

TYPE: CHERRY 3E
LO# 99794


WOB

Michael O'Rourke BCIN #19669



Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Cambridge	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	
Width (m):	6.1	
Exposed Perimeter (m):	9.1	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		88

TYPE: CHERRY 3E
LO# 99794

WOB

Air Infiltration Residential Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Cambridge			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.53			
Building Configuration				
Type:	Semi			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	823.2			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1097.3 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	30.0	30.0		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.376			
Cooling Air Leakage Rate (ACH/H):	0.100			

TYPE: CHERRY 3E
LO# 99794

WOB

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.



PARTIAL BASEMENT LAYOUT FOR WOB CONDITION

WOB
CSA-F280-12
PACKAGE A1


I MICHAEL O'ROURKE HAVE REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		


ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	HEAT LOSS 37473 BTU/H		# OF RUNS			S/A			R/A			FANS			Sheet Title		
GREENPARK HOMES			UNIT DATA		3RD FLOOR									BASEMENT					
Project Name			MAKE		2ND FLOOR			10			4			3			HEATING		
BARLASSINA			MODEL		1ST FLOOR			6			1			2			LAYOUT		
CAMBRIDGE, ONTARIO			INPUT		BASEMENT			4			1			0			Date		
Block 121 Units 1 to 6			40 MBTU/H														DEC/2022		
WOB			OUTPUT		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A												Scale		
CHERRY 3E		38.4 MBTU/H														3/16" = 1'-0"			
2140 sqft		COOLING		TONS												BCIN# 19669			
		2.0														LO#			
		FAN SPEED		cfm @ 0.6" w.c.												99794			
		890																	

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.



FIRST FLOOR PLAN EL-1



FIRST FLOOR PLAN EL-2

I MICHAEL O'ROURKE HAVE REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.



WOB
CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title	
GREENPARK HOMES			FIRST FLOOR HEATING LAYOUT	
Project Name			Date	DEC/2022
BARLASSINA CAMBRIDGE, ONTARIO Block 121 Units 1 to 6			Scale	3/16" = 1'-0"
WOB CHERRY 3E			BCIN# 19669	
2140 sqft			LO#	99794

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.



SEC. FLOOR PLAN EL-2

SEC. FLOOR PLAN EL-1

I MICHAEL O'ROURKE HAVE REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

WOB

CSA-F280-12

PACKAGE A1

HVAC LEGEND							3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	DescriptionDate
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title	
GREENPARK HOMES			SECOND FLOOR HEATING LAYOUT	
Project Name			Date	DEC/2022
BARLASSINA CAMBRIDGE, ONTARIO			Scale	3/16" = 1'-0"
Block 121 Units 1 to 6			BCIN# 19669	
WOB		LO#	99794	
CHERRY 3E	2140 sqft			