

SITE NAME: BARLASSINA

Block 121 Units 7 to 12

BUILDER: GREENPARK HOMES

TYPE: CHERRY 12

GFA: 2354

DATE: Aug-22

LO# 98652

WINTER NATURAL AIR CHANGE RATE 0.319

SUMMER NATURAL AIR CHANGE RATE 0.085

HEAT LOSS ΔT °F. 72

HEAT GAIN ΔT °F. 9

CSA-F280-12

SB-12 PACKAGE A1

ROOM USE	EXP. WALL	CLG. HT.	MBR	ENS	BED-2	BED-3	BED-4	BATH	ENS-3	SB-12 PACKAGE A1
			13	21	11	37	14	9	11	
			9	9	9	9	9	9	9	
GRS.WALL AREA	LOSS	GAIN	117	189	99	333	126	81	99	
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	20.3	15.0	0	0	0	0	0	0	0	0
EAST	20.3	40.5	0	0	0	0	0	0	0	0
SOUTH	20.3	23.9	0	0	0	0	0	0	0	0
WEST	20.3	40.5	24	487	10	203	405	12	243	287
SKYLT.	35.5	99.8	0	0	0	0	0	0	0	0
DOORS	19.1	2.4	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.3	0.5	93	395	50	167	710	90	69	293
NET EXPOSED BSMT WALL ABOVE GR	3.4	0.4	0	0	0	0	0	0	114	485
EXPOSED CLG	1.2	0.5	390	477	205	108	132	57	69	293
NO ATTIC EXPOSED CLG	2.6	1.1	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.4	0.3	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1359	1229	1288	1636	2629	919	658	376
SUB TOTAL HT GAIN				839		1434	1881	430		376
LEVEL FACTOR / MULTIPLIER	0.20	0.27		0.20	0.27	0.20	0.27	0.20	0.27	
AIR CHANGE HEAT LOSS	371			351		446		251		179
AIR CHANGE HEAT GAIN			51		35	60		79		16
DUCT LOSS			0		0	208		335		0
DUCT GAIN			0		0	222		268		0
HEAT GAIN PEOPLE	240		2		480	0		0		0
HEAT GAIN APPLIANCES/LIGHTS					481	0		0		0
TOTAL HT LOSS BTU/H			1729		1639	2291		3681		1169
TOTAL HT GAIN x 1.3 BTU/H			2913		1137	3168		3833		1520

ROOM USE			LIB		DIN		KT/FM				LAUN		PWD		FOY								BAS	
EXP. WALL			37		27		42				0		6		28								132	
CLG. HT.			10		10		10				9		10		10								9	
GRS.WALL AREA	FACTORS		370		270		420				0		60		280								792	
GLAZING	LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN				LOSS GAIN		LOSS GAIN		LOSS GAIN								LOSS GAIN	
NORTH	20.3	15.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							0
EAST	20.3	40.5	30	608	1216	0	0	0	0	0	0	0	0	0	0	0	0							0
SOUTH	20.3	23.9	15	304	358	33	669	788	30	608	717	0	0	0	15	304	358	10	203	239				4
WEST	20.3	40.5	0	0	0	0	0	0	82	1662	3325	0	0	0	0	0	0	0	0	0				81
SKYLT.	35.5	99.8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				81
DOORS	19.1	2.4	0	0	0	0	0	0	8	153	19	0	0	0	0	0	0	48	917	117				0
NET EXPOSED WALL	4.3	0.5	325	1382	176	237	1008	128	300	1275	162	0	0	0	45	191	24	222	944	120				20
NET EXPOSED BSMT WALL ABOVE GR	3.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0
EXPOSED CLG	1.2	0.5	0	0	0	0	0	0	0	0	0	42	51	22	0	0	0	0	0	0				0
NO ATTIC EXPOSED CLG	2.6	1.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				0
EXPOSED FLOOR	2.4	0.3	0	0	0	0	0	0	0	0	0	42	102	13	0	0	0	0	0	0				0
BASEMENT/CRAWL HEAT LOSS				0			0			0			0			0			0					0
SLAB ON GRADE HEAT LOSS				0			0			0			0			0			0					0
SUBTOTAL HT LOSS				2294			1677			3699			153			495			2063					4268
SUB TOTAL HT GAIN					1750			916			4223			35			383			475				6251
LEVEL FACTOR / MULTIPLIER		0.30	0.39			0.30	0.39		0.30	0.39		0.20	0.27		0.30	0.39		0.30	0.39					641
AIR CHANGE HEAT LOSS			883				646			1424			42			191			794					0.50
AIR CHANGE HEAT GAIN				73			38			176				1		16				20				1.05
DUCT LOSS			0				0			0			20			0			0					5563
DUCT GAIN				0			0			0				52		0			0					27
HEAT GAIN PEOPLE	240		0		0		0		0	0		0		0		0		0	0					0
HEAT GAIN APPLIANCES/LIGHTS				481			481			481			481			0		0	0					0
TOTAL HT LOSS BTU/H				3177			2322			5123			215			686			2858					481
TOTAL HT GAIN x 1.3 BTU/H					2996			1866			6344			740			518			644				12814
																								1493

TOTAL HEAT GAIN BTU/H:

28814

TONS: 2.40

LOSS DUE TO VENTILATION LOAD BTU/H: 1554

STRUCTURAL HEAT LOSS: 39793

TOTAL COMBINED HEAT LOSS BTU/H: 41347

SITE NAME: BARLASSINA
BUILDER: GREENPARK HOMES

TYPE: CHERRY 12

DATE: Aug-22

GFA: 2354

LO# 98652

HEATING CFM 928 COOLING CFM 928
TOTAL HEAT LOSS 39,793 TOTAL HEAT GAIN 28,616
AIR FLOW RATE CFM 23.32 AIR FLOW RATE CFM 32.43

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

DESIGN CFM = 928
CFM @ .6" E.S.P.

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	8	3
R/A	0	0	5	1	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	21	22	23
ROOM NAME	MBR	ENS	BED-2	BED-2	BED-3	BED-4	BATH	BED-3	LIB	MBR	ENS-3	LIB	DIN	KT/FM	KT/FM	KT/FM	LAUN	PWD	FOY	BAS	BAS	BAS
RM LOSS MBH.	0.86	1.64	1.15	1.15	1.84	1.17	0.84	1.84	1.59	0.86	1.25	1.59	2.32	1.71	1.71	1.71	0.21	0.69	2.86	4.27	4.27	4.27
CFM PER RUN HEAT	20	38	27	27	43	27	20	43	37	20	29	37	54	40	40	40	5	16	67	100	100	100
RM GAIN MBH.	1.46	1.14	1.58	1.58	1.92	1.52	0.51	1.92	1.50	1.46	0.94	1.50	1.87	2.11	2.11	2.11	0.74	0.52	0.64	0.50	0.50	0.50
CFM PER RUN COOLING	47	37	51	51	62	49	17	62	49	47	30	49	61	69	69	69	24	17	21	16	16	16
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16
ACTUAL DUCT LGH.	35	43	57	60	64	35	42	54	52	36	37	44	27	27	29	21	46	39	26	29	16	39
EQUIVALENT LENGTH	150	200	180	120	180	140	150	160	130	160	150	130	140	80	130	110	130	110	140	130	120	140
TOTAL EFFECTIVE LENGTH	185	243	237	180	244	175	192	214	182	196	187	174	167	107	159	131	176	149	166	159	136	179
ADJUSTED PRESSURE	0.09	0.07	0.07	0.1	0.07	0.1	0.09	0.08	0.09	0.09	0.09	0.1	0.1	0.16	0.11	0.13	0.1	0.12	0.1	0.1	0.12	0.09
ROUND DUCT SIZE	5	4	5	5	6	6	4	6	5	5	4	5	5	5	5	5	4	4	5	6	6	6
HEATING VELOCITY (ft/min)	147	436	198	198	219	138	229	219	272	147	333	272	396	294	294	294	57	184	492	510	510	510
COOLING VELOCITY (ft/min)	345	424	374	374	316	250	195	316	360	345	344	360	448	507	507	507	275	195	154	82	82	82
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	4X10	4X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10
TRUNK	C	D	A	B	A	D	D	A	A	C	B	A	B	D	C	C	B	B	B	C	D	A

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE															RETURN AIR TRUNK SIZE						
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)
TRUNK A	287	0.07	9.1	10	x	8	517		TRUNK G	0	0.00	0	0	x	8	0		0	x	8	0
TRUNK B	485	0.07	11.1	14	x	8	624		TRUNK H	0	0.00	0	0	x	8	0		0	x	8	0
TRUNK C	220	0.09	7.7	8	x	8	495		TRUNK I	0	0.00	0	0	x	8	0		0	x	8	0
TRUNK D	445	0.07	10.7	14	x	8	572		TRUNK J	0	0.00	0	0	x	8	0		0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0		TRUNK K	0	0.00	0	0	x	8	0		0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0		TRUNK L	0	0.00	0	0	x	8	0		0	x	8	0
RETURN AIR #	1	2	3	4	5	6									BR						
AIR VOLUME	135	95	85	75	75	360	0	0	0	0	0	0	0	0	0						
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15						
ACTUAL DUCT LGH.	45	36	64	68	69	38	1	1	1	1	1	1	1	1	1						
EQUIVALENT LENGTH	175	140	195	235	240	150	0	0	0	0	0	0	0	0	0						
TOTAL EFFECTIVE LH	220	176	259	303	309	188	1	1	1	1	1	1	1	1	1						
ADJUSTED PRESSURE	0.07	0.08	0.06	0.05	0.05	0.08	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80						
ROUND DUCT SIZE	6.8	5.8	6	6	6	9.6	0	0	0	0	0	0	0	0	0						
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0						
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X						
INLET GRILL SIZE	14	14	14	14	14	30	0	0	0	0	0	0	0	0	0						

TYPE: CHERRY 12
SITE NAME: BARLASSINA

LO # 98652

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES 9.32.3.1(1)

a) ☒ Direct vent (sealed combustion) only

b) ☐ Positive venting induced draft (except fireplaces)

c) ☐ Natural draft, B-vent or induced draft gas fireplace

d) ☐ Solid Fuel (including fireplaces)

e) ☐ No Combustion Appliances

HEATING SYSTEM

☒ Forced Air ☐ Non Forced Air

☐ Electric Space Heat

HOUSE TYPE 9.32.1(2)

☒ I Type a) or b) appliance only, no solid fuel

☐ II Type I except with solid fuel (including fireplaces)

☐ III Any Type c) appliance

☐ IV Type I, or II with electric space heat

☐ Other: Type I, II or IV no forced air

SYSTEM DESIGN OPTIONS O.N.H.W.P.

☐ 1 Exhaust only/Forced Air System

☐ 2 HRV with Ducting/Forced Air System

☒ 3 HRV Simplified/connected to forced air system

☐ 4 HRV with Ducting/non forced air system

☐ Part 6 Design

TOTAL VENTILATION CAPACITY 9.32.3.3(1)

Basement + Master Bedroom	2	@ 21.2 cfm	42.4	cfm
Other Bedrooms	3	@ 10.6 cfm	31.8	cfm
Kitchen & Bathrooms	5	@ 10.6 cfm	53	cfm
Other Rooms	5	@ 10.6 cfm	53.0	cfm
Table 9.32.3.A.	TOTAL		180.2	cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4.(1)

1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.5.

Total Ventilation Capacity	180.2	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	100.7	cfm

PRINCIPAL EXHAUST FAN CAPACITY

Model: VANE V150H Location: BSMT

79.5 cfm ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION

CFM		$\Delta T \cdot F$		FACTOR		% LOSS
79.5 CFM	X	72 F	X	1.08	X	0.25

SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR

Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
BATH	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
PWD	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5

HEAT RECOVERY VENTILATOR 9.32.3.11.

Model: VANE V150H

150 cfm high 35 cfm low

75 % Sensible Efficiency ☒ HVI Approved
@ 32 deg F (0 deg C)

LOCATION OF INSTALLATION

Lot: Concession

Township: Plan:

Address:

Roll # Building Permit #

BUILDER: GREENPARK HOMES

Name:

Address:

City:

Telephone #: Fax #:

INSTALLING CONTRACTOR

Name:

Address:

City:

Telephone #: Fax #:

DESIGNER CERTIFICATION

I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.

Name: HVAC Designs Ltd.

Signature: *Michael O'Rourke*

HRAI # 001820

Date: August-22

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 98652		Model: CHERRY 12		Date: 2022-08-30																																																								
Builder: GREENPARK HOMES																																																												
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1054</td> <td>9</td> <td>9486</td> </tr> <tr> <td>First</td> <td>1054</td> <td>10</td> <td>10540</td> </tr> <tr> <td>Second</td> <td>1300</td> <td>9</td> <td>11700</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>31,726.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>898.4 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)	Bsmt	1054	9	9486	First	1054	10	10540	Second	1300	9	11700	Third	0	9	0	Fourth	0	9	0	Total:			31,726.0 ft ³	Total:			898.4 m ³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.319</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.085</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-18</td> <td>40</td> <td>72</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>29</td> <td>5</td> <td>9</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.319	SUMMER NATURAL AIR CHANGE RATE	0.085	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-18	40	72	Summer DTDc	24	29	5	9
Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)																																																									
Bsmt	1054	9	9486																																																									
First	1054	10	10540																																																									
Second	1300	9	11700																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			31,726.0 ft ³																																																									
Total:			898.4 m ³																																																									
WINTER NATURAL AIR CHANGE RATE	0.319																																																											
SUMMER NATURAL AIR CHANGE RATE	0.085																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-18	40	72																																																								
Summer DTDc	24	29	5	9																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ <p>0.319 x 249.55 x 40 °C x 1.2 = 3847 W</p> <p>= 13127 Btu/h</p>			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ <p>= 0.085 x 249.55 x 5 °C x 1.2 = 129 W</p> <p>= 442 Btu/h</p>																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 72 °F x 1.08 x 0.25 = 1554 Btu/h</p>			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 9 °F x 1.08 x 0.25 = 197 Btu/h</p>																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	13,127	6,251	1.050																																																								
2	0.3		10,228	0.385																																																								
3	0.2		9,625	0.273																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
<p>*HLairbv = Air leakage heat loss + ventilation heat loss</p> <p>*For a balanced or supply only ventilation system HLairve = 0</p>																																																												

Michael O'Rourke
BCIN# 19669

Michael O'Rourke

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** CHERRY 12**BUILDER:** GREENPARK HOMES**SFQT:** 2354**LO#** 98652**SITE:** BARLASSINA**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	0	OUTDOOR DESIGN TEMP.	84
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	ATTACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	31726.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 57.0 ft	WIDTH: 25.0 ft	EXPOSED PERIMETER:	132.0 ft


2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKENOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS
& DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION
BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE
OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING
CODE AND ANY OTHER REFERENCED REQUIREMENTS.

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Cambridge	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	17.4	 Insulation Configuration
Floor Width (m):	7.6	
Exposed Perimeter (m):	40.2	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.1	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1250

TYPE: CHERRY 12
LO# 98652NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS
& DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION
BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE
OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING
CODE AND ANY OTHER REFERENCED REQUIREMENTS.

Michael O'Rourke BCIN #19669






Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Cambridge			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.71			
Building Configuration				
Type:	Semi			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	898.4			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa. 3.57	1197.6 cm ² ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply 37.5	Total Exhaust 37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):		0.319		
Cooling Air Leakage Rate (ACH/H):		0.085		

TYPE: CHERRY 12
LO# 98652NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS
& DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION
BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE
OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING
CODE AND ANY OTHER REFERENCED REQUIREMENTS.



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C. 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.

CSA-F280-12
PACKAGE A1


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client		<div></div> <div>375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services</div> <div>Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.</div>	HEAT LOSS 41347 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS				Sheet Title	
GREENPARK HOMES			MAKE GOODMAN		3RD FLOOR				BASEMENT HEATING LAYOUT	
Project Name BARLASSINA CAMBRIDGE, ONTARIO			MODEL GMEC960603BNA		2ND FLOOR		11 5 4			
Block 121 Units 7 to 12			INPUT 60 MBTU/H		1ST FLOOR		8 1 2		Date AUG/2022	
CHERRY 12 2354 sqft			OUTPUT 57.6 MBTU/H		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A				Scale 3/16" = 1'-0"	
			COOLING 2.5 TONS						BCIN# 19669	
			FAN SPEED 928 cfm @ 0.6" w.c.						LO# 98652	



FIRST FLOOR PLAN EL-1



FIRST FLOOR PLAN EL-2



FIRST FLOOR PLAN EL-2

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.3 OF THE BUILDING CODE.

Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.

CSA-F280-12
PACKAGE A1


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client
GREENPARK HOMES
Project Name
**BARLASSINA
CAMBRIDGE, ONTARIO**
Block 121 Units 7 to 12
CHERRY 12 **2354 sqft**

HVACDESIGNS LTD.
375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.


Sheet Title
**FIRST FLOOR
HEATING
LAYOUT**
Date **AUG/2022**
Scale **3/16" = 1'-0"**
BCIN# 19669
LO# 98652



SEC. FLOOR PLAN EL-1



SEC. FLOOR PLAN EL-2



SEC. FLOOR PLAN EL-2

CSA-F280-12
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		<div></div> <div>375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services</div> <div>Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.</div>	Sheet Title	
GREENPARK HOMES			SECOND FLOOR HEATING LAYOUT	
Project Name			Date	AUG/2022
BARLASSINA CAMBRIDGE, ONTARIO			Scale	3/16" = 1'-0"
Block 121 Units 7 to 12			BCIN# 19669	
CHERRY 12	2354 sqft		LO#	98652