

SITE NAME: TRINIGROUP
BUILDER: GREENPARK HOMESWOB
TYPE: CAROL 12

DATE: Feb-24

GFA: 3214 LO# 101184

HEATING CFM 1504 COOLING CFM 1504
TOTAL HEAT LOSS 63,640 TOTAL HEAT GAIN 47,919
AIR FLOW RATE CFM 23.63 AIR FLOW RATE CFM 31.39furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35#*GOODMAN
GMEC960804CNA
FAN SPEED 80AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = 76,800

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	12	5
R/A	0	0	6	2	1

plenium pressure s/a 0.18
max s/a dif press. loss 0.02
min adjusted pressure s/a 0.16
r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15LOW 868
MEDLOW 978
MEDIUM 1112
MEDIUM HIGH 1504
HIGH 1615DESIGN CFM = 1504
CFM @ .6" E.S.P.


TEMPERATURE RISE 47 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	BED-2	BED-3	BED-4	ENS-2	ENS-3	LOFT	MBR	ENS-4	LV/DN	FML	KT/BT	KT/BT	OFFICE	LAUN	PWD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.62	2.82	1.83	1.83	0.99	1.34	1.92	1.67	1.62	1.45	1.78	1.95	2.09	2.09	2.62	1.36	1.06	1.81	1.26	4.27	4.27	4.27	4.27
CFM PER RUN HEAT	38	67	43	43	23	32	45	39	38	34	42	46	49	49	62	32	25	43	30	101	101	101	101
RM GAIN MBH.	2.19	2.21	2.26	2.29	1.44	0.45	1.09	1.90	2.19	1.07	1.30	1.55	2.64	2.64	2.93	1.53	0.17	0.87	1.37	1.27	1.27	1.27	1.27
CFM PER RUN COOLING	69	69	71	72	45	14	34	60	69	34	41	49	83	83	92	48	5	27	43	40	40	40	40
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	28	41	48	56	37	52	62	54	36	53	26	33	17	26	52	40	38	44	33	37	44	12	21
EQUIVALENT LENGTH	130	150	230	190	180	120	230	200	160	150	160	80	110	120	110	180	140	130	150	120	160	120	150
TOTAL EFFECTIVE LENGTH	158	191	278	246	217	172	292	254	196	203	186	113	127	146	162	220	178	174	183	157	204	132	171
ADJUSTED PRESSURE	0.11	0.09	0.06	0.07	0.08	0.1	0.06	0.07	0.09	0.08	0.09	0.15	0.13	0.11	0.1	0.08	0.1	0.1	0.09	0.1	0.08	0.12	0.09
ROUND DUCT SIZE	5	5	6	6	5	4	5	5	5	4	4	5	6	6	6	5	4	4	4	6	6	6	6
HEATING VELOCITY (ft/min)	279	492	219	219	169	367	330	286	279	390	482	338	250	250	316	235	287	493	344	515	515	515	515
COOLING VELOCITY (ft/min)	507	507	362	367	330	161	250	441	507	390	470	360	423	423	469	352	57	310	493	204	204	204	204
OUTLET GRILL SIZE	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	C	D	B	C	D	D	A	C	C	B	A	A	D	C	D	D	C	A	A	B	C

RUN #	25	26	27	28	29	30
ROOM NAME	BAS	BED-3	BED-4	OFFICE	FML	LV/DN
RM LOSS MBH.	4.27	1.83	0.99	2.62	1.95	1.78
CFM PER RUN HEAT	101	43	23	62	46	42
RM GAIN MBH.	1.27	2.29	1.44	2.93	1.55	1.30
CFM PER RUN COOLING	40	72	45	92	49	41
ADJUSTED PRESSURE	0.16	0.17	0.17	0.16	0.17	0.17
ACTUAL DUCT LGH.	44	59	60	54	25	36
EQUIVALENT LENGTH	120	200	180	110	90	120
TOTAL EFFECTIVE LENGTH	164	259	240	164	115	156
ADJUSTED PRESSURE	0.1	0.07	0.07	0.1	0.15	0.11
ROUND DUCT SIZE	6	6	5	6	5	4
HEATING VELOCITY (ft/min)	515	219	169	316	338	482
COOLING VELOCITY (ft/min)	204	367	330	469	360	470
OUTLET GRILL SIZE	4X10	4X10	3X10	4X10	3X10	3X10
TRUNK	D	D	C	D	B	C



SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)
TRUNK A	376	0.08	9.7	12	x	8	564	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	659	0.08	12	16	x	8	741	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	842	0.06	14.1	24	x	8	632	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	463	0.06	11.3	16	x	8	521	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)	
TRUNK O	0	0.05	0	0	x	8	0
TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0
TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0
TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0
TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	0	0.05	0	0	x	8	0
TRUNK X	1504	0.05	18.4	32	x	10	677
TRUNK Y	480	0.05	12	16	x	8	540
TRUNK Z	250	0.05	9.4	10	x	8	450
DROP	1504	0.05	18.4	24	x	14	645

RETURN AIR #	1	2	3	4	5	6	7	8								BR
AIR VOLUME	128	115	115	135	115	135	393	115	0	0	0	0	0	0	0	253
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	33	69	67	43	65	42	22	43	1	1	1	1	1	1	1	14
EQUIVALENT LENGTH	195	215	255	240	230	205	155	235	0	0	0	0	0	0	0	135
TOTAL EFFECTIVE LH	228	284	322	283	295	247	177	278	1	1	1	1	1	1	1	149
ADJUSTED PRESSURE	0.06	0.05	0.05	0.05	0.05	0.06	0.08	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.10
ROUND DUCT SIZE	7	7	7	7.5	7	7	9.9	7	0	0	0	0	0	0	0	7.9
INLET GRILL SIZE	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	14	30	14	0	0	0	0	0	0	0	24

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

TYPE: CAROL 12
SITE NAME: TRINIGROUPLO # 101184
WOB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM		PXV
☒	Forced Air	☐ Non Forced Air
☐	Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm	
Other Bedrooms	<u>3</u> @ 10.6 cfm <u>31.8</u> cfm	
Kitchen & Bathrooms	<u>6</u> @ 10.6 cfm <u>63.6</u> cfm	
Other Rooms	<u>5</u> @ 10.6 cfm <u>53.0</u> cfm	
Table 9.32.3.A.	TOTAL	<u>190.8</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1	Bedroom	31.8 cfm
2	Bedroom	47.7 cfm
3	Bedroom	63.6 cfm
4	Bedroom	79.5 cfm
5	Bedroom	95.4 cfm
TOTAL		<u>79.5</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>190.8</u>	cfm
Less Principal Ventil. Capacity	<u>79.5</u>	cfm
Required Supplemental Capacity	<u>111.3</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
<u>79.5</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION			
CFM	ΔT °F	FACTOR	% LOSS
79.5 CFM	X 78 F	X 1.08	X 0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR	
Location	Model	cfm	HVI
ENS	BY INSTALLING CONTRACTOR	50	☒
ENS-2	BY INSTALLING CONTRACTOR	50	☒
ENS-4	BY INSTALLING CONTRACTOR	50	☒
PWD	BY INSTALLING CONTRACTOR	50	☒

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H		
<u>150</u> cfm high	<u>35</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:


DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	February-24

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE

05/01/2024

RECEIVED
Per: joshua.nabua

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 101184		Model: CAROL 12		Builder: GREENPARK HOMES																																																								
				Date: 2/14/2024																																																								
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>1523</td><td>9</td><td>13707</td></tr> <tr><td>First</td><td>1523</td><td>10</td><td>15230</td></tr> <tr><td>Second</td><td>1691</td><td>9</td><td>15219</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>44,156.0 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>1250.4 m³</td></tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1523	9	13707	First	1523	10	15230	Second	1691	9	15219	Third	0	9	0	Fourth	0	9	0	Total:			44,156.0 ft³	Total:			1250.4 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.380</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.118</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-21</td> <td>43</td> <td>78</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.380	SUMMER NATURAL AIR CHANGE RATE	0.118	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1523	9	13707																																																									
First	1523	10	15230																																																									
Second	1691	9	15219																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			44,156.0 ft³																																																									
Total:			1250.4 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.380																																																											
SUMMER NATURAL AIR CHANGE RATE	0.118																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.380 x 347.32 x 43 °C x 1.2 = 6843 W = 23350 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.118 x 347.32 x 7 °C x 1.2 = 351 W = 1197 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 78 °F x 1.08 x 0.25 = 1670 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5" style="text-align: center;">23,350</td><td>9,690</td><td>1.205</td></tr> <tr><td>2</td><td>0.3</td><td>15,355</td><td>0.456</td></tr> <tr><td>3</td><td>0.2</td><td>14,616</td><td>0.320</td></tr> <tr><td>4</td><td>0</td><td>0</td><td>0.000</td></tr> <tr><td>5</td><td>0</td><td>0</td><td>0.000</td></tr> </tbody> </table>					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	23,350	9,690	1.205	2	0.3	15,355	0.456	3	0.2	14,616	0.320	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	23,350	9,690	1.205																																																								
2	0.3		15,355	0.456																																																								
3	0.2		14,616	0.320																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

Michael O'Rourke
BCIN# 19669


HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: CAROL 12	WOB	BUILDER: GREENPARK HOMES
SFQT: 3214	LO# 101184	SITE: TRINIGROUP

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	44156.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.90	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 62.0 ft	WIDTH: 37.0 ft	EXPOSED PERIMETER:	133.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	65.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component

Compliance Package A1

	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE




CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	7.3	 Insulation Configuration
Floor Width (m):	11.3	
Exposed Perimeter (m):	40.5	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.61	
Window Area (m ²):	0.7	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		828

TYPE: CAROL 12
LO# 101184

WOB

Michael O'Rourke BCIN #19669


CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	4.3	
Width (m):	11.3	
Exposed Perimeter (m):	19.8	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		288

TYPE: CAROL 12
LO# 101184

WOB

Michael O'Rourke BCIN# 19669

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Richmond Hill			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.53			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1250.4			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1666.8 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.380			
Cooling Air Leakage Rate (ACH/H):	0.118			

TYPE: CAROL 12
LO# 101184

WOB

Michael O'Rourke BCIN# 19669

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.7 AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD.7 IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

INSTALLATION TO COMPLY WITH THE LATEST ONTARIO BUILDING CODE. ALL SUPPLY BRANCH OUTLETS SHALL BE EQUIPPED WITH MANUAL BALANCING DAMPER, DUCTWORK WHICH PASSES THROUGH THE GARAGE OR UNHEATED SPACES SHALL BE ADEQUATELY INSULATED AND GAS-PROOFED


ALL S/A DIFFUSERS "4x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"x UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A

SUPPLEMENTAL EXHAUST FAN (MINIMUM 100 CFM) DISCHARGING DIRECTLY TO THE EXTERIOR WILL BE PROVIDED IN THE KITCHEN. EXHAUST DUCTS SERVING THE KITCHEN SHALL NOT BE SMALLER THAN RECOMMENDED BY THE MANUFACTURER OF THE FANS AND MUST AT LEAST MEET O.B.C. STATED MINIMUMS.



PARTIAL BASEMENT PLAN FOR WALK-UP CONDITION

City of Richmond Hill
Building Division
HVAC REVIEWED
Initials: PV



BASEMENT FLOOR PLAN '2'

City of Richmond Hill
Building Division
REVIEWED
By: PV Date: May/07/2024
Building Permit #: RM#24-00016
All construction shall comply with the Ontario Building Code and all other applicable statutory regulations. The reviewed documents must be kept on file for 10 years. Submitting drawings to: richmondhill.ca/building_inquiry_line 905-771-3830

Ensure that R-Values and U-Values used for heat loss and heat gain calculations are consistent with the values specified by SB-12 Prescriptive Package 'A1' and the values used for architectural design.

BASEMENT FLOOR PLAN '3'

13.Exterior insulation effective R-Value for wall, roof or exposed floor shall be maintained at the respective location where duct or sanitary pipes are routed inside exterior envelope.
14. Return air intake shall be provided as recommended in HRAI Digest 2005 Section 4.7 Return air inlet should be positioned so that short circuiting of supply air is avoided. A high and low wall return air combination shall be provided when a combined cooling & heating system is installed.
15. For simplified HRV/ERV installation, with stale air and fresh air connected to return air plenum, stale air intake and fresh air supply shall be separated minimum 3' or as recommended by HRV/ERV Manufacturer.


1.Laundry dryer exhaust duct shall be provided as per OBC 2012 Div.B 6.2.3.8(7).
2.Kitchen hood exhaust duct shall be provided as per OBC 2012, Div.B 9.32.3.10, 9.32.3.5(2).
3.Minimum R-12 Insulation Value required for ducts installed at unheated or exposed condition (OBC 2012 Div.B 6.2.4.3(10) and seal the ducts as per 6.2.4.3(11) & HRAI Digest 2005, Clause 4.5.
4.Penetration of Air Barrier System by ducts, wires, conduits or building materials shall be sealed as per OBC 2012, Div.B 9.25.3.3(9) & (10).
5.Volume control dampers to all branches to be installed per OBC 2012, Div.B. 6.2.4.5.
6.Space between studs and joists used as return ducts shall be separated from unused portion as per OBC 2012 Div.B 6.2.4.7(6)

7. Combustion air supply shall be provided to the furnace and hot water tank.

8.HRV installation, testing, startup and commissioning shall be in compliance with OBC 2012, Div.B 9.32.3.11, 9.32.3.11(7)&(10)

9. HRV duct connection shall be in compliance with OBC 2012 Div.B 9.32.3.6(3) & 9.32.3.4(7).


10. Supply air grill at finished basement shall be at low level. Return air grill for finished or unfinished basement shall be at low level. HRAI digest 2005, clause 7.7(3).



FIRST FLOOR PLAN '1'

FIRST FLOOR PLAN '2'

FIRST FLOOR PLAN '3'



SECOND FLOOR PLAN '1'

SECOND FLOOR PLAN '3'

SECOND FLOOR PLAN '2'

HEAT LOSS 65310 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			
MAKE	GOODMAN	3RD FLOOR			
MODEL	GMEC960804CNA	2ND FLOOR	12	6	4
INPUT	80 MBTU/H	1ST FLOOR	12	2	3
OUTPUT	76.8 MBTU/H	BASEMENT	5	1	0
COOLING	4.0 TONS	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			
FAN SPEED	1504 cfm @ 0.6" w.c.				

HVAC LEGEND	
	SUPPLY AIR GRILLE
	SUPPLY AIR GRILLE 6" BOOT
	LINEAR BAR or LINEAR SLOT GRILLE
	SUPPLY AIR BOOT ABOVE
	6" SUPPLY AIR BOOT ABOVE
	SUPPLY AIR STACK
	6" SUPPLY AIR STACK
	14X8 RETURN AIR GRILLE
	30X8 RETURN AIR GRILLE
	FLOOR RETURN AIR GRILLE
	RETURN STACK ABOVE
	RETURN AIR STACK
	REDUCER
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	FLEX DUCT
	EXHAUST FAN
	LINT TRAP by REVERSOMATIC
	DIRECT VENT
	LOW WALL
	HIGH WALL
	CEILING
	MOTORIZED ZONE DAMPER
	MOTORIZED DAMPER
	EXHAUST PIPE
	CONCENTRIC VENT KIT
	CONCENTRIC HRV or ERV VENT KIT
	SINGLE WALL BOX by REVERSOMATIC
	DOUBLE WALL BOX by REVERSOMATIC
	TRIPLE WALL BOX by REVERSOMATIC
	DRYER BOOSTER FAN

2	ISSUED FOR PERMIT	DEC. 12/3	0
1	Revision	Date	By

SB-12 PACKAGE

A1

Microsoft Office has reviewed and taken responsibility for the design work and are qualified under division C.2.2 of this building code.
Michael Offenberg BSc H 1988 HVAC Designer Ltd.

HVACDESIGNS LTD.
375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca

Client: GREENPARK HOMES
Project Name: TRINIGROUP RICHMOND HILL, ONTARIO
CAROL 12 - WOB
3214 SQFT
Copyright & Copy: © 2023 HVAC Designs Ltd.

Copyright & Copy: © 2023 HVAC Designs Ltd.			
Sheet Title	ALL FLOORS		HEATING LAYOUT
Drawn By	YV	Checked By	MO
Scale	3/16"=1'-0"		Sheet No.
Date	MAY 2023		1
LD #	101184		1

1

1