

SITE NAME: STAR TIME LTD
BUILDER: GREENPARK HOMES
TYPE: BRIDGEFORD 3
DATE: Jan-17
LO# 11733
GFA: 2215
WINTER NATURAL AIR CHANGE RATE 0.330
SUMMER NATURAL AIR CHANGE RATE 0.120
HEAT LOSS AT °F. 76
HEAT GAIN AT °F. 16
CSA-F280-12
SB-12 PACKAGE A1

ROOM USE	MBR	ENS	WIC	BED-2	BED-3	ENS-3	ENS-2
EXP. WALL	38	26	5	33	43	11	6
CLG. HT.	10	9	9	9	10	9	9
FACTORS							
GRS.WALL AREA	380	234	45	297	430	99	54
GLAZING	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN
NORTH	0	0	0	0	0	0	0
EAST	21.3	16.8	0	0	0	0	0
SOUTH	21.3	42.4	0	0	0	0	0
WEST	21.3	25.7	0	0	0	0	0
SKYLT.	21.3	42.4	0	18	393	0	11
DOORS	37.2	103.0	0	28	596	0	234
NET EXPOSED WALL	4.5	0.9	0	0	0	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.6	0.7	0	0	0	0	0
EXPOSED CLG	1.3	0.6	42	201	442	92	43
NO ATTIC EXPOSED CLG	2.7	1.4	0	27	201	205	192
EXPOSED FLOOR	0	0	0	201	258	102	40
BASEMENT/CRAWL HEAT LOSS	0	0	0	28	77	0	63
SLAB ON GRADE HEAT LOSS	0	0	0	38	40	0	31
SUBTOTAL HT LOSS	2718	1673	255	168	428	0	0
SUB TOTAL HT GAIN	2053	1240	69	2862	2734	647	489
LEVEL FACTOR / MULTIPLIER	0.20	0.24	0.20	0.20	0.20	0.20	0.20
AIR CHANGE HEAT LOSS	646	398	61	681	650	154	116
AIR CHANGE HEAT GAIN	254	153	8	265	202	24	44
DUCT LOSS	0	0	0	354	0	0	0
DUCT GAIN	0	0	0	321	0	0	0
HEAT GAIN PEOPLE	2	0	0	1	240	0	0
HEAT GAIN APPLIANCES/LIGHTS	567	0	0	567	567	567	567
TOTAL HT LOSS BTU/H	3365	2071	315	3897	3384	801	605
TOTAL HT GAIN x 1.3 BTU/H	4359	1812	100	4590	3433	1020	1254

SITE NAME: STAR TIME LTD
BUILDER: GREENPARK HOMES

TYPE: BRIDGEFORD 3
DATE: Jan-17

GFA: 2215 LO# 71733

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 43,011
AIR FLOW RATE CFM 26.3

furnace pressure 0.6
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#AMANA
AMEC960603BNA 60
FAN SPEED LOW
MEDLOW
MEDIUM
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600
DESIGN CFM = 1131
CFM @ .6" E.S.P.

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	7	4
R/A	0	0	4	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5'Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	12	14	15	16	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	WIC	ENS-2	BED-2	BED-2	ENS-3	BED-3	BED-3	MBR	LVDN	KT/FM	KT/FM	KT/FM	LAUN	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.68	2.07	0.32	0.61	1.95	1.95	0.80	1.69	1.69	1.68	2.31	2.01	2.01	2.01	2.22	0.38	2.87	3.69	3.69	3.69	3.69
CFM PER RUN HEAT	44	54	8	16	51	51	21	45	45	44	61	53	53	53	58	10	76	97	97	97	97
RM GAIN MBH	2.18	1.81	0.10	1.25	2.30	2.30	1.02	1.72	1.72	2.18	3.10	1.37	1.37	1.37	1.52	0.82	1.52	0.28	0.28	0.28	0.28
CFM PER RUN COOLING	86	71	4	49	90	90	40	67	67	86	122	54	54	54	60	32	60	11	11	11	11
ADJUSTED PRESSURE	0.16	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.16	0.15	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
EQUIVALENT LENGTH	62	47	47	40	36	46	34	38	35	56	17	55	44	52	20	27	28	48	44	31	19
TOTAL EFFECTIVE LENGTH	160	200	150	150	160	170	190	150	130	130	130	180	150	150	190	180	120	150	160	140	160
ADJUSTED PRESSURE	0.07	0.07	0.09	0.09	0.08	0.08	0.08	0.09	0.09	0.09	0.1	0.09	0.09	0.09	0.08	0.08	0.12	0.08	0.08	0.09	0.09
ROUND DUCT SIZE	6	5	4	4	6	6	4	5	5	5	6	5	5	5	5	4	5	6	6	6	6
HEATING VELOCITY (f/min)	224	396	92	184	260	260	241	330	330	323	311	389	389	389	426	115	558	495	495	495	495
COOLING VELOCITY (f/min)	438	521	46	562	459	459	459	492	492	631	622	396	396	396	441	367	441	56	56	56	56
OUTLET GRILL SIZE	4X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	A	B	B	C	C	B	C	C	A	C	A	A	A	B	B	C	A	A	B	C

RUN #	ROOM NAME	RM LOSS MBH	CFM PER RUN HEAT	RM GAIN MBH	CFM PER RUN COOLING	ADJUSTED PRESSURE	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (f/min)	COOLING VELOCITY (f/min)	OUTLET GRILL SIZE	TRUNK
1	TRUNK A	495	0.07	11.1	14	18	8	8	8	8	8	8	8	8
2	TRUNK B	705	0.07	12.7	18	22	8	8	8	8	8	8	8	8
3	TRUNK C	426	0.08	10.2	12	16	8	8	8	8	8	8	8	8
4	TRUNK D	0	0.00	0	0	0	8	8	8	8	8	8	8	8
5	TRUNK E	0	0.00	0	0	0	8	8	8	8	8	8	8	8
6	TRUNK F	0	0.00	0	0	0	8	8	8	8	8	8	8	8

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)		
TRUNK A	495	0.07	11.1	14	8	636	TRUNK G	0	0.00	0	0	8	TRUNK O	0	0.05	0	0	8	
TRUNK B	705	0.07	12.7	18	8	705	TRUNK H	0	0.00	0	0	8	TRUNK P	0	0.05	0	0	8	
TRUNK C	426	0.08	10.2	12	8	639	TRUNK I	0	0.00	0	0	8	TRUNK Q	0	0.05	0	0	8	
TRUNK D	0	0.00	0	0	8	0	TRUNK J	0	0.00	0	0	8	TRUNK R	0	0.05	0	0	8	
TRUNK E	0	0.00	0	0	8	0	TRUNK K	0	0.00	0	0	8	TRUNK S	0	0.05	0	0	8	
TRUNK F	0	0.00	0	0	8	0	TRUNK L	0	0.00	0	0	8	TRUNK T	0	0.05	0	0	8	
RETURN AIR #	1	2	3	4	5	6							TRUNK U	0	0.05	0	0	8	
AIR VOLUME	115	120	120	120	310	160	0	0	0	0	0	0	TRUNK V	0	0.05	0	0	8	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0	0	0	0	0	0	TRUNK W	0	0.05	0	0	8	
ACTUAL DUCT LGH.	66	42	47	49	36	12	0	0	0	0	0	0	TRUNK X	1131	0.05	16.5	32	8	636
EQUIVALENT LENGTH	225	185	185	175	230	135	0	0	0	0	0	0	TRUNK Y	545	0.05	12.6	18	8	545
TOTAL EFFECTIVE LH	291	227	232	224	266	147	1	1	1	1	1	1	TRUNK Z	0	0.05	0	0	8	0
ADJUSTED PRESSURE	0.05	0.07	0.06	0.07	0.06	0.10	14.80	14.80	14.80	14.80	14.80	14.80	DROP	1131	0.05	16.5	24	10	679
ROUND DUCT SIZE	7	6.6	6.8	6.6	9.7	6.7	0	0	0	0	0	0							
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0							
INLET GRILL SIZE	14	14	14	14	30	14	0	0	0	0	0	0							

TYPE: BRIDGEFORD 3
SITE NAME: STAR TIME LTD

LO # 71733
OPT 2ND

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>2</u> @ 10.6 cfm	<u>21.2</u> cfm
Kitchen & Bathrooms	<u>5</u> @ 10.6 cfm	<u>53</u> cfm
Other Rooms	<u>5</u> @ 10.6 cfm	<u>53.0</u> cfm
Table 9.32.3.A.	TOTAL	<u>169.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
More than 5 - Part 6	TOTAL	<u>63.6</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>169.6</u>	cfm
Less Principal Ventil. Capacity	<u>139</u>	cfm
Required Supplemental Capacity	<u>30.6</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE 60H-V+ Location: BSMT
<u>139.0</u> cfm	<u>3.0</u> sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
139.0 CFM	X 76 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		NUTONE	
Location	Model	cfm	HVI
ENS	QTXEN050C	50	☒
ENS-3	QTXEN050C	50	☒
ENS-2	QTXEN050C	50	☒
W/R	QTXEN050C	50	☒

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE 60H-V+	
<u>139</u> cfm high	<u>50</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	January-17

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL:	BRIDGEFORD 3	OPT 2ND	BUILDER:	GREENPARK HOMES
SFQT:	2215	LO#	71733	SITE: STAR TIME LTD

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-4	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	72

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	WEST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	30165.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	4
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 55.0 ft	WIDTH: 24.0 ft	EXPOSED PERIMETER:	158.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.8
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	11.13
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669


MICHAEL O'ROURKE



CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																							
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																							
LO#: 71733	Model: BRIDGEFORD 3	Builder: GREENPARK HOMES	Date: 1/12/2017																																																				
Volume Calculation		Air Change & Delta T Data																																																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> <tr> <td>Bsmt</td> <td>1023</td> <td>9</td> <td>9207</td> </tr> <tr> <td>First</td> <td>1023</td> <td>10</td> <td>10230</td> </tr> <tr> <td>Second</td> <td>1192</td> <td>9</td> <td>10728</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>30,165.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>854.2 m³</td> </tr> </table>		Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1023	9	9207	First	1023	10	10230	Second	1192	9	10728	Third	0	9	0	Fourth	0	9	0	Total:			30,165.0 ft³	Total:			854.2 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="4">Design Temperature Difference</th> </tr> <tr> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>22</td> <td>-20</td> <td>42</td> <td>76</td> </tr> <tr> <td>22</td> <td>31</td> <td>9</td> <td>16</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>WINTER NATURAL AIR CHANGE RATE</td> <td>0.330</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.120</td> </tr> </table>		Design Temperature Difference				Tin °C	Tout °C	ΔT °C	ΔT °F	22	-20	42	76	22	31	9	16	WINTER NATURAL AIR CHANGE RATE	0.330	SUMMER NATURAL AIR CHANGE RATE	0.120
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																				
Bsmt	1023	9	9207																																																				
First	1023	10	10230																																																				
Second	1192	9	10728																																																				
Third	0	9	0																																																				
Fourth	0	9	0																																																				
Total:			30,165.0 ft³																																																				
Total:			854.2 m³																																																				
Design Temperature Difference																																																							
Tin °C	Tout °C	ΔT °C	ΔT °F																																																				
22	-20	42	76																																																				
22	31	9	16																																																				
WINTER NATURAL AIR CHANGE RATE	0.330																																																						
SUMMER NATURAL AIR CHANGE RATE	0.120																																																						
6.2.6 Sensible Gain due to Air Leakage																																																							
$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.120 x 237.27 x 9 °C x 1.2 = 301 W = 1026 Btu/h																																																							
6.2.7 Sensible heatGain due to Ventilation																																																							
$HL_{vaibrb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 139 CFM x 16 °F x 1.08 x 0.25 = 593 Btu/h																																																							
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																							
$HL_{airr} = Level Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HL_{clevel})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center; vertical-align: middle;">13,530</td> <td>8,008</td> <td>0.845</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>9,740</td> <td>0.417</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>11,379</td> <td>0.238</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0				Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})	1	0.5	13,530	8,008	0.845	2	0.3	9,740	0.417	3	0.2	11,379	0.238	4	0	0	0.000	5	0	0	0.000																										
Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})																																																			
1	0.5	13,530	8,008	0.845																																																			
2	0.3		9,740	0.417																																																			
3	0.2		11,379	0.238																																																			
4	0		0	0.000																																																			
5	0		0	0.000																																																			

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.8	 Insulation Configuration
Floor Width (m):	7.3	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.8	
Window Area (m ²):	1.4	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1509

TYPE: BRIDGEFORD 3
LO# 71733

OPT 2ND


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Vaughan (Woodbridge)			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.71			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	854.2			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1138.6 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	65.6	65.6		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.330			
Cooling Air Leakage Rate (ACH/H):	0.120			

TYPE: BRIDGEFORD 3
LO# 71733

OPT 2ND



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		



ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services		HEAT LOSS 45863 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS		Sheet Title	
GREENPARK HOMES				MAKE AMANA		3RD FLOOR		BASEMENT HEATING LAYOUT	
Project Name		Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.		MODEL AMEC960603BNA-60		2ND FLOOR 10 4 3		Date JAN/2017	
STARTIME HOME LTD VAUGHAN, ONTARIO				INPUT 60 MBTU/H		1ST FLOOR 7 2 2		Scale 3/16" = 1'-0"	
OPT 2ND BRIDGEFORD 3 2215 sqft				OUTPUT 57.6 MBTU/H		BASEMENT 4 1 0		BCIN# 19669	
				COOLING 2.5 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A		LO# 71733	
				FAN SPEED 1131 cfm @ 0.6" w.c.					

GROUND FLOOR PLAN 3



GROUND FLOOR PLAN 2



GROUND FLOOR PLAN 1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12
PACKAGE A1


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title FIRST FLOOR HEATING LAYOUT	
Project Name STARTIME HOME LTD VAUGHAN, ONTARIO			Date JAN/2017	
OPT 2ND BRIDGEFORD 3 2215 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
		LO#	71733	

SECOND FLOOR PLAN 3

SECOND FLOOR PLAN 2



SECOND FLOOR PLAN 1
3 BEDROOM OPTION

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12
PACKAGE A1

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title SECOND FLOOR HEATING LAYOUT	
Project Name STARTIME HOME LTD VAUGHAN, ONTARIO			Date JAN/2017	
OPT 2ND BRIDGEFORD 3 2215 sqft			Scale 3/16" = 1'-0"	
			BCIN# 19669	
			LO#	71733