



HANGER LEGEND:

DESIGN CRITERIA:

TC LL= 37.1 psf TC DL= 3 psf
BC LL= 0 psf BC DL= 7 psf
DEFLECTION: LL= L/360 TL= L/360
SPACING: 24" O/C UNLESS NOTED OTHERWISE
BLDG: RESIDENTIAL PART 9
CODE: OBC 2012 & TPIC 2011

IMPORTANT NOTES:

- SEE REVERSE FOR CONNECTOR CHART.
- REFER TO RESPECTIVE TRUSS DRAWINGS IN THE TRUSS ENGINEERING PACKAGE FOR PLY TO PLY ATTACHMENT NOTES.
- FOR SITE FRAMED VALLEYS: TOP CHORDS OF ALL ROOF TRUSSES MUST BE LATERALLY SUPPORTED USING 2X4 CONTINUOUS BRACING @ 24" O/C. ALL BRACING MUST BE ANCHORED AT ENDS AS PER TPIC INSTALLATION GUIDELINES.
- READ ALL NOTES ON THIS PAGE IN ADDITION TO THOSE SHOWN ON THE KOTT TRUSS ENGINEERING PACKAGE.
- FIELD ERECTION, HANDLING, SAFETY PRECAUTIONS AND BRACING OF ROOF TRUSSES ARE NOT THE RESPONSIBILITY OF THE TRUSS MANUFACTURER OR THE UNDERSIGNED ENGINEER; AND THEREFORE PROFESSIONAL ADVICE SHOULD BE SOUGHT RELATIVE TO ERECTION, HANDLING AND BRACING.
- UNLESS NOTED OTHERWISE, HURRICANE TIES ARE TO BE INSTALLED AT THE BEARINGS OF ALL COMMERCIAL TRUSSES, WHICH INCLUDES: TRUSSES EXCEEDING 40FT CLEAR SPAN, AND ANY GIRDER OR BEAM SUPPORTING TRUSSES WITH A CLEAR SPAN EXCEEDING 40FT. TYPE OF HURRICANE TIE WILL BE NOTED IN THE HANGER LEGEND.
- UNLESS NOTED OTHERWISE, FOR PART 9 BUILDINGS, ALL TRUSSES ARE TO BE ANCHORED TO THE TOP OF SUPPORTING WALLS AS FOLLOWS: TRUSSES WITH A CLEAR SPAN LESS THAN 40FT USE THREE 3-1/4" NAILS AT EACH BEARING. FOR TRUSSES EXCEEDING 40FT CLEAR SPAN, USE THREE 3-1/4" NAILS AT EACH BEARING, IN ADDITION TO THE APPROPRIATE HURRICANE TIE.

CUSTOMER:

PHOENIX HOMES

MODEL:

B2-A NODUS

ADDRESS:

LOT 77 WHITE TAIL RIDGE

FILE PATH:

S:\DESIGN\2015\PHOENIX\B2-A NODUS (77 WTR)\106382\QUOTE\TRUSSES*

JOB #:

SALESPERSON: Dany Wester

DESIGNED BY:

DATE: 19-Aug-2015

