



UNITED ENGINEERING INC
Mechanical and Electrical Consulting Engineers

3645 Keele St. #105
Toronto, ON, M3J 1M6
Email: info@u-eng.ca
T: (416) 398-1999
F: (416) 398-1933

SITE INSTRUCTION

PROJECT: HAMPTON MANOR
25 BAKER HILL BLVD
STOUFFVILLE, ONTARIO

PROJECT NO: 14-016

CONTRACT: Electrical

DATE August 11, 2017

SITE INSTRUCTION: E-3

THIS SITE INSTRUCTION IS NOT TO BE CONSTRUED AS A CHANGE IN THE CONTRACT PRICE, BUT IS ISSUED FOR CLARIFICATION ONLY. IF A CHANGE IN CONTRACT PRICE IS PERCEIVED, PROVIDE AN ITEMIZED BREAKDOWN OF ANY EXTRAS OR CREDITS WITHIN SEVEN (7) WORKING DAYS.

Purpose: To coordinate with architectural, interior designer, mechanical changes and client requested revisions.

1.0 Reference Drawing E-1 (Site Plan) Issued

1.1 Relocate: Main incoming communication lines to site conditions

2.0 Reference Drawing E-3A & E-3B (Ground Floor) Issued

- 2.1 Relocate: Four (4) wall mounted receptacles; (1) wall mounted TV outlet; two (2) floor mounted receptacles and two (2) floor mounted data outlets in the Amenity areas.
- 2.2 Delete: One (1) floor mounted receptacle and one (1) floor mounted data outlet in the Amenity area.
- 2.3 Add: One (1) wall mounted TV outlet in the Amenity area.
- 2.4 Revise: Lighting layout in Lobby and Amenity areas to suit interior designers' drawings

3.0 Reference Drawings E-3A & E-3B (Ground Floor) Issued E-4A & E-4B (2nd Floor) Issued E-5A & E-5B (3rd-5th Floor) Issued E-6A & E-6B (6th Floor) Issued E-7A & E-7B (7th Floor) Issued

**Project #14-016
Hampton Manor**

- 3.1 Relocate: Lighting fixtures to suit architectural buckhead in suites
- 3.2 Revise: Dimensions of lighting fixtures in suites as per client request.
- 3.3 Add: Lighting fixture type P1 in laundry and in master bathroom.
- 3.4 Relocate: GFI receptacle outlet to be centered between 2 sinks in master bathroom.
- 3.5 Relocate: Telephone/TV distribution, power and security panels in suite to suit revised architectural background.
- 3.6 Relocate: Lighting fixtures, TV, multiport and phone outlets and receptacles to suit client revisions to Flanders and Glen Cove suites.
- 3.7 Revise: Lighting layout in corridor to suit revised interior designers' drawings.

4.0 Reference Drawing E-8 (MPH) Issued

- 4.1 Relocate: Elevator machine splitter SPE62, conduit location, CO, smoke detectors, lighting fixtures, power outlet, power connections for exhaust fan E-6 and split systems, blower and coil and condensing unit to suit revised location of the elevator machine room.


5.0 Reference Drawing E-9B (Details B) Issued

- 5.1 Revise: Interior designer's lighting fixtures schedule.

6.0 Reference Drawing E-12 (Panel) Issued

- 6.1 Revise: Panel schedules C, EC and M

Note: The site instruction & drawings will be uploaded to FTP SITE

PREPARED BY: 
Chula Meksavanh
Electrical Department

Project #14-016
Hampton Manor

ISSUED TO ROYAL PINE HOMES,
Frank Carogioiello, frank@royalpinehomes.com;
Kelly Watson, Kelly@royalpinehomes.com
FOR DISTRIBUTION TO ALL AFFECTED PARTIES.

cc. GRAZIANI + CORAZZA ARCH. INC.,
Gino Colangelo, GColangelo@gc-architects.com
DINEEN CONSTRUCTION CORP., Ric Wight, rwight@dineen.com