

PANEL IDENTIF:	B	SERVICE: 208Y/120V, 3ø, 4ø MAIN CCT. BRK: 225 AMPS MOUNTING: SURFACE					NOTES:
		LOCATION:					
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - LOCKERS (P1)		15A	1	2	15A		RECEPTABLES - LOBBY ELEVATORS
LIGHTING - LOCKERS (P1)		15A	3	4	15A		RECEPTABLES - STAR A (P1)
LIGHTING - MECH. RM. (P1)		15A	5	6	15A		RECEPTABLES - STAR B (P1)
LGT. - GARBAGE/REC/BUCK (P1)		15A	7	8	15A		RECEPTABLES - STAR C (P1)
REC - GARBAGE/REC/BUCK (P1)		15A	9	10	15A		RECEPTABLES - STAR D (P1)
TRISORT - GARBAGE (P1)		20A	11	12	15A		SPARE
RECEPT. - ELEVATOR LOBBY (P1)		15A	13	14	15A		RECEPT. - LOCKERS (P1)
SPARE		15A	15	16	15A		RECEPT. - LOCKERS (P1)
		15A	17	18	15A		RECEPTABLE - MAIN ELEC. (P3)
		15A	19	20	15A		RECEPTABLE - MECH. RM. #1 (P1)
		15A	21	22	15A		REC. - SUB-ELECT. 1/COMM. (P1)
		15A	23	24	15A		RECEPTABLE - SUB-ELECT. 2 (P1)
		15A	25	26	15A		SPARE
		15A	27	28	15A		SPARE
		15A	29	30	15A		SPACE
		15A	31	32			SPACE
		15A	33	34			
		15A	35	36			
		15A	37	38			
		15A	39	40			
		15A	41	42			


PANEL IDENTIF	EB	SERVICE:		208Y/120V, 3ø, 4W		NOTES	
		MAIN CCT. BRK:	MANS:	225 AMPS	SURFACE	*** LOCK ON BREAKER	LOCATION:
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - LOBBY ELEVATORS		15A	1	2	15A		EXIT SIGNS - (P1) ***
LIGHTING - STAIR A (P1)		15A	3	4	15A		EXIT SIGNS - (P1) ***
LIGHTING - STAIR B (P1)		15A	5	6	15A		LOWER STAIR PRESS FAN 'F-9' SA
LIGHTING - STAIR C (P1)		15A	7	8	15A		LOWER STAIR PRESS FAN 'F-9' SB
LIGHTING - STAIR D (P1)		15A	9	10	15A		LOWER STAIR PRESS FAN 'F-9' SC
SPARE		15A	11	12	15A		SPARE
LIGHTING - LOCKERS (P1)		15A	13	14	15A		
LIGHTING - LOCKERS (P1)		15A	15	16	15A		
LIGHTING - MAIN ELEC. (P1)		15A	17	18	15A		
LIGHTING - MECH. RM. (P1)		15A	19	20	15A		
LGT. - SUB-ELEC./COMM. (P1)		15A	21	22	15A		
LGT. - GARBAGE/REC/BUCK (P1)		15A	23	24	15A		
SPARE		15A	25	26	15A		
		15A	27	28			
		15A	29	30			
		15A	31	32			SPACE
		15A	33	34			
		15A	35	36			
		15A	37	38			
		15A	39	40			
		15A	41	42			

PANEL IDENTIF:	SUITE (TYPICAL)	SERVICE: MAIN CCT. BRK: 120/208V, 1ø, 3ø MANS: 125 AMPS MOUNTING: RECESSED	NOTES:				
		LOCATION:					
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LTC, RECEPT. & SMOKE ALARM	1000	15A	1	2	15A**	1000	KITCHEN GFI SPLIT RECEPTACLE **
LIGHTING & RECEPTABLES	1000	15A	3	4	2P		
LIGHTING & RECEPTABLES	1000	15A	5	6	15A	1000	SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A	7	8	2P		
LIGHTING & RECEPTABLES	1000	15A	9	10	50A	6000	RANGE (3 #0)
EXTERIOR REC. GFI AS REQUIRED	500	15A	11	12	2P		
GFI RECEPTACLE	1000	15A	13	14	15A	800	FRIDGE
FAN COIL UNIT *	1000	15A**	15	16	30A	3000	DRYER
FAN COIL UNIT **	**	1000	15A**	17	18	2P	
AUTO FLUSH TOILET *		15A	19	20	15A	1000	WASHER
SPARE		15A	21	22	15A	1000	DISHWASHER
SEPARATE RECEPTACLE **	500	15A	23	24	15A**		BATHRM. HEATER (TOP FLOOR)**
COMBO MICROWAVE HOOD/FAN **	15A**	25	26	15A**	1000	MICROWAVE	
DRYER EXHAUST FAN	15A	27	28	15A**	1000	SPLIT RECEPTACLE	
WINDOW A/C UNIT	**	1000	15A	29	30	2P	
SPARE		15A	31	32			SPACE
		15A	33	34			
		15A	35	36			
		15A	37	38			
		15A	39	40			
		15A	41	42			

PANEL IDENTIF:	SUITE (TYPICAL)	SERVICE: MAIN CCT. BRK: 120/208V, 1ø, 3ø MANS: 100 AMPS MOUNTING: RECESSED	NOTES:				
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION	
LTC, RECEPT. & SMOKE ALARM	1000	15A	1	2	15A**	1000	KITCHEN GFI SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A	3	4	2P		
LIGHTING & RECEPTABLES	1000	15A	5	6	15A	1000	SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A	7	8	2P		
LIGHTING & RECEPTABLES	1000	15A	9	10	50A	6000	RANGE (3 #)
EXTERIOR REC. GFI AS REQUIRED	500	15A	11	12	2P		
GFI RECEPTACLE	1000	15A	13	14	15A	800	FRIDGE
FAN COIL UNIT *	1000	15A**	15	16	30A	3000	DRYER
FAN COIL UNIT **	**	1000	15A**	17	18	2P	
AUTO FLUSH TOILET *		15A	19	20	15A	1000	WASHER
SPARE		15A	21	22	15A	1000	DISHWASHER
SEPARATE RECEPTACLE **	**	500	15A	23	24	15A**	BATHRM. HEATER (TOP FLOOR)**
COMBO MICROWAVE/HOOD/FAN **	15A**	25	26	15A**	1000	MICROWAVE	
DRYER EXHAUST FAN	15A	27	28	15A**	1000	SPLIT RECEPTACLE	
WINDOW A/C UNIT	**	1000	15A	29	30	2P	
SPARE		15A	31	32			
		15A	33	34			
		15A	35	36			
		15A	37	38			
		15A	39	40			
		15A	41	42			

NOTES:

- * CONFIRM ELEC REQUIREMENTS WITH UNITS SHOP DWGS (FOR EACH DIFFERENT SUITE/UNIT)
- ** WHERE APPLICABLE AND REQUIRED, REFER TO UNITS LAYOUTS, ELEC PROVIDE SPARES
- PANELS CAN'T TRIGGER-NOT OR BE USED TO TRIGGER
- PANELS SHALL BE SIZABLE FOR THE USE OF DOUBLE BREAKERS WHICH SHALL BE USED SHOULD THE ACTUAL PROPORTION OF REQUIRED WATTS/AMPS EXCEED CODE REQUIREMENTS
- PROVIDE FIRE STOPPING IN CONDUIT AT PANEL AND IN ELECTRICAL CLOSET IN ACCORDANCE TO CODE

PANEL IDENTIF:	C	SERVICE: MAIN CCT. BRK: 208Y/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE	NOTES:				
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
RECEPTABLES - AMENITY (1ST)		15A	1	2	15A	RECEPTABLES - STAR C (1ST)	
RECEPTABLES - AMENITY (1ST)		15A	3	4	15A	RECEPTABLES - CORRIDOR (1ST)	
RECEPTABLES - AMENITY (1ST)		15A	5	6	15A	RECEPTABLES - CORRIDOR (1ST)	
RECEPTABLES - AMENITY (1ST)		15A	7	8	15A	RECEPTABLES - ENTRANCE (1ST)	
TV RECEPTABLES-AMENITY (1ST)		15A	9	10	15A	RECEPTABLES - LOBBY (1ST)	
FIREPLACE - AMENITY (1ST)		15A	11	12	15A	RECEPTABLES - LOBBY (1ST)	
FLOOR REC. - AMENITY (1ST)		15A	13	14	15A	FIREPLACE REC. - LOBBY (1ST)	
FL EQUIP REC - AMENITY (1ST)		15A	15	16	15A	RECEPTABLE - CAF ROOM (1ST)	
SPARE		15A	17	18	15A	CONCREGE FL REC - (1ST)	
		15A	19	20	15A	CONCREGE FL REC - (1ST)	
EXT. BBQ REC - AMENITY (1ST)		15A	21	22	15A	REC. - M OFFICE/MAIL (1ST)	
EXT. BBQ REC - AMENITY (1ST)		15A	23	24	15A	RECEPTABLES - M OFFICE (1ST)	
EXTERIOR REC. - AMENITY (1ST)		15A	25	26	15A	GFI RECEPTABLES - WC (1ST)	
EXTERIOR REC. - AMENITY (1ST)		15A	27	28	15A	GFI RECEPTABLES - WC (1ST)	
EXTERIOR REC. - AMENITY (1ST)		15A	29	30	15A	SPARE	
GFI RECEPTABLE-DOG SPA (1ST)		15A	31	32	15A	FRIDGE - AMENITY (1ST)	
GFI RECEPTABLE-DOG SPA (1ST)		15A	33	34	15A	COUNTER REC - AMENITY (1ST)	
LIGHTING - LOBBY (1ST)		15A	35	36	15A		
LIGHTING - LOBBY (1ST)		15A	37	38	15A	COUNTER REC - AMENITY (1ST)	
LIGHTING - AMENITY (1ST)		15A	39	40	15A		
LIGHTING - AMENITY (1ST)		15A	41	42	15A	DISHWASHER - AMENITY (1ST)	
LIGHTING - AMENITY (1ST)		15A	43	44	15A	COOKTOP - AMENITY (1ST)	
SPARE		15A	45	46	15A	MICRO/HOOD FAN - AMENITY	
		15A	47	48	15A	STOVE - AMENITY (1ST)	
		15A	49	50	15A	DOOR HOLD OPEN DEVICE	
		15A	51	52	15A	DOOR HOLD OPEN DEVICE	
		15A	53	54	15A	DOOR HOLD OPEN DEVICE	
		15A	55	56	15A	SPARE	
		15A	57	58	15A		
SPACE		15A	59	60	15A		
		15A	61	62		SPACE	
		15A	63	64			
		15A	65	66			
		15A	67	68			
		15A	69	70			
		15A	71	72			

PANEL IDENTIF:	EC	SERVICE: MAIN CCT. BRK: 208Y/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE	NOTES: *** LOCK ON BREAKER LOCATION:				
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - STAIR C (1ST FL)	15A	1	1	2	15A	EXIT SIGNS - STAIR C (1ST) ***	
LIGHTING - DOG SPA (1ST FL)	15A	3	4	15A	EXIT SIGNS - LOBBY (1ST) ***		
LIGHTING - LOBBY (1ST FL)	15A	5	6	15A	EXIT SIGNS - AMENITY (1ST) ***		
LIGHTING - LOBBY (1ST FL)	15A	7	8	15A	SPARE		
LIGHTING - LOBBY (1ST FL)	15A	9	10	15A			
LIGHTING - AMENITY (1ST FL)	15A	11	12	15A			
LIGHTING - CORRIDOR (1ST FL)	15A	13	14	15A			
LIGHTING - CORRIDOR (1ST FL)	15A	15	16	15A			
LIGHTING - CORRIDOR (1ST FL)	15A	17	18	15A			
SPARE	15A	19	20	15A			
	15A	21	22	15A			
	15A	23	24	15A			
	15A	25	26	15A			
	15A	27	28	15A			
	15A	29	30	15A			
	15A	31	32		SPARE		
	15A	33	34				
	15A	35	36				
	15A	37	38				
	15A	39	40				
	15A	41	42				

PANEL IDENTIF: ECN		SERVICE: MAIN CCT. BRK: 208Y/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE			NOTES:		
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
CD CONTROL PANEL		15A	1	2	15A		DO NOT ENTER SIGN (P1)
ENTERPHONE CONTROL PANEL		15A	3	4	15A		AUTO DOOR OPENER ENTR.(1ST)
SECURITY RESEER CONTROL PANEL		15A	5	6	15A		AUTO DOOR OPENER (GND WC)
TEL./TV RECEPTABLES		15A	7	8	15A		SPARE
TEL./TV RECEPTABLES		15A	9	10	15A		
ENTERPHONE PANEL--MAIN ENTR.		15A	11	12	15A		
MASTER OPERATING SWITCH FOR F/A		15A	13	14	15A		
ELEVATOR SUMP PUMP P-10 (P1)		15A	15	16	15A		
SPARE		15A	17	18	15A		
		15A	19	20	15A		
		15A	21	22	15A		
		15A	23	24	15A		
SPACE		25	26				SPACE
		27	28				
		29	30				
		31	32				
		33	34				
		35	36				
		37	38				
		39	40				
		41	42				

PANEL IDENTIF:	D	SERVICE: MAIN CCT. BRK: 208Y/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE	NOTES:					
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOCATION:	LOAD DESCRIPTION
STAIR A RECEPTABLES (2ND-7TH)		15A	1	2	15A			CORRIDOR RECEPT. (2ND-7TH)
STAIR B RECEPTABLES (2ND-7TH)		15A	3	4	15A			CORRIDOR RECEPT. (2ND-7TH)
SPARE		15A	5	6	15A			CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)		15A	7	8	15A			CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)		15A	9	10	15A			CORRIDOR RECEPT. (2ND-7TH)
DISHWASHER - GUESS RM (1ST)		15A	11	12	15A			CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)		15A	13	14	15A			CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)		15A	15	16	15A			CORRIDOR RECEPT. (2ND-7TH)
WC GFI REC. - GUESS RM (1ST)		15A	17	18	15A			CORRIDOR RECEPT. (2ND-7TH)
WC EX FAN - GUESS RM (1ST)		15A	19	20	15A			CORRIDOR RECEPT. (2ND-7TH)
FAN COIL - GUESS RM (1ST)		15A	21	22	15A			CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)		15A	23	24	15A			CORRIDOR RECEPT. (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT		15A	25	26	15A			LIGHTING - LOCKER (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)		15A	27	28	15A			LIGHTING - LOCKER (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT		15A	29	30	15A			SPARE
SPACE		31	32	32	15A			
		33	34	34	15A			
		35	36	36	15A			
		37	38	38	15A			
		39	40	40	15A			
		41	42	42	15A			

PANEL IDENTIF:	ED	SERVICE: MAIN CCT. BRK: 208Y/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE	NOTES:		
		LOCATION:			
LOAD DESCRIPTION					
WATTS	BRK	CIRCUITS	BRK WATTS	LOAD DESCRIPTION	
LIGHTING - STAIR A (1ST-3RD)	15A	1	2	15A	EXIT SIGNS STAIR A (1ST-7TH) ***
LIGHTING - STAIR A (4TH-PH)	15A	3	4	15A	EXIT SIGNS STAIR B (1ST-7TH) ***
LIGHTING - STAIR B (1ST-3RD)	15A	5	6	15A	EXIT SIGNS CORRIDOR (1ST-7TH) ***
LIGHTING - STAIR B (4TH-PH)	15A	7	8	15A	EXIT SIGNS CORRIDOR (1ST-7TH) ***
LIGHTING - GARBAGE CHUTE	15A	9	10	15A	LIGHTING - CORRIDOR (2ND-3RD)
SPARE	15A	11	12	15A	LIGHTING - CORRIDOR (2ND-3RD)
LIGHTING - GUESS RM. (1ST)	15A	13	14	15A	LIGHTING - CORRIDOR (4TH-5TH)
LIGHTING - LOCKER (2ND-7TH)	15A	15	16	15A	LIGHTING - CORRIDOR (4TH-5TH)
LIGHTING - LOCKER (2ND-7TH)	15A	17	18	15A	LIGHTING - CORRIDOR (6TH-7TH)
SPARE	15A	19	20	15A	LIGHTING - CORRIDOR (6TH-7TH)
	15A	21	22	15A	LIGHTING - CORRIDOR (6TH-7TH)
	15A	23	24	15A	LIGHTING - CORRIDOR (6TH-7TH)
	15A	25	26	15A	LIGHTING - CORRIDOR (6TH-7TH)
	15A	27	28	15A	LIGHTING - CORRIDOR (6TH-7TH)
	15A	29	30	15A	SPACE
	15A	31	32	15A	
	15A	33	34	15A	
	15A	35	36	15A	
	15A	37	38	15A	
	15A	39	40	15A	
	15A	41	42	15A	