

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
LIGHTING - LOCKERS (P1)	15A	1	2	15A	RECEPTABLES - LOBBY ELEVATORS
LIGHTING - LOCKERS (P1)	15A	3	4	15A	RECEPTABLES - STAR A (P1)
LIGHTING - MECH. RM. (P1)	15A	5	6	15A	RECEPTABLES - STAR B (P1)
LGT. - GARBAGE/REC/BUCK (P1)	15A	7	8	15A	RECEPTABLES - STAR C (P1)
REC - GARBAGE/REC/BUCK (P1)	15A	9	10	15A	RECEPTABLES - STAR D (P1)
TRISORT - GARBAGE (P1)	20A	11	12	15A	SPARE
RECEPT. - ELEVATOR LOBBY (P1)	15A	13	14	15A	RECEPT. - LOCKERS (P1)
SPARE	15A	15	16	15A	RECEPT. - LOCKERS (P1)
	15A	17	18	15A	RECEPTABLE - MAIN ELEC. (P1)
	15A	19	20	15A	RECEPTABLE - MECH. RM. #1 (P1)
	15A	21	22	15A	REC. - SUB-ELEC. 1/COMM. (P1)
	15A	23	24	15A	RECEPTABLE - SUB-ELEC. 2 (P1)
	15A	25	26	15A	SPARE
	15A	27	28	15A	SPARE
	15A	29	30	15A	SPACE
	15A	31	32		SPACE
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOC ON BREAKER
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
LIGHTING - LOBBY ELEVATORS	15A	1	2	15A	EXIT SIGNS - (P1) ***
LIGHTING - STAIR A (P1)	15A	3	4	15A	EXIT SIGNS - (P1) ***
LIGHTING - STAIR B (P1)	15A	5	6	15A	LOWER STAIR PRESS FAN "Y-9" SA
LIGHTING - STAIR C (P1)	15A	7	8	15A	LOWER STAIR PRESS FAN "Y-9" SB
LIGHTING - STAIR D (P1)	15A	9	10	15A	LOWER STAIR PRESS FAN "Y-9" SC
SPARE	15A	11	12	15A	SPARE
LIGHTING - LOCKERS (P1)	15A	13	14	15A	
LIGHTING - LOCKERS (P1)	15A	15	16	15A	
LIGHTING - MAIN ELEC. (P1)	15A	17	18	15A	
LIGHTING - MECH. RM. (P1)	15A	19	20	15A	
LGT. - SUB-ELEC./COMM. (P1)	15A	21	22	15A	
LGT. - GARBAGE/REC/BUCK (P1)	15A	23	24	15A	
SPARE	15A	25	26	15A	
	15A	27	28		
	15A	29	30		
	15A	31	32		SPACE
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

PANEL IDENTIF:	SERVICE: 120/208V, 1ø, 3ø				NOTES:
	MAIN CTT. BRK:	MANNS:	125 AMPS RECESS		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
LTC, RECEPT. & SMOKE ALARM	1000	15A	1	2	15A** 1000
LIGHTING & RECEPTABLES	1000	15A	3	4	2P
LIGHTING & RECEPTABLES	1000	15A	5	6	15A 1000
LIGHTING & RECEPTABLES	1000	15A	7	8	2P
LIGHTING & RECEPTABLES	1000	15A	9	10	50A 6000
EXTERIOR REC. QTY AS REQUIRED	500	15A	11	12	2P
QTY RECEPTABLE	1000	15A	13	14	15A 800
FAN COIL UNIT **	1000	15A** 15	16	30A	3000 DRYER
FAN COIL UNIT **	1000	15A** 17	18	2P	
AUTO FLUSH TOILET *	15A	19	20	15A	1000 WASHER
SPARE	15A	21	22	15A	1000 DISHWASHER
SEPARATE RECEPTABLE **	500	15A	23	24	15A** BATHRM. HEATER (TOP FLOOR)**
COMBO MICROWAVE HOOD/FAN **	15A	25	26	15A** 1000	MICROWAVE
DRYER EXHAUST FAN	15A	27	28	15A** 1000	SPLIT RECEPTABLE
WINDOW A/C UNIT **	1000	15A	29	30	2P
SPARE	15A	31	32		SPACE
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

NOTES:

- \* CONFIRM ELEC. REQUIREMENTS WITH UNITS SHOP DWGS (FOR EACH DIFFERENT SUITE/UNIT)
- \*\* WHERE APPLICABLE AND REQUIRED, REFER TO UNITS LAYOUTS. ELSE, PROVIDE SPARES
- PANELS C/W "PLUG-IN" OR BOLT-ON BREAKERS
- PANELS SHALL BE SATISFIED FOR THE USE OF DOUBLE BREAKERS WHICH SHALL BE USED SHOULD THE ACTUAL PROPORTION OF REQUIRED CIRCUITS/EMPTY SPACE EXCEED CODE REQUIREMENTS
- PROVIDE FIRE STOPPING IN CONDUIT AT PANEL AND IN ELECTRICAL CLOSET IN ACCORDANCE TO CODE

PANEL IDENTIF:	SERVICE: 120/208V, 1ø, 3ø				NOTES:
	MAIN CTT. BRK:	MANNS:	100 AMPS RECESS		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
LTC, RECEPT. & SMOKE ALARM	1000	15A	1	2	15A** 1000
LIGHTING & RECEPTABLES	1000	15A	3	4	2P
LIGHTING & RECEPTABLES	1000	15A	5	6	15A 1000
LIGHTING & RECEPTABLES	1000	15A	7	8	2P
LIGHTING & RECEPTABLES	1000	15A	9	10	50A 6000
EXTERIOR REC. QTY AS REQUIRED	500	15A	11	12	2P
QTY RECEPTABLE	1000	15A	13	14	15A 800
FAN COIL UNIT **	1000	15A** 15	16	30A	3000 DRYER
FAN COIL UNIT **	1000	15A** 17	18	2P	
AUTO FLUSH TOILET *	15A	19	20	15A	1000 WASHER
SPARE	15A	21	22	15A	1000 DISHWASHER
SEPARATE RECEPTABLE **	500	15A	23	24	15A** BATHRM. HEATER (TOP FLOOR)**
COMBO MICROWAVE HOOD/FAN **	15A	25	26	15A** 1000	MICROWAVE
DRYER EXHAUST FAN	15A	27	28	15A** 1000	SPLIT RECEPTABLE
WINDOW A/C UNIT **	1000	15A	29	30	2P
SPARE	15A	31	32		SPACE
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

NOTES:

- \* CONFIRM ELEC. REQUIREMENTS WITH UNITS SHOP DWGS (FOR EACH DIFFERENT SUITE/UNIT)
- \*\* WHERE APPLICABLE AND REQUIRED, REFER TO UNITS LAYOUTS. ELSE, PROVIDE SPARES
- PANELS C/W "PLUG-IN" OR BOLT-ON BREAKERS
- PANELS SHALL BE SATISFIED FOR THE USE OF DOUBLE BREAKERS WHICH SHALL BE USED SHOULD THE ACTUAL PROPORTION OF REQUIRED CIRCUITS/EMPTY SPACE EXCEED CODE REQUIREMENTS
- PROVIDE FIRE STOPPING IN CONDUIT AT PANEL AND IN ELECTRICAL CLOSET IN ACCORDANCE TO CODE

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
RECEPTABLES - AMENITY (1ST)	15A	1	2	15A	RECEPTABLES - STAR C (1ST)
RECEPTABLES - AMENITY (1ST)	15A	3	4	15A	RECEPTABLES - CORRIDOR (1ST)
RECEPTABLES - AMENITY (1ST)	15A	5	6	15A	RECEPTABLES - CORRIDOR (1ST)
RECEPTABLES - AMENITY (1ST)	15A	7	8	15A	RECEPTABLES - ENTRANCE (1ST)
TV RECEPTABLES-AMENITY (1ST)	15A	9	10	15A	RECEPTABLES - LOBBY (1ST)
FIREPLACE - AMENITY (1ST)	15A	11	12	15A	RECEPTABLES - LOBBY (1ST)
FLOOR REC. - AMENITY (1ST)	15A	13	14	15A	FIREPLACE REC. - LOBBY (1ST)
FL EQUIP REC - AMENITY (1ST)	15A	15	16	15A	RECEPTABLE - CADT ROOM (1ST)
FL EQUIP REC - AMENITY (1ST)	15A	17	18	15A	CONDENSE FL REC - (1ST)
SPARE	15A	19	20	15A	CONDENSE FL REC - (1ST)
ELECTRICAL RM - AMENITY (1ST)	15A	21	22	15A	REC. - M OFFICE/MAIL (1ST)
EXT. BBQ REC - AMENITY (1ST)	15A	23	24	15A	RECEPTABLES - M OFFICE (1ST)
EXT. BBQ REC - AMENITY (1ST)	15A	25	26	15A	GFI RECEPTABLES - WC (1ST)
EXTERIOR REC. - AMENITY (1ST)	15A	27	28	15A	GFI RECEPTABLES - WC (1ST)
EXTERIOR REC. - AMENITY (1ST)	15A	29	30	15A	SPARE
GFI RECEPTABLE-DOG SPA (1ST)	15A	31	32	15A	FRIDGE - AMENITY (1ST)
GFI RECEPTABLE-DOG SPA (1ST)	15A	33	34	15A	COUNTER REC - AMENITY (1ST)
LIGHTING - LOBBY (1ST)	15A	35	36	15A	
LIGHTING - LOBBY (1ST)	15A	37	38	15A	COUNTER REC - AMENITY (1ST)
LIGHTING - AMENITY (1ST)	15A	39	40	15A	
LIGHTING - AMENITY (1ST)	15A	41	42	15A	DISHWASHER - AMENITY (1ST)
LIGHTING - AMENITY (1ST)	15A	43	44	15A	COOKTOP - AMENITY (1ST)
SPARE	15A	45	46	15A	MICRO/HOOD FAN - AMENITY
	15A	47	48	15A	STOVE - AMENITY (1ST)
	15A	49	50	15A	DOOR HOLD OPEN DEVICE
	15A	51	52	15A	DOOR HOLD OPEN DEVICE
	15A	53	54	15A	DOOR HOLD OPEN DEVICE
	15A	55	56	15A	SPARE
	15A	57	58	15A	
	15A	59	60	15A	SPACE
	15A	61	62		SPACE
	15A	63	64		
	15A	65	66		
	15A	67	68		
	15A	69	70		
	15A	71	72		

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOC ON BREAKER
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
LIGHTING - STAIR C (1ST FL)	15A	1	2	15A	EXIT SIGNS - STAIR C (1ST) ***
LIGHTING - DOG SPA (1ST FL)	15A	3	4	15A	EXIT SIGNS - LOBBY (1ST) ***
LIGHTING - LOBBY (1ST FL)	15A	5	6	15A	EXIT SIGNS - AMENITY (1ST) ***
LIGHTING - LOBBY (1ST FL)	15A	7	8	15A	SPARE
LIGHTING - LOBBY (1ST FL)	15A	9	10	15A	
LIGHTING - AMENITY (1ST FL)	15A	11	12	15A	
LIGHTING - CORRIDOR (1ST FL)	15A	13	14	15A	
LIGHTING - CORRIDOR (1ST FL)	15A	15	16	15A	
LIGHTING - CORRIDOR (1ST FL)	15A	17	18	15A	
SPARE	15A	19	20	15A	
	15A	21	22	15A	
	15A	23	24	15A	
	15A	25	26	15A	
	15A	27	28	15A	
	15A	29	30		SPACE
	15A	31	32		
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
CD CONTROL PANEL	15A	1	2	15A	DO NOT ENTER* SIGN (P1)
ENTERPHONE CONTROL PANEL	15A	3	4	15A	AUTO DOOR OPENER ENTR.(1ST)
SECURITY REER CONTROL PANEL	15A	5	6	15A	AUTO DOOR OPENER (GND WCD)
TEL./TV RECEPTABLES	15A	7	8	15A	SPARE
TEL./TV RECEPTABLES	15A	9	10	15A	
ENTERPHONE PANEL-MAN ENTR.	15A	11	12	15A	
MASTER OPERATING SWITCH FOR F/A	15A	13	14	15A	
ELEVATOR SUMP PUMP P-10 (P1)	15A	15	16	15A	
SPARE	15A	17	18	15A	
	15A	19	20	15A	
	15A	21	22	15A	
	15A	23	24	15A	
	15A	25	26		SPACE
	15A	27	28		
	15A	29	30		
	15A	31	32		
	15A	33	34		
	15A	35	36		
	15A	37	38		
	15A	39	40		
	15A	41	42		

PANEL IDENTIF:	SERVICE: 208Y/120V, 3ø, 4W				NOTES:
	MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE		LOCATION:
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS
STAIR A RECEPTABLES (2ND-7TH)	15A	1	2	15A	CORRIDOR RECEPT. (2ND-7TH)
STAIR B RECEPTABLES (2ND-7TH)	15A	3	4	15A	CORRIDOR RECEPT. (2ND-7TH)
SPARE	15A	5	6	15A	CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)	15A	7	8	15A	CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)	15A	9	10	15A	CORRIDOR RECEPT. (2ND-7TH)
DISHWASHER - GUESS RM (1ST)	15A	11	12	15A	CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)	15A	13	14	15A	CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)	15A	15	16	15A	CORRIDOR RECEPT. (2ND-7TH)
WC EX. FAN - GUESS RM (1ST)	15A	17	18	15A	CORRIDOR RECEPT. (2ND-7TH)
WC EX. FAN - GUESS RM (1ST)	15A	19	20	15A	CORRIDOR RECEPT. (2ND-7TH)
FAN COIL - GUESS RM (1ST)	15A	21	22	15A	CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)	15A	23	24	15A	CORRIDOR RECEPT. (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT	15A	25	26	15A	LIGHTING - LOCKER (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)	15A	27	28	15A	LIGHTING - LOCKER (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT	15A	29	30	15A	SPARE
SPARE	15A	31	32	15A	
	15A	33	34	15A	
	15A	35	36	15A	
	15A	37	38	15A	
	15A	39	40	15A	
	15A	41	42	15A	

PANEL IDENTIF:	ED	SERVICE: 208Y/120V, 3ø, 4W			NOTES:		
		MAIN CTT. BRK:	MANNS:	225 AMPS SURFACE			
		MOUNTING:			LOCATION:		
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - STAIR A (1ST-3RD)		15A	1	2	15A		EXIT SIGNS STAIR A (1ST-7TH) ***
LIGHTING - STAIR A (4TH-6TH)		15A	3	4	15A		EXIT SIGNS STAIR B (1ST-7TH) ***
LIGHTING - STAIR B (1ST-3RD)		15A	5	6	15A		EXIT SIGNS CORRIDOR (1ST-7TH) ***
LIGHTING - STAIR B (4TH-6TH)		15A	7	8	15A		EXIT SIGNS CORRIDOR (1ST-7TH) ***
LIGHTING - GARBAGE CHUTE		15A	9	10	15A		EXIT SIGNS CORRIDOR (1ST-7TH) ***
SPARE		15A	11	12	15A		LIGHTING - CORRIDOR (2ND-3RD)
LIGHTING - GUESS RM. (1ST)		15A	13	14	15A		LIGHTING - CORRIDOR (2ND-3RD)
LIGHTING - LOCKER (2ND-7TH)		15A	15	16	15A		LIGHTING - CORRIDOR (2ND-3RD)
LIGHTING - LOCKER (2ND-7TH)		15A	17	18	15A		LIGHTING - CORRIDOR (4TH-5TH)
SPARE		15A	19	20	15A		LIGHTING - CORRIDOR (4TH-5TH)
		15A	21	22	15A		LIGHTING - CORRIDOR (5TH-5TH)
		15A	23	24	15A		LIGHTING - CORRIDOR (6TH-7TH)
		15A	25	26	15A		LIGHTING - CORRIDOR (6TH-7TH)
		15A	27	28	15A		LIGHTING - CORRIDOR (6TH-7TH)
		15A	29	30			SPACE
		15A	31	32			
		15A	33	34			
		15A	35	36			
		15A	37	38			
		15A	39	40			
		15A	41	42			