
SITE INSTRUCTION #6**Project Name: Hampton Manor (25 Baker Hill Boulevard) - Stouffville****Project Number: 20140490****Vince Staffieri****November 13, 2017****Royal Pine Homes****3550 Langstaff Road, Suite 200****Woodbridge, Ontario L4L 9G3****via email: vince@royalpinehomes.com**

Distribution: Owner []; Contractor []; Consultant A []; M []; E []; L []; Other

-
1. Site instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions.
 2. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract.
 3. Should the Contractor require a change in the contract price or project schedule, he shall submit an itemized proposal to the Architect within 14 calendar days of the date hereof.
 4. If the proposal is accepted by the Client, this site instruction will be superseded by a Change Order.
-

A. REFERENCE:

- .1 Drawings S5-01

B. INSTRUCTION:

- .1 At step along perimeter of transfer slab, a horizontal construction joint may be provided per alternate detail GF1A/S5-01. Add stirrups as indicated.

C. REASON:

- .1 Forming contractor's request.

Yours very truly,
STEPHENSON ENGINEERING LIMITED

per 

Mauricio Nieto, MAsC., P.Eng.
Senior Engineer, Project Manager
mnieto@stephenson-eng.com

per 

Sandra Cullen, P.Eng.
Principal
scullen@stephenson-eng.com

Distribution cc:

Jeffrey Ellis	jellis@dineen.com
Gino Colangelo	gcolangelo@gc-architects.com
Carmen Taranu	CTaranu@gc-architects.com
Shari Grant	SGrant@gc-architects.com
Hrvoje Vukic	hvukic@stephenson-eng.com

