


## Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

<b>A. Project Information</b>			
Building number, street name		Unit no.	Lot/con.
Municipality RICHMOND HILL	Postal code	Plan number/ other description	
<b>B. Individual who reviews and takes responsibility for design activities</b>			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ( )	
<b>C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]</b>			
<input type="checkbox"/> House <input type="checkbox"/> Small Buildings <input type="checkbox"/> Large Buildings <input type="checkbox"/> Complex Buildings <input checked="" type="checkbox"/> HVAC – House <input type="checkbox"/> Building Services <input type="checkbox"/> Detection, Lighting and Power <input type="checkbox"/> Fire Protection <input type="checkbox"/> Building Structural <input type="checkbox"/> Plumbing – House <input type="checkbox"/> Plumbing – All Buildings <input type="checkbox"/> On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 38-11 BELVEDERE  Project: CENTREFIELD (WEST GORMLEY)	
<b>D. Declaration of Designer</b>			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
<input type="checkbox"/> I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories.  Individual BCIN: _____ Firm BCIN: _____			
<input checked="" type="checkbox"/> I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code.  Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
<input type="checkbox"/> The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 19, 2021			
Date		Signature of Designer	

**NOTE:**

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

**Application for a Permit Construct or Demolish – Effective January 1, 2015**

SITE NAME: CENTREFIELD (WEST GORMLEY)										DATE: Apr-21					WINTER NATURAL AIR CHANGE RATE 0.227					HEAT LOSS ΔT °F. 78			CSA-F280-12															
BUILDER: ROYAL PINE HOMES										TYPE: 38-11					GFA: 2674					LO# 87614					SUMMER NATURAL AIR CHANGE RATE 0.071					HEAT GAIN ΔT °F. 13			SB-12 PERFORMANCE					
ROOM USE			MBR			ENS			WIC			BED-2			BED-3			BED-4			BATH						ENS-4											
EXP. WALL			41			22			6			18			35			31			7						8											
CLG. HT.			9			9			9			9			9			9			9						9											
FACTORS																																						
GRS.WALL AREA			LOSS			GAIN			369			198			54			162			315			279			63			72								
GLAZING									LOSS			GAIN			LOSS			GAIN			LOSS			GAIN			LOSS			GAIN			LOSS			GAIN		
NORTH			21.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
EAST			21.8	41.6	44	958	1828	22	479	914	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
SOUTH			21.8	24.9	0	0	0	0	0	0	0	0	0	0	18	392	448	0	0	0	0	0	0	0	0	7	152	174	0	0	0	0	0					
WEST			21.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	51	1111	2119	55	1198	2285	0	0	0	0	0	0	0	0	0	0					
SKYLT.			35.8	101.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
DOORS			25.8	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
NET EXPOSED WALL			4.2	0.7	325	1367	225	176	740	122	54	227	37	144	606	100	264	1110	183	224	942	155	56	236	39	72	303	50	0	0	0	0	0					
NET EXPOSED BSMT WALL ABOVE GR			3.7	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
EXPOSED CLG			1.3	0.6	355	467	209	125	164	73	70	92	41	232	305	136	162	213	95	198	260	116	85	112	50	75	99	44	0	0	0	0	0					
NO ATTIC EXPOSED CLG			2.8	1.3	0	0	0	0	0	0	0	0	0	0	0	0	40	112	50	40	112	50	0	0	0	0	0	0	0	0	0	0	0					
EXPOSED FLOOR			2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	40	104	17	238	621	102	0	0	0	75	196	32	0	0	0	0	0					
BASEMENT/CRAWL HEAT LOSS						0			0			0			0			0			0			0			0			0			0			0		
SLAB ON GRADE HEAT LOSS						0			0			0			0			0			0			0			0			0			0			0		
SUBTOTAL HT LOSS						2792			1384			319			1303			2651			3134			500			597											
SUB TOTAL HT GAIN						2262			1109			79			684			2464			2709			263			126											
LEVEL FACTOR / MULTIPLIER			0.20	0.18				0.20	0.18				0.20	0.18				0.20	0.18				0.20	0.18				0.20	0.18									
AIR CHANGE HEAT LOSS						507			251			58			237			481			569			91			108											
AIR CHANGE HEAT GAIN						114			56			4			34			124			136			13			6											
DUCT LOSS						0			0			0			154			313			370			59			71											
DUCT GAIN						0			0			0			175			362			387			28			13											
HEAT GAIN PEOPLE			240		2		480	0	0	0	0	1		240	1		240	1		240	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
HEAT GAIN APPLIANCES/LIGHTS						790			0			0			790			790			790			0			0											
TOTAL HT LOSS BTU/H						3299			1635			377			1693			3446			4074			650			776											
TOTAL HT GAIN x 1.3 BTU/H						4738			1515			107			2500			5173			5541			395			189											

ROOM USE					FAM		KT/BR		LV/DN		LAUN		PWD		FOY		MUD								BAS	
EXP. WALL					32		35		39		0		6		29		15								168	
CLG. HT.					10		10		10		9		10		11		11								10	
FACTORS																										
GRS.WALL AREA	LOSS	GAIN			323		354		394		0		61		322		167								1176	
GLAZING			LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN
NORTH	21.8	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST	21.8	41.6	22	479	914	63	1372	2618	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	196	374	
SOUTH	21.8	24.9	0	0	0	0	0	0	38	828	946	0	0	0	9	196	224	0	0	0	0	0	6	131	149	
WEST	21.8	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	18	392	748	0	0	0	0	0	0
SKYLT.	35.8	101.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	25.8	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	40	1034	170	20	517	85	20	517	85
NET EXPOSED WALL	4.2	0.7	301	1267	208	291	1222	201	356	1497	246	0	0	0	52	217	36	264	1110	183	147	616	101	0	0	0
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	504	1857	305	
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0	95	125	56	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS																										
SLAB ON GRADE HEAT LOSS																										5684
SUBTOTAL HT LOSS						1746		2594		2324		125		413		2536		1133							8384	
SUB TOTAL HT GAIN					1123			2819				56		260		1101		186								914
LEVEL FACTOR / MULTIPLIER	0.30	0.32				0.30	0.32		0.30	0.32		0.20	0.18	0.30	0.32	0.30	0.32	0.30	0.32				0.50	0.69		
AIR CHANGE HEAT LOSS					567		842			755		23		134		823		368						5814		
AIR CHANGE HEAT GAIN						56		142			60		3		13		55		9						46	
DUCT LOSS					0		0			0		0		0		0		0						0		
DUCT GAIN					0		0			0		0		0		0		0		0			0		0	
HEAT GAIN PEOPLE	240				0		0		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
HEAT GAIN APPLIANCES/LIGHTS						790		790			790		0		0		0		0				0		790	
TOTAL HT LOSS BTU/H						2313		3436		3079		148		547		3359		1501							14199	
TOTAL HT GAIN x 1.3 BTU/H						2559		4875		2654		76		355		1503		255								2274

TOTAL HEAT GAIN BTU/H:

34984

TONS: 2.92

LOSS DUE TO VENTILATION LOAD BTU/H: 1670

STRUCTURAL HEAT LOSS: 44531

TOTAL COMBINED HEAT LOSS BTU/H: 46201

SITE NAME: CENTREFIELD (WEST GORMLEY)  
BUILDER: ROYAL PINE HOMES

TYPE: 38-11

DATE: Apr-21

GFA: 2674

LO# 87614

HEATING CFM 1145 COOLING CFM 1145  
TOTAL HEAT LOSS 44,531 TOTAL HEAT GAIN 34,710  
AIR FLOW RATE CFM 25.71 AIR FLOW RATE CFM 32.99

furnace pressure 0.6  
furnace filter 0.05  
a/c coil pressure 0.2  
available pressure  
for s/a & r/a 0.35

**\*\*CARRIER**  
**59TN6A-060-14V**  
**FAN SPEED 60**

AFUE = 97 %  
INPUT (BTU/H) = 60,000  
OUTPUT (BTU/H) = **58,000**

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	7	4
R/A	0	0	5	2	1

plenium pressure s/a 0.18  
max s/a dif press. loss 0.02  
min adjusted pressure s/a 0.16  
r/a pressure 0.17  
r/a grille press. Loss 0.02  
adjusted pressure r/a 0.15

LOW 820  
MEDLOW 0  
MEDIUM 1145  
MEDIUM HIGH 0  
HIGH 1520

DESIGN CFM = **1145**  
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	BED-3	BED-4	MBR	ENS-4	FAM	KT/BR	KT/BR	LV/DN	LAUN	PWD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.65	1.63	0.38	1.69	1.72	2.04	0.65	1.72	2.04	1.65	0.78	2.31	1.72	1.72	3.08	0.15	0.55	3.36	1.50	3.55	3.55	3.55	3.55
CFM PER RUN HEAT	42	42	10	44	44	52	17	44	52	42	20	59	44	44	79	4	14	86	39	91	91	91	91
RM GAIN MBH.	2.37	1.51	0.11	2.50	2.59	2.77	0.40	2.59	2.77	2.37	0.19	2.56	2.44	2.44	2.65	0.08	0.35	1.50	0.25	0.57	0.57	0.57	0.57
CFM PER RUN COOLING	78	50	4	82	85	91	13	85	91	78	6	84	80	80	88	3	12	50	8	19	19	19	19
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.16	0.16	0.17	0.17	0.16	0.17	0.17	0.16	0.17	0.17	0.16	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	69	37	30	32	34	40	32	42	46	56	36	53	42	35	14	32	14	30	45	48	29	8	20
EQUIVALENT LENGTH	130	140	120	150	140	120	120	150	130	190	160	130	150	100	120	180	130	130	140	130	110	130	120
TOTAL EFFECTIVE LENGTH	199	177	150	182	174	160	152	192	176	246	196	183	192	135	134	212	144	160	185	178	139	138	140
ADJUSTED PRESSURE	0.09	0.1	0.11	0.09	0.09	0.1	0.11	0.08	0.09	0.07	0.09	0.09	0.09	0.13	0.12	0.08	0.12	0.1	0.09	0.09	0.12	0.12	0.12
ROUND DUCT SIZE	6	5	4	6	6	6	4	6	6	6	4	6	6	6	6	4	4	6	4	6	6	6	6
HEATING VELOCITY (ft/min)	214	308	115	224	224	265	195	224	265	214	229	301	224	224	403	46	161	438	447	464	464	464	464
COOLING VELOCITY (ft/min)	398	367	46	418	433	464	149	433	464	398	69	428	408	408	449	34	138	255	92	97	97	97	97
OUTLET GRILL SIZE	4X10	3X10	3X10	4X10	4X10	4X10	3X10	4X10	4X10	4X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	4X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	B	B	D	C	D	D	C	D	A	D	A	A	B	D	B	C	C	A	A	B	B	C

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.65	42	2.37	78	0.17	69	130	199	0.09	6	214	398	4X10	A
2	ENS	1.63	42	1.51	50	0.17	37	140	177	0.1	5	308	367	3X10	B
3	WIC	0.38	10	0.11	4	0.17	30	120	150	0.11	4	115	46	3X10	B
4	BED-2	1.69	44	2.50	82	0.16	32	150	182	0.09	6	224	418	4X10	D
5	BED-3	1.72	44	2.59	85	0.16	34	140	174	0.09	6	224	433	4X10	C
6	BED-4	2.04	52	2.77	91	0.16	40	120	160	0.1	6	265	464	4X10	D
7	BATH	0.65	17	0.40	13	0.17	32	120	152	0.11	4	195	149	3X10	D
8	BED-3	1.72	44	2.59	85	0.16	42	150	192	0.08	6	224	433	4X10	C
9	BED-4	2.04	52	2.77	91	0.16	46	130	176	0.09	6	265	464	4X10	D
10	MBR	1.65	42	2.37	78	0.17	56	190	246	0.07	6	214	398	4X10	A
11	ENS-4	0.78	20	0.19	6	0.17	36	160	196	0.09	4	229	69	3X10	D
13	FAM	2.31	59	2.56	84	0.16	53	130	183	0.09	6	301	428	4X10	A
14	KT/BR	1.72	44	2.44	80	0.17	42	150	192	0.13	6	224	408	4X10	A
15	KT/BR	1.72	44	2.44	80	0.17	35	100	135	0.12	6	224	408	4X10	B
16	LV/DN	3.08	79	2.65	88	0.16	14	120	212	0.08	6	403	449	4X10	D
17	LAUN	0.15	4	0.08	3	0.17	32	180	212	0.12	4	46	34	3X10	B
18	PWD	0.55	14	0.35	12	0.17	14	130	144	0.12	4	161	138	3X10	C
19	FOY	3.36	86	1.50	50	0.16	30	140	160	0.1	6	438	255	4X10	C
20	MUD	1.50	39	0.25	8	0.17	45	130	185	0.09	4	447	92	3X10	A
21	BAS	3.55	91	0.57	19	0.16	48	110	178	0.09	6	464	97	4X10	A
22	BAS	3.55	91	0.57	19	0.16	29	130	139	0.12	6	464	97	4X10	B
23	BAS	3.55	91	0.57	19	0.16	8	130	138	0.12	6	464	97	4X10	B
24	BAS	3.55	91	0.57	19	0.16	20	120	140	0.12	6	464	97	4X10	C

SUPPLY AIR TRUNK SIZE												RETURN AIR TRUNK SIZE											
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)			
TRUNK A	317	0.07	9.4	10	x	8	571	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0
TRUNK B	599	0.07	12	16	x	8	674	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0
TRUNK C	279	0.08	8.7	10	x	8	502	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0
TRUNK D	543	0.08	11.2	16	x	8	611	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0

RETURN AIR #	1	2	3	4	5	6	7											BR	TRUNK W TRUNK X TRUNK Y TRUNK Z DROD	0	0.05	0	0	x	8	0
AIR VOLUME	130	130	75	75	85	340	130	0	0	0	0	0	0	0	0	0	180	1145		0.05	16.6	32	x	8	644	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	340		0.05	10.5	14	x	8	437	
ACTUAL DUCT LGH.	49	41	39	46	45	24	39	1	1	1	1	1	1	1	1	1	14	0		0.05	0	0	x	8	0	
EQUIVALENT LENGTH	195	175	275	235	195	120	215	0	0	0	0	0	0	0	0	0	135	1145		0.05	16.6	24	x	10	687	
TOTAL EFFECTIVE LH	244	216	314	281	240	144	254	1	1	1	1	1	1	1	1	1	149									
ADJUSTED PRESSURE	0.06	0.07	0.05	0.05	0.06	0.10	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.10									
ROUND DUCT SIZE	7	6.8	6	6	6	8.9	7	0	0	0	0	0	0	0	0	0	7									
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8									
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X									
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	14									

TYPE: 38-11  
SITE NAME: CENTREFIELD (WEST GORMLEY)

LO # 87614

**RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY**

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	<input checked="" type="checkbox"/> Direct vent (sealed combustion) only	
b)	<input type="checkbox"/> Positive venting induced draft (except fireplaces)	
c)	<input type="checkbox"/> Natural draft, B-vent or induced draft gas fireplace	
d)	<input type="checkbox"/> Solid Fuel (including fireplaces)	
e)	<input type="checkbox"/> No Combustion Appliances	

HEATING SYSTEM	
<input checked="" type="checkbox"/> Forced Air	<input type="checkbox"/> Non Forced Air
<input type="checkbox"/> Electric Space Heat	

HOUSE TYPE		9.32.1(2)
<input checked="" type="checkbox"/> I	Type a) or b) appliance only, no solid fuel	
<input type="checkbox"/> II	Type I except with solid fuel (including fireplaces)	
<input type="checkbox"/> III	Any Type c) appliance	
<input type="checkbox"/> IV	Type I, or II with electric space heat	
<input type="checkbox"/>	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
<input type="checkbox"/> 1	Exhaust only/Forced Air System	
<input type="checkbox"/> 2	HRV with Ducting/Forced Air System	
<input checked="" type="checkbox"/> 3	HRV Simplified/connected to forced air system	
<input type="checkbox"/> 4	HRV with Ducting/non forced air system	
<input type="checkbox"/>	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>3</u> @ 10.6 cfm	<u>31.8</u> cfm
Kitchen & Bathrooms	<u>5</u> @ 10.6 cfm	<u>53</u> cfm
Other Rooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Table 9.32.3.A.	TOTAL	<u>169.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>79.5</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>169.6</u>	cfm
Less Principal Ventil. Capacity	<u>79.5</u>	cfm
Required Supplemental Capacity	<u>90.1</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE 65H
Location:	BSMT
<u>79.5</u> cfm	<input checked="" type="checkbox"/> HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	$\Delta T$ °F	FACTOR	% LOSS	
79.5 CFM	X 78 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
BATH	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
PWD	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE 65H	
<u>155</u> cfm high	<u>64</u> cfm low	
<u>75</u> % Sensible Efficiency @ 32 deg F (0 deg C)	<input checked="" type="checkbox"/> HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
ROYAL PINE HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-21

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

*Michael O'Rourke*

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 87614	Model: 38-11	Builder: ROYAL PINE HOMES	Date: 4/19/2021																																																									
<b>Volume Calculation</b>			<b>Air Change &amp; Delta T Data</b>																																																									
<b>House Volume</b> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1154</td> <td>10</td> <td>11540</td> </tr> <tr> <td>First</td> <td>1154</td> <td>10</td> <td>11655.4</td> </tr> <tr> <td>Second</td> <td>1520</td> <td>9</td> <td>13680</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>36,875.4 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1044.2 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1154	10	11540	First	1154	10	11655.4	Second	1520	9	13680	Third	0	9	0	Fourth	0	9	0	Total:			36,875.4 ft³	Total:			1044.2 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.227</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.071</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-21</td> <td style="text-align: center;">43</td> <td style="text-align: center;">78</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">24</td> <td style="text-align: center;">31</td> <td style="text-align: center;">7</td> <td style="text-align: center;">13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.227	SUMMER NATURAL AIR CHANGE RATE	0.071	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1154	10	11540																																																									
First	1154	10	11655.4																																																									
Second	1520	9	13680																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			36,875.4 ft³																																																									
Total:			1044.2 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.227																																																											
SUMMER NATURAL AIR CHANGE RATE	0.071																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	24	31	7	13																																																								
<b>5.2.3.1 Heat Loss due to Air Leakage</b>			<b>6.2.6 Sensible Gain due to Air Leakage</b>																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ <p>0.227 x 290.05 x 43 °C x 1.2 = 3408 W</p> <p>= 11629 Btu/h</p>			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ <p>= 0.071 x 290.05 x 7 °C x 1.2 = 175 W</p> <p>= 597 Btu/h</p>																																																									
<b>5.2.3.2 Heat Loss due to Mechanical Ventilation</b>			<b>6.2.7 Sensible heat Gain due to Ventilation</b>																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 78 °F x 1.08 x 0.25 = 1670 Btu/h</p>			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h</p>																																																									
<b>5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)</b>																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL <sub>clevel</sub> )	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	11,629	8,384	0.693																																																								
2	0.3		10,746	0.325																																																								
3	0.2		12,804	0.182																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
<p>*HLairbv = Air leakage heat loss + ventilation heat loss</p> <p>*For a balanced or supply only ventilation system HLairve = 0</p>																																																												

**HEAT LOSS AND GAIN SUMMARY SHEET****MODEL:** 38-11**BUILDER:** ROYAL PINE HOMES**SFQT:** 2674**LO#** 87614**SITE:** CENTREFIELD (WEST GORMLEY)**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

**BUILDING DATA**

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft <sup>3</sup> ):	36875.4	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft <sup>2</sup> ):	1.65	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 52.0 ft	WIDTH: 32.0 ft	EXPOSED PERIMETER:	168.0 ft

**2012 OBC - COMPLIANCE PACKAGE****Component****Compliance Package  
SB-12 PERFORMANCE****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.20
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.70
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22+1.5	18.50
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	1.6	-
Skylights Maximum U-Value	2.6	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	TE=94%	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



# Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	15.8	 Insulation Configuration
Floor Width (m):	9.8	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m <sup>2</sup> ):	1.4	
Door Area (m <sup>2</sup> ):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1665

TYPE: 38-11

LO# 87614

# Air Infiltration Residential Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Richmond Hill			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.74			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m <sup>3</sup> ):	1044.2			
Air Leakage/Ventilation				
Air Tightness Type:	Energy Star Detached (2.5 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	974.8 cm <sup>2</sup>		
	2.50	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.227			
Cooling Air Leakage Rate (ACH/H):	0.071			


TYPE: 38-11

LO# 87614






BASEMENT FLOOR PLAN ELEV. 'A'



BASEMENT FLOOR PLAN ELEV. 'B'



BASEMENT FLOOR PLAN ELEV. 'C'

CSA-F280-12


SB-12 PERFORMANCE

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.  
*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	REVISED AS PER ARCHITECTURALS	APR/2021
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE	SEPT/2020
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client		<div></div> <div>375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services</div>		HEAT LOSS 46201 BTU/H UNIT DATA		# OF RUNS S/A R/A FANS			Sheet Title	
Project Name CENTREFIELD (WEST GORMLEY) RICHMOND HILL, ONTARIO				MAKE CARRIER		3RD FLOOR			BASEMENT HEATING LAYOUT	
				MODEL 59TN6A-060-14V		2ND FLOOR				
				INPUT 60 MBTU/H		1ST FLOOR				
38-112674 sqft		OUTPUT 58 MBTU/H		BASEMENT			Date			
		COOLING 3.0 TONS		ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			Scale			
		FAN SPEED 1145 cfm @ 0.6" w.c.					BCIN# 19669			
							LO# 87614			



GROUND FLOOR PLAN ELEV. 'A'



GROUND FLOOR PLAN ELEV. 'B'



GROUND FLOOR PLAN ELEV. 'C'

CSA-F280-12


SB-12 PERFORMANCE

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.  
*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	REVISED AS PER ARCHITECTURALS	APR/2021
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE	SEPT/2020
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


Client		<div></div> <div>375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services</div> <div>Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.</div>	Sheet Title	
ROYAL PINE HOMES			FIRST FLOOR HEATING LAYOUT	
Project Name			Date	SEPT/2020
CENTREFIELD (WEST GORMLEY) RICHMOND HILL, ONTARIO			Scale	3/16" = 1'-0"
		BCIN# 19669		
38-11		LO#	87614	
2674 sqft				



SECOND FLOOR PLAN ELEV. 'A'



SECOND FLOOR PLAN ELEV. 'B'



SECOND FLOOR PLAN ELEV. 'C'

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.

CSA-F280-12

SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.	REVISED AS PER ARCHITECTURALS	APR/2021
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE	SEPT/2020
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		<div></div> <div>375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services</div> <div>Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.</div>	Sheet Title	
ROYAL PINE HOMES			SECOND FLOOR HEATING LAYOUT	
Project Name			Date	SEPT/2020
CENTREFIELD (WEST GORMLEY) RICHMOND HILL, ONTARIO			Scale	3/16" = 1'-0"
38-11		BCIN# 19669		
2674 sqft		LO#	87614	