

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality BRAMPTON	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 7001 - ELEV C OPT IN-LAW Project: VALES OF HUMBER SOUTH	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 7, 2022			
Date		Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: VALES OF HUMBER SOUTH										OPT IN-LAW						DATE Apr-22				WINTER NATURAL AIR CHANGE RATE 0.241						HEAT LOSS ΔT °F. 74		CSA-F280-12																	
BUILDER: ROYAL PINE HOMES										TYPE: 7001 - ELEV C						GFA: 5590				LO# 95345				SUMMER NATURAL AIR CHANGE RATE 0.078						HEAT GAIN ΔT °F. 11		SB-12 PERFORMANCE													
ROOM USE				GREAT				KIT				PAINT				DIN				LIV				FOY				IN-LAW				PWD-1				PWD-2				MD/LN					
EXP. WALL				48				32				20				26				30				20				22				3				8				33					
CLG. HT.				21				11				11				11				11				23				11				11				11				12					
FACTORS																																													
GRS.WALL AREA		LOSS GAIN		1008				352				220				286				330				460				242				33				88				396					
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN					
NORTH		20.8	15.5	0	0	0		0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		25	519	387						
EAST		20.8	41.0	0	0	0		0	0	0		0	0	0	0		34	706	1396	33		686	1355	34		706	1396	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0
SOUTH		20.8	24.4	0	0	0		0	0	0		0	0	0	39		810	951	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
WEST		20.8	41.0	192	3989	7881		107	2223	4392		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
SKYLT.		34.1	100.3	0	0	0		0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
DOORS		24.7	3.7	0	0	0		20	493	73		0	0	0	0		0	0	0	0		60	1479	219	0		0	0	0	0		0	0	0	0		40	986	146						
NET EXPOSED WALL		3.5	0.5	816	2829	419		225	780	116		220	763	113		247	856	127	296		1026	152	367		1272	189	208		721	107	33		114	17	88		305	45	331		1148	170			
NET EXPOSED BSMT WALL ABOVE GR		3.5	0.5	0	0	0		0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
EXPOSED CLG		1.3	0.6	503	630	280		0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
NO ATTIC EXPOSED CLG		2.7	1.2	10	27	12		0	0	0		0	0	0	0		0	0	0	0		80	215	95	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
EXPOSED FLOOR		2.5	0.4	0	0	0		0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	
BASEMENT/CRAWL HEAT LOSS																																													
SLAB ON GRADE HEAT LOSS																																													
SUBTOTAL HT LOSS						7475				3496				763				1667			1733				3652			1428				114			305			2653							
SUB TOTAL HT GAIN							8593				4581			113			1078			1548				1858			1503				17			45			703								
LEVEL FACTOR / MULTIPLIER				0.30		0.37			0.30		0.37			0.30		0.37		0.30		0.37			0.30		0.37			0.30		0.37			0.30		0.37			0.30		0.37					
AIR CHANGE HEAT LOSS						2788					1304			285			622			646				1362			533				43			114			990								
AIR CHANGE HEAT GAIN							466				248			6			58			84				101			81				1			2			38								
DUCT LOSS						0					0			0			0			0				0			0				0			0			0								
DUCT GAIN						0					0			0			0			0			0			0				0			0			0			0						
HEAT GAIN PEOPLE		240				0			0		0			0		0		0		0		0		0		1		240		0		0		0		0		0		0		0			
HEAT GAIN APPLIANCES/LIGHTS							1636				1636			0			1636			1636				0			1		1636			0			0			0		1636					
TOTAL HT LOSS BTU/H						10264					4800			1047			2288			2379				5014			1960				157			419			3643								
TOTAL HT GAIN x 1.3 BTU/H							13903				8404			155			3604			4248				2546			4498				23			62			3090								

ROOM USE																							
EXP. WALL																							
CLG. HT.																							
FACTORS																							
GRS.WALL AREA	LOSS	GAIN																					
GLAZING																							
NORTH	20.8	15.5	0	0	0																		
EAST	20.8	41.0	0	0	0																		
SOUTH	20.8	24.4	0	0	0																		
WEST	20.8	41.0	0	0	0																		
SKYLT.	34.1	100.3	0	0	0																		
DOORS	24.7	3.7	0	0	0																		
NET EXPOSED WALL	3.5	0.5	121	420	62																		
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0																		
EXPOSED CLG	1.3	0.6	0	0	0																		
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0																		
EXPOSED FLOOR	2.5	0.4	0	0	0																		
BASEMENT/CRAWL HEAT LOSS			0																				
SLAB ON GRADE HEAT LOSS			0																				
SUBTOTAL HT LOSS																							
SUB TOTAL HT GAIN				420																			
LEVEL FACTOR / MULTIPLIER	0.30	0.37																					
AIR CHANGE HEAT LOSS																							
AIR CHANGE HEAT GAIN																							
DUCT LOSS				0																			
DUCT GAIN				0																			
HEAT GAIN PEOPLE	240		0																				
HEAT GAIN APPLIANCES/LIGHTS																							
TOTAL HT LOSS BTU/H				576																			
TOTAL HT GAIN x 1.3 BTU/H					85																		

TOTAL HEAT GAIN BTU/H: 76833

TONS: 6.40

LOSS DUE TO VENTILATION LOAD BTU/H: 6010

STRUCTURAL HEAT LOSS: 83912

TOTAL COMBINED HEAT LOSS BTU/H: 89922



[illegible]

TOTAL COMBINED HEAT LOSS BTU/H: 89922

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

OPT IN-LAW
TYPE: 7001 - ELEV C

DATE: Apr-22

GFA: 5590 LO# 95345

FURNACE 1

HEATING CFM 1370 COOLING CFM 1370
TOTAL HEAT LOSS 59,851 TOTAL HEAT GAIN 42,330
AIR FLOW RATE CFM 22.89 AIR FLOW RATE CFM 32.36

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 62857 BTUH**

#CARRIER

AFUE = 97 %

59SP5A-80-16
80

INPUT (BTU/H) = 80,000

OUTPUT (BTU/H) = **78,000**

FAN SPEED

LOW 0

DESIGN CFM = **1370**

MEDLOW 975

CFM @ .6" E.S.P.

MEDIUM 1200

MEDIUM HIGH 1370

HIGH 1540

TEMPERATURE RISE 53 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	21	8
R/A	0	0	0	5	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	GREAT	GREAT	GREAT	GREAT	GREAT	KIT	KIT	KIT	PANT	DIN	DIN	LIV	LIV	FOY	FOY	IN-LAW	IN-LAW	PWD-1	PWD-2	MD/LN	BAS	BAS	BAS	BAS
RM LOSS MBH.	2.05	2.05	2.05	2.05	2.05	1.60	1.60	1.60	1.05	1.14	1.14	1.19	1.19	2.51	2.51	0.98	0.98	0.16	0.42	3.64	3.41	3.41	3.41	3.41
CFM PER RUN HEAT	47	47	47	47	47	37	37	37	24	26	26	27	27	57	57	22	22	4	10	83	78	78	78	78
RM GAIN MBH.	2.78	2.78	2.78	2.78	2.78	2.80	2.80	2.80	0.15	1.80	1.80	2.12	2.12	1.27	1.27	2.25	2.25	0.02	0.06	3.09	0.21	0.21	0.21	0.21
CFM PER RUN COOLING	90	90	90	90	90	91	91	91	5	58	58	69	69	41	41	73	73	1	2	100	7	7	7	7
ADJUSTED PRESSURE	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	31	25	21	23	28	35	47	53	55	50	62	78	74	78	82	81	87	31	11	18	53	38	21	25
EQUIVALENT LENGTH	100	100	120	140	120	110	90	110	100	120	110	100	120	150	130	120	130	120	170	140	110	100	130	130
TOTAL EFFECTIVE LENGTH	131	125	141	163	148	145	137	163	155	170	172	178	194	228	212	201	217	151	181	158	163	138	151	155
ADJUSTED PRESSURE	0.12	0.13	0.11	0.1	0.11	0.11	0.12	0.1	0.11	0.1	0.1	0.1	0.09	0.08	0.08	0.09	0.08	0.11	0.1	0.1	0.11	0.12	0.11	0.11
ROUND DUCT SIZE	6	6	6	6	6	6	6	6	4	5	5	5	5	5	5	6	6	4	4	6	5	5	5	5
HEATING VELOCITY (ft/min)	240	240	240	240	240	189	189	189	275	191	191	198	198	419	419	112	112	46	115	423	573	573	573	573
COOLING VELOCITY (ft/min)	459	459	459	459	459	464	464	464	57	426	426	507	507	301	301	372	372	11	23	510	51	51	51	51
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10
TRUNK	F	F	F	E	E	E	E	D	D	C	C	A	A	A	B	B	B	E	E	F	D	E	E	F

RUN #	25	26	27	28	29
ROOM NAME	BAS	BAS	BAS	BAS	I-ENS
RM LOSS MBH.	3.41	3.41	3.41	3.41	0.58
CFM PER RUN HEAT	78	78	78	78	13
RM GAIN MBH.	0.21	0.21	0.21	0.21	0.09
CFM PER RUN COOLING	7	7	7	7	3
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	52	58	71	78	60
EQUIVALENT LENGTH	110	110	110	100	120
TOTAL EFFECTIVE LENGTH	162	168	181	178	180
ADJUSTED PRESSURE	0.11	0.1	0.1	0.1	0.1
ROUND DUCT SIZE	5	5	5	5	4
HEATING VELOCITY (ft/min)	573	573	573	573	149
COOLING VELOCITY (ft/min)	51	51	51	51	34
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10
TRUNK	C	C	A	B	B

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
TRUNK	STATIC	ROUND	RECT	VELOCITY						TRUNK	STATIC	ROUND	RECT	VELOCITY					
CFM	PRESS.	DUCT	DUCT							CFM	PRESS.	DUCT	DUCT						
TRUNK A	189	0.08	7.5	8	x	8	425			TRUNK G	0	0.00	0	0	x	8	0		
TRUNK B	192	0.08	7.6	8	x	8	432			TRUNK H	0	0.00	0	0	x	8	0		
TRUNK C	589	0.08	11.5	16	x	8	663			TRUNK I	0	0.00	0	0	x	8	0		
TRUNK D	139	0.10	6.3	8	x	8	313			TRUNK J	0	0.00	0	0	x	8	0		
TRUNK E	1066	0.08	14.4	24	x	8	800			TRUNK K	0	0.00	0	0	x	8	0		
TRUNK F	302	0.10	8.5	10	x	8	544			TRUNK L	0	0.00	0	0	x	8	0		

RETURN AIR #	1	2	3	4	5	BR									
AIR VOLUME	330	155	360	130	130	0	0	0	0	0	0	0	0	0	265
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	15	55	55	63	60	1	1	1	1	1	1	1	1	1	16
EQUIVALENT LENGTH	145	205	200	205	165	0	0	0	0	0	0	0	0	0	185
TOTAL EFFECTIVE LH	160	260	255	268	225	1	1	1	1	1	1	1	1	1	201
ADJUSTED PRESSURE	0.09	0.06	0.06	0.06	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.07
ROUND DUCT SIZE	9	7.5	10.3	7	6.8	0	0	0	0	0	0	0	0	0	8.8
INLET GRILL SIZE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	30	14	14	0	0	0	0	0	0	0	0	0	30

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

OPT IN-LAW
TYPE: 7001 - ELEV C

DATE: Apr-22

GFA: 5590 LO# 95345

FURNACE 2

HEATING CFM 1040 COOLING CFM 1040
TOTAL HEAT LOSS 24,060 TOTAL HEAT GAIN 34,057
AIR FLOW RATE CFM 43.22 AIR FLOW RATE CFM 30.54

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 27065 BTUH**
#*CARRIER
59SP5A-40-12
40

AFUE = 97 %

INPUT (BTU/H) = 40,000

OUTPUT (BTU/H) = **39,000**

FAN SPEED

LOW 0

MEDLOW 0

MEDIUM 0

MEDIUM HIGH 770

HIGH 1040

DESIGN CFM = **1040**

CFM @ .6" E.S.P.

TEMPERATURE RISE 35 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	20	0	0
R/A	0	0	7	0	0

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	15	16	17	18	19	20	21
ROOM NAME	PRI	PRI	PRI	ENS	ENS	DRESS	BED-2	BED-2	ENS-2	WIC-4	BED-3	BED-3	ENS-3	BED-4	BED-4	ENS-4	BED-5	BED-5	SHARED	RETR
RM LOSS MBH.	1.12	1.12	1.12	2.13	0.71	0.98	1.02	1.02	0.90	0.95	1.55	1.55	2.25	1.41	1.41	0.28	1.25	1.25	0.64	1.41
CFM PER RUN HEAT	48	48	48	92	31	42	44	44	39	41	67	67	97	61	61	12	54	54	28	61
RM GAIN MBH.	2.11	2.11	2.11	1.99	0.66	0.47	1.84	1.84	0.34	1.08	2.13	2.13	1.99	2.57	2.57	0.08	2.30	2.30	0.41	3.02
CFM PER RUN COOLING	65	65	65	61	20	14	56	56	10	33	65	65	61	78	78	2	70	70	12	92
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.16
ACTUAL DUCT LGH.	84	69	63	90	85	85	43	38	33	41	37	42	49	64	58	39	94	88	80	92
EQUIVALENT LENGTH	190	200	210	160	170	200	180	180	110	110	120	130	130	190	220	110	170	170	170	190
TOTAL EFFECTIVE LENGTH	274	269	273	250	255	285	223	218	143	151	157	172	179	254	278	149	264	258	250	282
ADJUSTED PRESSURE	0.06	0.06	0.06	0.06	0.07	0.06	0.08	0.08	0.12	0.11	0.11	0.1	0.09	0.07	0.06	0.12	0.07	0.07	0.07	0.06
ROUND DUCT SIZE	6	6	6	6	4	5	5	5	4	4	6	6	6	6	6	4	6	6	4	6
HEATING VELOCITY (ft/min)	245	245	245	469	356	308	323	323	447	470	342	342	495	311	311	138	275	275	321	311
COOLING VELOCITY (ft/min)	331	331	331	311	229	103	411	411	115	379	331	331	311	398	398	23	357	357	138	469
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	4X10	3X10	4X10	4X10	3X10	4X10
TRUNK	A	A	A	A	A	A	B	B	B	D	D	B	B	C	C	D	C	C	C	C

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY					
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)					
TRUNK A	309	0.06	9.7	10	x	8	556	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0				
TRUNK B	600	0.06	12.4	18	x	8	600	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0				
TRUNK C	319	0.06	9.8	14	x	8	410	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0				
TRUNK D	439	0.06	11.1	18	x	8	439	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0				
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0				

RETURN AIR #	1	2	3	4	5	6	7	BR											
AIR VOLUME	280	95	230	115	115	75	130	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	46	42	54	66	89	60	53	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	175	165	245	205	210	215	205	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	221	207	299	271	299	275	258	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.07	0.07	0.05	0.05	0.05	0.05	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	9	6	9.1	7	7	6	7	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	30	14	14	14	14	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: 7001 - ELEV C
SITE NAME: VALES OF HUMBER SOUTH

LO # 95345
OPT IN-LAW

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>5</u> @ 10.6 cfm	<u>53</u> cfm
Kitchen & Bathrooms	<u>9</u> @ 10.6 cfm	<u>95.4</u> cfm
Other Rooms	<u>6</u> @ 10.6 cfm	<u>63.6</u> cfm
Table 9.32.3.A.	TOTAL	<u>254.4</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
6 Bedrooms		
As Per Ashrea 62.2 Dwelling- Unit Ventilation		
4.1.1 Total Ventilation Rate		
$Q_{tot}=0.03A_{floor}+7.5(N_{br}+1)$		
TOTAL		<u>220.2</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>254.4</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>104.4</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE V150H
Location:	BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 74 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	INSTALL 2 HRV / ERV's
<u>150</u>	cfm high	<u>35</u> cfm low
<u>75</u>	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
ROYAL PINE HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																													
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																													
LO#: 95345		Model: 7001 - ELEV C		Builder: ROYAL PINE HOMES																																																									
				Date: 2022-04-07																																																									
Volume Calculation			Air Change & Delta T Data																																																										
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2793</td> <td>10</td> <td>27930</td> </tr> <tr> <td>First</td> <td>2793</td> <td>11</td> <td>30723</td> </tr> <tr> <td>Second</td> <td>3336</td> <td>10</td> <td>33360</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>92,013.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>2605.5 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2793	10	27930	First	2793	11	30723	Second	3336	10	33360	Third	0	9	0	Fourth	0	9	0	Total:			92,013.0 ft³	Total:			2605.5 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.241</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.078</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-19</td> <td>41</td> <td>74</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>30</td> <td>6</td> <td>11</td> </tr> </tbody> </table>			WINTER NATURAL AIR CHANGE RATE	0.241	SUMMER NATURAL AIR CHANGE RATE	0.078	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-19	41	74	Summer DTDc	24	30	6	11
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																										
Bsmt	2793	10	27930																																																										
First	2793	11	30723																																																										
Second	3336	10	33360																																																										
Third	0	9	0																																																										
Fourth	0	9	0																																																										
Total:			92,013.0 ft³																																																										
Total:			2605.5 m³																																																										
WINTER NATURAL AIR CHANGE RATE	0.241																																																												
SUMMER NATURAL AIR CHANGE RATE	0.078																																																												
Design Temperature Difference																																																													
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																									
Winter DTDh	22	-19	41	74																																																									
Summer DTDc	24	30	6	11																																																									
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																										
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.241 x 723.76 x 41 °C x 1.2 = 8639 W = 29475 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.078 x 723.76 x 6 °C x 1.2 = 416 W = 1421 Btu/h																																																										
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																										
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 74 °F x 1.08 x 0.25 = 6010 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 11 °F x 1.08 x 0.25 = 891 Btu/h																																																										
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																													
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																													
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																									
1	0.5	29,475	12,566	1.173																																																									
2	0.3		23,705	0.373																																																									
3	0.2		17,044	0.346																																																									
4	0		0	0.000																																																									
5	0		0	0.000																																																									
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																													
				Michael O'Rourke BCIN# 19669 																																																									

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 7001 - ELEV C	OPT IN-LAW	BUILDER: ROYAL PINE HOMES
SFQT: 5590	LO# 95345	SITE: VALES OF HUMBER SOUTH

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-2	OUTDOOR DESIGN TEMP.	86
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.60

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	92013.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	7
INTERIOR LIGHTING LOAD (Btu/h/ft²):	2.20	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 63.0 ft	WIDTH: 62.0 ft	EXPOSED PERIMETER:	250.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
SB-12 PERFORMANCE****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22+1.5	21.40
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	1.6	-
Skylights Maximum U-Value	2.6	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.9	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	19.2	 Insulation Configuration
Floor Width (m):	18.9	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	2.2	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2619

TYPE: 7001 - ELEV C
LO# 95345

OPT IN-LAW

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Brampton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.32			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2605.5			
Air Leakage/Ventilation				
Air Tightness Type:	Energy Star Detached (2.5 ACH)			
Custom BDT Data:	ELA @ 10 Pa.		2432.2 cm ²	
	2.50		ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply		Total Exhaust	
	70.8		70.8	
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.241			
Cooling Air Leakage Rate (ACH/H):	0.078			

TYPE: 7001 - ELEV C
LO# 95345

OPT IN-LAW