

It is the builder's complete responsibility to ensure that all plans submitted for approval fully comply with the Architectural Guidelines and all applicable regulations and requirements including zoning provisions and any provisions in the subdivision agreement. The Control Architect is not responsible in any way for working or approving site (lotting) plans or submitting drawings with respect to any zoning or building code or permit matter or that any house can be properly built or located on its lot.

This is to certify that these plans comply with the applicable Architectural Design Guidelines approved by the Township of King. **ARCHITECTURAL REVIEW & APPROVAL**

[illegible]

This is to certify that these plans comply with the applicable Architectural Design Guidelines approved by the Township of KING ARCHITECTURAL REVIEW & APPROVAL

200.40
DANGER - HIGH VOLTAGE(S)
Use Approved Shielding / Use Warning Device

Site plan of Arabian B 42-07 REV. (9BASEMENT) showing building footprint, parking areas, and surrounding infrastructure. The plan includes dimensions, elevations, and labels for various features like 'ARABIAN B 42-07 REV. (9BASEMENT)', 'PARKING', 'W.O.B.', and '1.50m CONC. SIDEWALK'. It also shows a '2.4m HIGH WOOD ACOUSTIC FENCE' and a '1.50m CONC. SIDEWALK'.

NOTES:

- Builder to verify storm and sanitary service lateral elevations prior to pouring footings
- Extend footings at front to ensure 1.25M cover (Min)
- Garage footings to extend to original ground or as directed by soils engineer.

I have reviewed the site and grading plan for the proposed building(s) to be constructed on lot(s) 82 and hereby certify that:

1. The proposed grading and appurtenant drainage works comply with sound engineer principles.
2. The proposed grading is in conformity with the grading plan approved for the subdivision and will not adversely affect adjacent lands.
3. The proposed building is compatible with the proposed grading.

Date:

A circular professional seal for a Licensed Professional Engineer in the Province of Ontario. The seal contains the following information:

- Top Arc:** LICENSED PROFESSIONAL ENGINEER
- Bottom Arc:** PROVINCE OF ONTARIO
- Center:** K. CHEN
- Below Name:** 100136982
- Right Side (Vertical):** DEC 11 2012
- Signature:** A stylized signature is written across the left side of the seal.

DATE _____

SIGNATURE _____

LOT NUMBER 82

ARN design
Imagine • Inspire • Create
TEL: (905) 738-3177
FAX: (905) 738-5449
DWG@ARNDESIGN.COM

**SOUND BARRIER
FOOTING TO BE EXTENDED
TO 1.25 (MIN) BELOW GRADE**

[illegible]

LOT NUMBER 82