

Brody Guenther

Service Work Order

Number: 36770
Entered: 3/4/2022

TRUDEL & SONS ROOFING LTD.

5 Paisley Lane
Stouffville, ONT L4A7X4

Duplicate

Service

Location:

Zancor Homes - COOKSTOWN
LOT 33
32 VICTORIA STREET
COOKSTOWN ONT

Contacts:

Phone:
Mobile:

Bill To:

Zancor Homes
221 North Rivermede Rd.
Concord, ONT L4K 3N7

PO Number:

Payment Method:

Customer Code:

Bill Out
ZANC

Call Type:

Repair

Est. Hours/Priority:

1.00

Problem:

Builder Work Order See Attached

Permission Code:

Homeowner

Scheduled:

3/4/2022

Scheduled Time:

8:00 am

Technician:

Brody Guenther

Job Priority:

High

Fax Back No:

Service Dept Comments:

INSPECT LEAK AT ROOF MASTER CLOSET LEAK.

Parts:

(To Be Filled In By Technician)

Labour:

(To Be Filled In By Technician)

Comments & Notes: (Technician)

To Do Items:

Work Order Notes:

THIS IS AN ICE DAMNING ISSUES. ALOT OF SNOW AND ICE IN AREA. IF THIS LEAKS AGAIN WHEN THERE IS NO SNOW OR ICE ON ROOF AREA WE WILL REVISIT.

INSPECTED FEB. 28/22
LOT 33 - COOKSTOWN