

Mark.

MAY 16 @ 8:00 AM



Zancor Homes (Block 81) Ltd.
Warranty Services
Phone: (905) 738-7010
Fax: (905) 738-5948

Work Order

Closing Date: 21May21
Address: 32 Tatton Court
King City, Ontario
Location: The Village at Kings Ridge - Phase: 1 - Lot: Block 4 Unit 19
Today's Date: 06May22
Contact(s): Matthew, Paul Vanelli - Cell: (647) 505-8172 - (mattvanelli@gmail.com)
Chantelle, Bianca Vanelli - Cell: (647) 505-8172
Email: mattvanelli@gmail.com

Company: Dart Electric
Attention: Danny or Lisa
Telephone: (905) 761-5758
Fax: (905) 761-5269

Please Complete the following items:

DAI	Type	Issue		Appt. Date/Time	Notes
147535	Emergency	Other- General- home inspector has informed that the Smoke Alarm outside of our Bedrooms is not a Co2 & Smoke detector which is Code and Law.	request for 3-1 Co2 Smoke		

Date Completed: MAY 16/22

Homeowner Signature: Mark
The Homeowner acknowledges and accepts all work has been completed in a workman like manner.

Date Completed: MAY 16/22

Trade &/or Service Tech.

Signature: Mark Deluca

Print Name: MARK DELUCA

Please schedule your Service Department to complete work on the above Lot. Should no appointment time or date appear (below) on this form, it is your responsibility to arrange and adhere to the appointment you have scheduled. Your service representative must have this form signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.

Failure to comply with this request within 10 business days will give Zancor Homes (and

Zancor Homes

32 Tatton Crt

May 13 2022

Homeowner (Chantelle) has notified me that their home inspector has made a note regarding the AFCI breakers used in the home and the homeowner has asked us to confirm that the AFCI breakers used are new style with the neutral bus bar connection.

I have requested that the homeowner prints the original work order that she is referencing so we can have the homeowner sign off.

Nicholas Paldino | Dart Electric Ltd.

Homeowner of 32 Tatton Crt Blk 4 Unit 19 | Zancor Homes