



NEWMAR WINDOW MFG. INC.
ALPA LUMBER GROUP

7630 AIRPORT ROAD, MISSISSAUGA, ON L4T 4G6
TEL (905) 672-1233 FAX (905) 672-1076

WO # W189021

Pack Slip: 240573

Service Date: Aug 29, 2023

Priority: Normal Status: SCHEDULED

BUILDER

Customer: N000531 City: CALEDON Received: Jun 12, 2023
Name: ZANCOR CALEDON CLUB Service Phone(s): Time: 1ST CALL
Service Fax: Site Phone: Order: D390012-1
Site Fax: Lot#: 130B Phase: 1B

RESIDENT INFORMATION

Home Owner Name: N/A Address: N/A
Home Phone(s): Work Phone(s):
Cell Phone(s): Email(s):

LINKED ORDER INFORMATION (D390012-1)

Customer: N000531 ZANCOR CALEDON CLUB Lot #: 130B
Model: 38-01 MAGNA (CB)/LOT 130B Phase: 1B

SERVICE INSTRUCTIONS

MISSING LOCKS AND WHEEL FROM THE SLIDING DOOR.

PARTS REQUIRED

LN	Item Description	Location	Specification	Size	Options	Qty
60	BUCKINGHAM PURCH. PATIO DOOR MISSING LOCKS AND WHEEL FROM THE SLIDING DOOR. and meeting rail	RR/ KIT	OTHER RPLCMNT PARTS	117.125 X 95.5	CB 61316 CENTRE OPEN RIGHT BUCKINGHAM PURCH. PATIO DOOR	1

Problem Description:

☐ Warranty

Material \$

Labour \$

Cause:

☐ CHARGEABLES

Material \$

Labour \$

P.O.#:

Solution:

Date Completed: Aug 29 2023

Approved:

Time:

Service Signature: ALEX

No back from builder.

6/12/23, 9:13 AM

Newmar / Casa Bella Mail - Fwd: *IS* D390012-1 Lot 130B - ZANCOR CALEDON CLUB - N000531



Service Department <servicedept@newmar.com>

Fwd: *IS* D390012-1 Lot 130B - ZANCOR CALEDON CLUB - N000531

1 message

Melissa Green <mgreen@newmar.com>
To: Service Department <servicedept@newmar.com>

Mon, Jun 5, 2023 at 1:46 PM

----- Forwarded message -----

From: COPS <cops@newmar.com>
Date: Mon, Jun 5, 2023 at 12:14 PM
Subject: *IS* D390012-1 Lot 130B - ZANCOR CALEDON CLUB - N000531
To: <service@newmar.com>
Cc: <tcamara@newmar.com>



INSTALL SERVICE EMAIL REQUIRED



Install
Required

In Progress



Install
Completed

BRICKLAYERS "NOTE":

A clearance of 1/4" must be left on both sides and top of the frame and
1/2" (first floor) 1" (second floor) on bottom of frames.

Contact **Newmar** for bottom clearances above two floors.

WARNING! Failure to adhere to the above voids all performance warranties

First Install: Monday February 13, 2023

Last Install: Monday June 05, 2023

Installer's Name:

D390012-1 N000531 - ZANCOR CALEDON CLUB

Sl's ID: 0038

Lot / Phase: 130B / 1B

House Model: 38-01 MAGNA (CB)/LOT 130B

Elevation: C

Back Sls ID: 040572

6/12/23, 9:13 AM

Newmar / Casa Bella Mail - Fwd: 'IS' D390012-1 Lot 130B - ZANCOR CALEDON CLUB - N000531

Back Supp. 240073

Line Count Summary

Pieces to Load: 1
Openings Count: 1
Outstanding: 0
Installed: 1
Not Installed: 0
Backordered: 0
Cancelled: 0
Site Joins: 1

INSTALLATION ITEMS

LN #60 / ITEM SVPD

QTY: 1 **INSTALLED** (06-05-2023) (confirmed)

LOCATION: RR/ KIT

SIZE: 117.125 X 95.5 CENTRE OPEN RIGHT **SWING: C**

OPTIONS: 61316 CB CLR 10 FT

NOTES: Nothing wheels nothing locks

Notes Saved On: Jun 05, 2023 12:14:48 pm

(Email Sent to Service Dept)

NEWMAR WINDOW MFG. INC.
7630 AIRPORT ROAD, MISSISSAUGA, ON L4T 4G6

**** IN ORDER TO BETTER SERVE OUR CUSTOMERS, PLEASE NOTE THAT EFFECTIVE IMMEDIATELY ALL NEW SERVICE REQUESTS ARE TO BE SENT TO servicedept@newmar.com *****if inquiring about a follow up please email me directly at mgreen@newmar.com

Thank you 😊

Melissa Green
Customer Service Coordinator



Service Department <servicedept@newmar.com>

Fwd: Zancor caledon lot 130B

1 message

Melissa Green <mgreen@newmar.com>
To: Service Department <servicedept@newmar.com>

Wed, Aug 16, 2023 at 2:24 PM

----- Forwarded message -----

From: **Louie Tesoro** <tesorotruck13@gmail.com>
Date: Wed, Aug 16, 2023 at 2:21 PM
Subject: Zancor caledon lot 130B
To: Newmar <service@newmar.com>
Cc: Tesoro <tesorowindows@bellnet.ca>, Ted <tschlosser@newmar.com>

RR/kit- patio door H bar missing from slab

**** IN ORDER TO BETTER SERVE OUR CUSTOMERS, PLEASE NOTE THAT EFFECTIVE IMMEDIATELY ALL NEW SERVICE REQUESTS ARE TO BE SENT TO servicedept@newmar.com *****if inquiring about a follow up please email me directly at mgreen@newmar.com

Thank you 😊

Melissa Green
Customer Service Coordinator



20230816_140253.jpg
2060K