



IN-SERVICE Work Order

WO No: W-233856

WO Date: 02/09/2024

Contractor: RYAN WALL

Builder : ZANCOR HOMES

Project : R-ZAN526 - ZANCOR-RIVERSEDGE-WASAG

Address :

City : WASAGA BEACH

Contact :

Phone :

Cell:

Lot No: 277

Model: 40-04

Block:

Phase:

Name:

Closing:

PDI Date:

Sch'd Date

Start Date

Comp Date

Unit Model

Serial No

02/12/2024

ML196UH070XE36B-19A

1723J25238

QTY

MATERIAL & WORK REQUIRED

SERIAL NO

- moved HRV control Down inline with T-stat. control wire was located by Electrician. NOT National.

- Balanced House.

* Could NOT find super to tell Her control is moved but she needs to call Electrician in future. They locate control wire

WO Notes :

** Please arrive 9-1
Booked with builder

A heat balance is required, inventory home
HRV stat in the family need to be lowered, installed too high and not in line with the thermostat

Contractor

Invoice No

Invoice Amt

Date

Site Super Sign